

OKLAHOMA STATE UNIVERSITY

ENVIRONMENTAL HEALTH & SAFETY DEPARTMENT



2006 INCIDENT REPORT LOG

Weekly reports on fire alarms, ambulance calls, accident investigations, hazmat response, and other activities that required immediate response by EHS personnel

**OSU EHS Department
Incident Summary**
For the Period 07/3/06 – 07/9/06

134A-06 07-3-06 2:15 p.m. Kelley
Incident: Ambulance Assist
Location: Gallagher-Iba Arena
Details: Patient injured right shoulder while wrestling; transported to SMC.

134B-06 07-3-06 2:45 pm Kelley
Incident: Fire Alarm
Location: Morrison Apartments, #110
Details: No fire; malfunctioning vacuum cleaner created dust that set off the fire alarm.

134C-06 07-3-06 10:20 pm Kelley
Incident: Fire Alarm
Location: Peterson Apartments, #108
Details: No fire; Smoke from cooking set off fire alarm.

135-06 07-6-06 4:18 pm Kelley
Incident: Ambulance Assist
Location: Library
Details: Patient suffered a seizure; transported to SMC.

136-06 07-7-06 5:45 am Nutt
Incident: Fire Alarm
Location: Business Bldg.
Details: No fire; application of floor wax around an uncovered electrical outlet created a short circuit.

OSU EHS Department
Incident Summary
For the Period 07/10/06 – 07/16/06

137-06	07-11-06	12:45 pm	Nutt
--------	----------	----------	------

Incident: Fire Alarm

Location: Human Environmental Science

Details: Construction personnel accidentally pulled pull box.

138-06	07-14-06	4:19 am	Kelley
--------	----------	---------	--------

Incident: Fire Alarm

Location: ATRC

Details: No fire; possibility that lightning may have activated alarm system.

**OSU EHS Department
Incident Summary**
For the Period 07/17/06 – 07/23/06

139-06	07-17-06	2:30 pm	Nutt
Incident: Fire Alarm			
Location: Human Environmental Science			
Details: Pull box in construction area was pulled.			
140-06	07-17-06	4:50 pm	Kelley
Incident: Ambulance Assist			
Location: McElroy and Walnut intersection			
Details: Auto/Bicycle accident, 10-year-old riding bicycle going west on McElroy turned south into the crosswalk in front of the auto. Bicyclist received injuries to head and legs and was transported to SMC.			
141-06	07-18-06	9:15 am	Nutt
Incident: Fire Alarm			
Location: South Boone Pickens Stadium			
Details: Construction dust set off fire alarm.			
142-06	07-19-06	7:40 am	Nutt
Incident: Fire Alarm			
Location: Human Environmental Sciences West			
Details: Construction dust set off the fire alarm.			
143-06	07-19-06	9:18 pm	Kelley
Incident: Fire Alarm			
Location: Morrison Apartments 206			
Details: Fire alarm in unoccupied apartment; no fire.			
144-06	07-20-06	9:06 am	Lundy
Incident: Accident Investigation			
Location: Cordell South, Construction area			
Details: Person slipped and fell outside Cordell South in construction area, hit lower back on step, no medical attention required at time of incident.			
145-06	07-20-06	10:45 am	Lundy
Incident: Ambulance Assist			
Location: Animal Science Arena			
Details: Participant in livestock judging event fainted from heat exhaustion; SFD EMT's attended to victim; patient declined transport to SMC.			
146-06	07-20-06	2:10 pm	Lundy
Incident: Ambulance Assist			
Location: Noble Research Center, Room 348, Building D			
Details: Participant at REYAPE camping event suffered heat exhaustion. SFD EMT's treated victim and transported to SMC.			

147-06 07-21-06 10:30 pm Lundy

Incident: Fire Alarm

Location: Classroom Building 1st Floor

Details: Cleaning crew was dry buffing the floor and created enough dust to activate the alarm.

148-06 07-22-06 7:50 am Lundy

Incident: Fire Alarm

Location: 205 Sitlington Apartments

Details: Resident awoke to find smoke in her apartment. No cause for the smoke was found. EHS standby unplugged a candle pot. Physical Plant Evening Operations was called to look for any signs of heat or fire damage; EHS standby returned later to recheck the area and found no smoke.

149-06 07-22-06 11:10 pm Lundy

Incident: Fire Alarm

Location: Campus Southeast Quadrant (Student Union, Gundersen, Alumni Center)

Details: OG&E electrical outage caused alarms in Southeast Quadrant area.

OSU EHS Department
Incident Summary
For the Period 07/24/06 – 07/30/06

150-06 07-24-06 6:30 am Lundy
Incident: Fire Alarm
Location: Engineering North, 2nd floor
Details: Dirty smoke detector activated alarm

151-06 07-25-06 12:05 pm Lundy
Incident: Ambulance Assist
Location: Corner of Stout Lane and Parker Lane
Details: Person stepped in hole and injured right ankle. Area marked off with tape.

152-06 07-25-06 10:15 am Lundy
Incident: Stuck Elevator
Location: Food and Animal Processing Center
Details: Elevator stuck between 2nd & 3rd floors with 1 occupant inside. Elevator company contacted and doors opened manually.

153-06 07-25-06 4:30 pm Lundy
Incident: Smoke Investigation
Location: Business Building South Elevator
Details: There was a burned up generator on the elevator system. Elevator company made repairs.

154-06 07-27-06 3:05pm Fox
Incident: Chemical spill
Location: Physical Science 408
Details: Lab personnel were cleaning out chemicals from a freezer and a bottle broke.

155-06 07-27-06 3:30 pm Lundy
Incident: Fire Alarm
Location: Stout Hall, Room 243
Details: Smoke from burned popcorn in the microwave activated fire alarm. No Fire.

OSU EHS Department
Incident Summary
For the Period 07/31/06 – 08/6/06

156-06	08-02-06	1:05 pm	Fox
--------	----------	---------	-----

Incident: Chemical spill

Location: Gallagher-Iba Arena, loading dock

Details: Diesel leaking from trailer parked by loading docks.

157-06	08-04-06	7:52 pm	Kelley
--------	----------	---------	--------

Incident: Ambulance Assist

Location: Colvin Center Gym #3, north side

Details: patient with seizure; transported to SMC

158-06	08-01-06	4:35 pm	Kelley
--------	----------	---------	--------

Incident: Ambulance Assist

Location: Student Union, outside of room 432

Details: Patient fell; transported to SMC

OSU EHS Department
Incident Summary
For the Period 08/7/06 – 08/13/06

159-06	08-07-06	5:54 pm	Kelley
--------	----------	---------	--------

Incident: Ambulance Assist

Location: Student Health Center, 1st floor, room 137

Details: patient with severe pain transported to SMC

160-06	08-07-06	10:20 am	Nutt
--------	----------	----------	------

Incident: Fire Alarm

Location: South Stadium

Details: Dust in west elevator shaft created by construction crews caused alarm.

161-06	08-08-06	2:45 pm	Nutt
--------	----------	---------	------

Incident: Fire Alarm

Location: Village Apartments, Bldg. A

Details: JPI employee cut through sprinkler line on 4th floor

162-06	08-08-06	3:18 pm	Fox
--------	----------	---------	-----

Incident: Chemical odor

Location: University Mailing Services

Details: Construction employee applying floor sealant in enclosed building

163-06	08-12-06	10:45 PM	Nutt
--------	----------	----------	------

Incident: Fire Alarm

Location: Patchin/Jones Hall

Details: Residents misunderstood their move-in documents to test their smoke detector and set off alarm

164-06	08-13-06	6:40 pm	Nutt
--------	----------	---------	------

Incident: Fire Alarm

Location: 114 Friend Hall

Details: Burning food caused smoke detector to activate

OSU EHS Department
Incident Summary
For the Period 08/14/06 – 08/20/06

165-06	08-14-06	Kelley
Incident:	Ambulance Assist	
Location:	Cordell South Wing, hallway near room 189	
Details:	OSU Custodian became ill at work	

166-06	08-15-06	Kelley
Incident:	Chemical Spill	
Location:	Physical Sciences, Room 144	
Details:	Custodian found a small amount of a liquid on floor	

167-06	08-15-06	Kelley
Incident:	Ambulance Assist	
Location:	Corner of Walnut and Scott	
Details:	disoriented individual	

168-06	08-16-06	Kelley
Incident:	Smoke Investigation	
Location:	Stout Hall, 4 th floor North wing	
Details:	student's suitcase was smoldering, too close to heat of exhaust pipe in car's trunk	

169-06	08-16-06	Nutt
Incident:	Fire Alarm	
Location:	Stinchcomb Hall	
Details:	dirty smoke detector set off fire alarm	

**OSU EHS Department
Incident Summary**
For the Period 08/21/06 – 08/27/06

170-06	08-21-06	9:45 am	Nutt
Incident:	Fire Alarm		
Location:	Peterson-Friend-Kamm Complex		
Details:	Use of hair dryer too close to smoke detector set off fire alarm		
171-06	08-21-06	10:28 pm	Kelley
Incident:	Fire Alarm		
Location:	Zink Hall		
Details:	Steam from burned popcorn activated fire alarm		
172-06	08-21-06	4:41 pm	Kelley
Incident:	Fire Alarm		
Location:	Career Tech North Bldg. 2 nd floor hallway		
Details:	Burned popcorn activated fire alarm		
173-06	08-22-06	4:00 pm	Nutt
Incident:	Ambulance assist		
Location:	Student Union		
Details:	OSU employee passed out in bathroom; transported to SMC		
174-06	08-24-06	8:30 am	Nutt
Incident:	Fire Alarm		
Location:	Lake Carl Blackwell store		
Details:	Cause of fire alarm unknown; store clerk reset alarm system before EHS arrived.		
175-06	08-24-06	10:30 am	Nutt
Incident:	Fire Alarm		
Location:	Murray Hall North		
Details:	Heat detector in hallway was accidentally hit		
176-06	08-24-06	6:25 pm	Kelley
Incident:	Fire Alarm		
Location:	Classroom Bldg. 3 rd floor, west stairs		
Details:	Accidental pulling of fire alarm pull box		
177-06	08-24-06	9:56 pm	Kelley
Incident:	Fire Alarm		
Location:	Village Apts.		
Details:	Steam from burnt popcorn set off fire alarm		
178-06	08-25-06	2:20 PM	Nutt
Incident:	Ambulance Assist		
Location:	South Stadium		
Details:	Heat-related distress		
179-06	08-25-06	7:22 pm	Kelley
Incident:	Fire Alarm		
Location:	Jones Suites		
Details:	Resident using spray paint under smoke detector in room		

180-06	08-26-06	3:52 AM	Kelley
Incident:	Fire Alarm		
Location:	Bennett Hall West, 1 st floor SW exit		
Details:	Someone pulled fire alarm pull box		
181-06	08-26-06	10:15 AM	Kelley
Incident:	Fire Alarm		
Location:	Colvin Center, lower level Basketball Court #4		
Details:	Volleyball hit fire alarm pull box activating alarm		
182-06	08-25-06	2:57 PM	Kelley
Incident:	Fire Alarm		
Location:	Friend Apts.		
Details:	Smoke from cooking activated alarm		
183-06	08-26-06	5:15 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apts. Bldg. B		
Details:	Steam from burned popcorn activated fire alarm		
184-06	08-76-06	4:15 PM	Kelley
Incident:	Fire Alarm		
Location:	Beef Cattle Arena 2 nd floor living area closet		
Details:	Ceiling tile with heat detector fell and broke heat sensor on detector		

**OSU EHS Department
Incident Summary**
For the Period 08/28/06 – 09/03/06

185-06	08-28-06	Kelley
Incident:	Fire alarm	
Location:	Stinchcomb Hall	
Details:	Humidifier running near smoke detector activated alarm	
186-06	08-28-06	Kelley
Incident:	Fire Alarm	
Location:	Village Apts. Bldg. B	
Details:	Burned popcorn activated alarm	
187-06	08-29-06	Nutt
Incident:	Fire Alarm	
Location:	Peterson Hall	
Details:	Burned food activated alarm	
188-06	08-30-06	Nutt
Incident:	Ambulance Assist	
Location:	Student Health Services	
Details:	Transported patient to SMC	
189-06	08-31-06	Nutt
Incident:	Fire Alarm	
Location:	Sitlington Hall	
Details:	Burned food activated alarm	
190-06	08-31-06	Nutt
Incident:	Fire Alarm	
Location:	Carreker Hall West	
Details:	Resident burning incense activated alarm	
191-06	08-31-06	Kelley
Incident:	Fire Alarm	
Location:	South Stadium, 7 th Floor West Elevator Control	
Details:	Dust from maintenance work activated alarm	
192-06	09-01-06	Nutt
Incident:	Fire Alarm	
Location:	Stinchcomb Hall 4 th Floor Corridor	
Details:	No cause for the alarm could be found	
193-06	09-02-06	Lundy
Incident:	Fire Alarm	
Location:	Press Box, South Stadium, #021, Elevator Control Room	
Details:	Smoke detector activated by residual dust	
194-06	09-03-06	Lundy
Incident:	Fire Alarm	
Location:	Zink Hall Room	
Details:	Smoke detector activated by hair dryer	

OSU EHS Department
Incident Summary
For the Period 08/7/06 – 08/13/06

159-06	08-07-06	5:54 pm	Kelley
--------	----------	---------	--------

Incident: Ambulance Assist

Location: Student Health Center, 1st floor, room 137

Details: patient with severe pain transported to SMC

160-06	08-07-06	10:20 am	Nutt
--------	----------	----------	------

Incident: Fire Alarm

Location: South Stadium

Details: Dust in west elevator shaft created by construction crews caused alarm.

161-06	08-08-06	2:45 pm	Nutt
--------	----------	---------	------

Incident: Fire Alarm

Location: Village Apartments, Bldg. A

Details: JPI employee cut through sprinkler line on 4th floor

162-06	08-08-06	3:18 pm	Fox
--------	----------	---------	-----

Incident: Chemical odor

Location: University Mailing Services

Details: Construction employee applying floor sealant in enclosed building

163-06	08-12-06	10:45 PM	Nutt
--------	----------	----------	------

Incident: Fire Alarm

Location: Patchin/Jones Hall

Details: Residents misunderstood their move-in documents to test their smoke detector and set off alarm

164-06	08-13-06	6:40 pm	Nutt
--------	----------	---------	------

Incident: Fire Alarm

Location: 114 Friend Hall

Details: Burning food caused smoke detector to activate

OSU EHS Department
Incident Summary
For the Period 08/14/06 – 08/20/06

165-06	08-14-06	Kelley
Incident:	Ambulance Assist	
Location:	Cordell South Wing, hallway near room 189	
Details:	OSU Custodian became ill at work	

166-06	08-15-06	Kelley
Incident:	Chemical Spill	
Location:	Physical Sciences, Room 144	
Details:	Custodian found a small amount of a liquid on floor	

167-06	08-15-06	Kelley
Incident:	Ambulance Assist	
Location:	Corner of Walnut and Scott	
Details:	disoriented individual	

168-06	08-16-06	Kelley
Incident:	Smoke Investigation	
Location:	Stout Hall, 4 th floor North wing	
Details:	student's suitcase was smoldering, too close to heat of exhaust pipe in car's trunk	

169-06	08-16-06	Nutt
Incident:	Fire Alarm	
Location:	Stinchcomb Hall	
Details:	dirty smoke detector set off fire alarm	

**OSU EHS Department
Incident Summary**
For the Period 08/21/06 – 08/27/06

170-06	08-21-06	9:45 am	Nutt
Incident:	Fire Alarm		
Location:	Peterson-Friend-Kamm Complex		
Details:	Use of hair dryer too close to smoke detector set off fire alarm		
171-06	08-21-06	10:28 pm	Kelley
Incident:	Fire Alarm		
Location:	Zink Hall		
Details:	Steam from burned popcorn activated fire alarm		
172-06	08-21-06	4:41 pm	Kelley
Incident:	Fire Alarm		
Location:	Career Tech North Bldg. 2 nd floor hallway		
Details:	Burned popcorn activated fire alarm		
173-06	08-22-06	4:00 pm	Nutt
Incident:	Ambulance assist		
Location:	Student Union		
Details:	OSU employee passed out in bathroom; transported to SMC		
174-06	08-24-06	8:30 am	Nutt
Incident:	Fire Alarm		
Location:	Lake Carl Blackwell store		
Details:	Cause of fire alarm unknown; store clerk reset alarm system before EHS arrived.		
175-06	08-24-06	10:30 am	Nutt
Incident:	Fire Alarm		
Location:	Murray Hall North		
Details:	Heat detector in hallway was accidentally hit		
176-06	08-24-06	6:25 pm	Kelley
Incident:	Fire Alarm		
Location:	Classroom Bldg. 3 rd floor, west stairs		
Details:	Accidental pulling of fire alarm pull box		
177-06	08-24-06	9:56 pm	Kelley
Incident:	Fire Alarm		
Location:	Village Apts.		
Details:	Steam from burnt popcorn set off fire alarm		
178-06	08-25-06	2:20 PM	Nutt
Incident:	Ambulance Assist		
Location:	South Stadium		
Details:	Heat-related distress		
179-06	08-25-06	7:22 pm	Kelley
Incident:	Fire Alarm		
Location:	Jones Suites		
Details:	Resident using spray paint under smoke detector in room		

180-06	08-26-06	3:52 AM	Kelley
Incident:	Fire Alarm		
Location:	Bennett Hall West, 1 st floor SW exit		
Details:	Someone pulled fire alarm pull box		

181-06	08-26-06	10:15 AM	Kelley
Incident:	Fire Alarm		
Location:	Colvin Center, lower level Basketball Court #4		
Details:	Volleyball hit fire alarm pull box activating alarm		

182-06	08-25-06	2:57 PM	Kelley
Incident:	Fire Alarm		
Location:	Friend Apts.		
Details:	Smoke from cooking activated alarm		

183-06	08-26-06	5:15 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apts. Bldg. B		
Details:	Steam from burned popcorn activated fire alarm		

184-06	08-76-06	4:15 PM	Kelley
Incident:	Fire Alarm		
Location:	Beef Cattle Arena 2 nd floor living area closet		
Details:	Ceiling tile with heat detector fell and broke heat sensor on detector		

**OSU EHS Department
Incident Summary**
For the Period 08/28/06 – 09/03/06

185-06	08-28-06	Kelley
Incident:	Fire alarm	
Location:	Stinchcomb Hall	
Details:	Humidifier running near smoke detector activated alarm	
186-06	08-28-06	Kelley
Incident:	Fire Alarm	
Location:	Village Apts. Bldg. B	
Details:	Burned popcorn activated alarm	
187-06	08-29-06	Nutt
Incident:	Fire Alarm	
Location:	Peterson Hall	
Details:	Burned food activated alarm	
188-06	08-30-06	Nutt
Incident:	Ambulance Assist	
Location:	Student Health Services	
Details:	Transported patient to SMC	
189-06	08-31-06	Nutt
Incident:	Fire Alarm	
Location:	Sitlington Hall	
Details:	Burned food activated alarm	
190-06	08-31-06	Nutt
Incident:	Fire Alarm	
Location:	Carreker Hall West	
Details:	Resident burning incense activated alarm	
191-06	08-31-06	Kelley
Incident:	Fire Alarm	
Location:	South Stadium, 7 th Floor West Elevator Control	
Details:	Dust from maintenance work activated alarm	
192-06	09-01-06	Nutt
Incident:	Fire Alarm	
Location:	Stinchcomb Hall 4 th Floor Corridor	
Details:	No cause for the alarm could be found	
193-06	09-02-06	Lundy
Incident:	Fire Alarm	
Location:	Press Box, South Stadium, #021, Elevator Control Room	
Details:	Smoke detector activated by residual dust	
194-06	09-03-06	Lundy
Incident:	Fire Alarm	
Location:	Zink Hall Room	
Details:	Smoke detector activated by hair dryer	

**OSU EHS Department
Incident Summary**
For the Period 09/04-/06 – 09/10/06

195-06	09-04-06	Lundy
Incident:	Fire Alarm	
Location:	Peterson-Friend-Kamm Hall	
Details:	Smoke detector activated by burned food	
196-06	09-04-06	Lundy
Incident:	Fire Alarm	
Location:	Wentz Hall, north side breezeway	
Details:	Fire in trash can; cause unknown	
197-06	09-01-06	Nutt
Incident:	Fire Alarm	
Location:	Kamm Hall	
Details:	Smoke detector activated by burned food	
198-06	09-05-06	Kelley
Incident:	Fire Alarm	
Location:	Village Apartments, Bldg. D	
Details:	Smoke detector activated; unknown cause	
199-06	09-07-06	Kelley
Incident:	Fire Alarm	
Location:	Smith Apartments	
Details:	Smoke detector activated; unknown cause	
200-06	09-08-06	Kelley
Incident:	Fire Alarm	
Location:	Village Apts.	
Details:	Burned popcorn activated smoke detector	
201-06	09-09-06	Mason
Incident:	Fire Alarm	
Location:	Allen Hall	
Details:	Smoke from cooking on grill on patio entered apt and activated alarm	
202-06	09-10-06	Mason
Incident:	Fire Alarm	
Location:	NW corner of Kamm Hall	
Details:	Fire in dumpster, unknown cause	
203-06	09-10-06	Kelley
Incident:	Fire Alarm	
Location:	Peterson Apts.	
Details:	Smoke from cooking activated fire alarm	

**OSU EHS Department
Incident Summary**
For the Period 09/11/06 – 09/17/06

204-06	09-11-06	Nutt
Incident:	Ambulance Assist	
Location:	1111 North Hester	
Details:	OSU employee fell through rotten roof while working	

205-06	09-12-06	Kelley
Incident:	Fire Alarm	
Location:	Softball Complex, elevator equipment room & pressbox	
Details:	Fire alarm activated, unknown cause	

206-06	09-17-06	Nutt
Incident:	Fire Alarm	
Location:	Friend Hall	
Details:	Smoke alarm activated by burned food	

207-06	09-17-06	Nutt
Incident:	Fire Alarm	
Location:	Village Apts, Bldg. B	
Details:	Smoke detector activated by steam from the shower	

208-06	09-17-06	Nutt
Incident:	Fire Alarm	
Location:	Carreker Hall East	
Details:	Pull box activated; no fire	

213-06	09-16-06	Mason
Incident:	Fire Investigation	
Location:	South Boone Pickens Stadium, lower club level	
Details:	Hot charcoal placed in plastic trash can causing fire	

**OSU EHS Department
Incident Summary**
For the Period 09/18/06 – 09/24/06

209-06	09-19-06	Nutt
Incident:	Fire Alarm	
Location:	Jones Hall	
Details:	Burned food activated smoke alarm	
210-06	09-18-06	Nutt
Incident:	Fire Alarm	
Location:	Sitlington Hall	
Details:	Burned food activated fire alarm	
211-06	09-19-06	Nutt
Incident:	Fire Alarm	
Location:	Noble Research Center; "A" Wing	
Details:	Electrician caused arc in mechanical room, activating local smoke detector	
212-06	09-19-06	Nutt
Incident:	Fire Alarm	
Location:	Gallagher Iba Arena	
Details:	Dirty smoke detector activated fire alarm	
214-06	09-20-06	Kelley
Incident:	Fire alarm	
Location:	Gallagher-Iba Arena 323-326	
Details:	Dirty beam detector activated smoke alarm	
215-06	09-21-06	Kelley
Incident:	Fire Alarm	
Location:	Village Apartments, Bldg. F	
Details:	Steam from electric tea kettle activated smoke alarm	
216-06	09-21-06	Nutt
Incident:	Fire Alarm	
Location:	Noble Center, B Wing, Mechanical Room	
Details:	Construction activity in mechanical room set off smoke detector	
218-06	09-24-06	Kelley
Incident:	Fire Alarm	
Location:	Ag Hall North basement, east stairs by room 0159	
Details:	Faulty smoke detector	

**OSU EHS Department
Incident Summary**
For the Period 09/25/06 – 10/01/06

217-06	09-25-06	Nutt
Incident:	Fire Alarm	
Location:	Friend Hall	
Details:	Hair dryer activated smoke alarm in apartment	
219-06	09-26-06	Kelley
Incident:	Explosion	
Location:	Fractionation Facility	
Details:	Pressure relief valve on steam line popped off due to excessive pressure	
220-06	09-26-06	Kelley
Incident:	Fire Alarm	
Location:	Seretean Performing Arts Center, 1 st floor, North zone	
Details:	Fire alarm activated; unknown cause	
221-06	09-29-06	Nutt
Incident:	Ambulance Assist	
Location:	Sidewalk area north of Library	
Details:	Participant in President's Charity Walk fell, injuring ankle	
222-06	09-29-06	Kelley
Incident:	Fire Alarm	
Location:	Peterson Hall	
Details:	Candle burning in apartment activated smoke alarm	
223-06	09-29-06	Kelley
Incident:	Fire Alarm	
Location:	4-H Building	
Details:	Button-type heat detector accidentally hit while working on light fixtures	
224-06	09-27-06	Nutt
Incident:	Fire Alarm	
Location:	McPherson Hall	
Details:	Pull box accidentally activated	
225-06	09-27-06	Kelley
Incident:	Fire Alarm	
Location:	Morrison Apts., Bldg. 245	
Details:	Pull box activated, unknown cause	
226-06	09-28-06	Nutt
Incident:	Fire Alarm	
Location:	Young Hall	
Details:	Burned food activated smoke detector	
227-06	09-30-06	Spybuck
Incident:	Fire Alarm	
Location:	Peterson Hall	
Details:	Smoke from grilling entered apartment and activated smoke detector	

228-06 10-01-06
Incident: Fire Alarm
Location: Kamm Hall
Details: Smoke from cooking activated smoke detector

Spybuck

**OSU EHS Department
Incident Summary**
For the Period 10/02/06 – 10/8/06

228-06	10-01-06	10:30 AM	Spybuck
Incident:	Fire Alarm		
Location:	Kamm Hall		
Details:	Smoke from cooking activated smoke detector		
229-06	10-02-06	8:58 PM	Kelley
Incident:	Ambulance Assist		
Location:	Soccer Field at Willis & McElroy		
Details:	Soccer player injured left knee		
230-06	10-02-06	9:48 PM	Kelley
Incident:	Ambulance Assist		
Location:	West side of Bost Hall in parking lot		
Details:	Student ill		
231-06	09-29-06	9:55 PM	Kelley
Incident:	Ambulance Assist		
Location:	Village Apartments, Bldg. A		
Details:	Student with severe abdominal pain		
232-06	10-03-06	2:30 PM	Lundy
Incident:	Fire		
Location:	Edmond Low Library		
Details:	Small fire from cigarette thrown in front-door flower bed		
233-06	10-03-06	8:52 PM	Kelley
Incident:	Ambulance Assist		
Location:	North side of Athletic Ave., east of Hester St.		
Details:	Person tripped on curb and fell		
234-06	10-06-06	11:30 AM	Nutt
Incident:	Fire alarm		
Location:	Sitlington Hall		
Details:	Burned food activated alarm system		
235-06	10-08-06	2:15 AM	Lundy
Incident:	Fire alarm		
Location:	Sitlington Hall		
Details:	Smoke from burned food activated alarm system		

**OSU EHS Department
Incident Summary**
For the Period 10/09/06 – 10/15/06

236-06	10-11-06	12:30 PM	Nutt
Incident:	Ambulance Assist		
Location:	Hall of Fame & Farm Road		
Details:	Problem with medication		
237-06	10-11-06	3:00 PM	Spybuck
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E, Community Kitchen		
Details:	Smoke from burned food activated fire alarm system		
238-06	10-11-06	5:30 PM	Kelley
Incident:	Gasoline Spill		
Location:	Monroe Street in front of PIO Bldg.		
Details:	Large spill of gasoline from ruptured gas tank		
239-06	10-11-06	7:19 PM	Kelley
Incident:	Fire Alarm		
Location:	Colvin Center, basement basketball courts		
Details:	Basketball hit fire alarm pull box		
240-06	10-11-06	8:40 PM	Kelley
Incident:	Odor Investigation		
Location:	University Apartments		
Details:	Very strong skunk odor		
241-06	10-11-06	9:17 PM	Kelley
Incident:	Fire Alarm		
Location:	Patchin-Jones Suites		
Details:	Large fire in dumpster caused by hot coals from grill		
242-06	10-13-06	7:55 PM	Kelley
Incident:	Fire Alarm		
Location:	Old Central, 1 st floor		
Details:	Fog machine being used for haunted house; activated smoke detector		
243-06	10-14-06	12:25 PM	Mason
Incident:	Morrison Apartments, Bldg. 245		
Location:	Fire Alarm		
Details:	Unknown person pulled the fire alarm pull box		
244-06	10-14-06	3:00 PM	Mason
Incident:	Fire Alarm		
Location:	Univ. Mailing/Landscape Architecture Mailing Bldg.		
Details:	Dust from sanding of sheetrock activated smoke detector		

245-06	10-14-06	10:00 PM	Mason
Incident:	Fire		
Location:	University Apartments, Bldg. 39		
Details:	Igniter on stove shorted out causing the stove to spark		
246-06	10-15-06	6:15 am & 10:00 AM	Mason
Incident:	Fire Alarm		
Location:	Noble Center, D wing, fourth floor		
Details:	Unknown cause for fire alarm		
247-06	10-15-06	11:00 AM	Mason
Incident:	Sprinkler Leak		
Location:	Village Apartments, Bldg. C, first floor		
Details:	T connection in sprinkler pipe was leaking		
248-06	10-12-06	10:33 PM	Kelley
Incident:	Ambulance Assist		
Location:	Intramural fields west of Wellness Center		
Details:	Patient hit in chest playing flag football		

**OSU EHS Department
Incident Summary**
For the Period 10/16/06 – 10/22/06

249-06	10-18-06	3:45 AM	Mason
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Occupant sprayed air freshener in room, which activated smoke detector		
250-06	10-18-06	10:15 AM	Nutt
Incident:	Fire Alarm		
Location:	Patchin Suites		
Details:	Clothes steamer left on, activated smoke detector		
251-06	10-18-06	1:15 PM	Nutt
Incident:	Ambulance Assist		
Location:	Intersection of Monroe and McElroy		
Details:	Traffic accident		
252-06	10-19-06	8:44 PM	Kelley
Incident:	Fire Alarm		
Location:	Young Hall		
Details:	Smoke from cooking activated smoke detector		
253-06	10-21-06	12:00 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		
254-06	10-20-06	5:51 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke from cooking activated smoke alarm		
255-06	10-21-06	6:20 PM	Nutt
Incident:	Fire Alarm		
Location:	Cordell Hall		
Details:	Pull box activated by unknown person		
256-06	10-21-06	2:30 PM	Nutt
Incident:	Fire Alarm		
Location:	Student Union Food Court		
Details:	Heat detector in food court activated by heat from cooking		
257-06	10-22-06	12:00 AM	Nutt
Incident:	Fire Alarm		
Location:	Telecommunications Bldg.		
Details:	Smoke detector activated by unknown cause		

**OSU EHS Department
Incident Summary**
For the Period 10/23/06 – 10/29/06

258-06	10-23-06	10:45 AM	Nutt
Incident:	Fire Alarm		
Location:	Whitehurst		
Details:	Broken water line shorted out smoke detector, activating fire alarm		
259-06	10-23-06	11:00 AM	Nutt
Incident:	Ambulance Assist		
Location:	Cordell Hall		
Details:	Student having difficulty breathing in classroom		
260-06	10-23-06	6:40 PM	Kelley
Incident:	Fire Alarm		
Location:	Kamm Apartments		
Details:	Resident testing new smoke/fog machine in room activated smoke detector		
261-06	10-24-06	5:00 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D, lounge area		
Details:	Plastic left on stove melted and created smoke, which activated the detector		
262-06	10-24-06	8:00 PM	Kelley
Incident:	Ambulance Assist		
Location:	Hall of Fame, west of Cowboy Mall		
Details:	Student injured in automobile accident		
263-06	10-25-06	12:00 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		
264-06	10-25-06	10:30 AM	Nutt
Incident:	Smoke Investigation		
Location:	104 Willard Hall		
Details:	Burnt light ballast caused sparks and smoke to issue from a light fixture		
265-06	10-25-06	11:30 AM	Nutt
Incident:	Ambulance Assist		
Location:	412 Student Union		
Details:	Person fell down steps		
266-06	10-25-06	12:10 PM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Burned popcorn activated smoke alarm		
267-06	10-26-06	5:00 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Fire alarm pull box activated		

268-06	10-27-06	6:45 PM	Kelley
Incident:	Ambulance Assist		
Location:	Intramural Soccer Field on Walnut		
Details:	Patient injured left elbow playing soccer		
269-06	10-28-06	9:42 PM	Kelley
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Smoke from cooking activated smoke alarm		
270-06	10-28-06	11:05 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke alarm activated by unknown cause		
271-06	10-29-06	10:31 AM	Kelley
Incident:	Fire Alarm		
Location:	Kamm Apartments		
Details:	Smoke from cooking activated smoke alarm		
272-06	10-28-06	5:45 PM	Nutt
Incident:	Fire Alarm		
Location:	University Print Building		
Details:	Dust created by construction workers activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 10/30/06 – 11/05/06

273-06	10-30-06	1:20 PM	Nutt
Incident:	Fire Alarm		
Location:	WW-CITD		
Details:	Alarm pull box activated, unknown cause		
274-06	10-30-06	3:45 PM	Kelley
Incident:	Water flow from sprinkler pipe		
Location:	Sitlington Hall		
Details:	Broken sprinkler head in laundry area		
275-06	10-30-06	5:45 PM	Kelley
Incident:	Ambulance Assist		
Location:	Intersection of Scott & Walnut		
Details:	Automobile accident		
276-06	10-30-06	7:39 PM	Kelley
Incident:	Ambulance Assist		
Location:	Intramural Fields, Near McElroy & Willis		
Details:	Soccer player knocked unconscious while playing soccer		
277-06	10-31-06	9:06 PM	Kelley
Incident:	Fire Alarm		
Location:	West Bennett Hall		
Details:	Burned food activated smoke detector		
278-06	11-01-06	3:18 AM	Kelley
Incident:	Fire Alarm		
Location:	Young Hall, 2 nd floor breezeway		
Details:	Alarm pull box activated by unknown person		
279-06	11-01-06	3:20 PM	Nutt
Incident:	Ambulance Assist		
Location:	Fire Service Training Building		
Details:	OSU employee fell		
280-06	11-01-06	6:44 PM	Kelley
Incident:	Ambulance Assist		
Location:	Intramural fields, South field nearest Farm Road		
Details:	Flag football player injured right knee		
281-06	11-01-06	11:15 PM	Kelley
Incident:	Investigation of possible tampering		
Location:	Village Apartments, Bldg. F		
Details:	Resident cited for tampering smoke detector and horn		
282-06	11-02-06	8:30 PM	Kelley
Incident:	Domestic hot water line break		
Location:	Village Apartments, Bldg. B, 4 th Floor		
Details:	Hot water line separated at elbow, water dripping down to 1 st floor		

283-06	11-03-06	12:15 PM	Germain
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E. 1 st floor kitchen		
Details:	Grease fire on stove		
284-06	11-03-06	10:07 PM	Kelley
Incident:	Ambulance Assist		
Location:	Engineering South		
Details:	Patient cut left index finger using a drill press		
285-06	11-04-06	4:00 PM	Lundy
Incident:	Fire Alarm		
Location:	Smith Apts. 2 nd Floor		
Details:	Alarm pull box activated by unknown person		
286-06	11-05-06	5:00 PM	Lundy
Incident:	Fire Alarm		
Location:	University Apartments, Bldg 78		
Details:	Smoke from burned food activated smoke alarm		
287-06	11-05-06	10:00 AM	Lundy
Incident:	Fire Alarm		
Location:	Morrison Apartments		
Details:	Lightning strike activated smoke detector		
288-06	11-05-06	10:00 PM	Lundy
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. A		
Details:	Burned popcorn activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 11/06/06 – 11/12/06

289-06	11-06-06	1:10 PM	Nutt
Incident:	Fire Alarm		
Location:	Student Union		
Details:	Fire alarm pull box accidentally activated		

290-06	11-07-06	10:30 AM	Nutt
Incident:	Ambulance Assist		
Location:	Engineering South, 2nd floor stairway		
Details:	Patient unresponsive		

291-06	11-08-06	11:20 AM	Nutt
Incident:	Ambulance Assist		
Location:	University Health Services		
Details:	Patient alert, possible overdose		

292-06	11-08-06	4:30 PM	Lundy
Incident:	Smoke Investigation		
Location:	Southeast corner of South Boone Pickens Stadium		
Details:	Unknown caller reported seeing smoke; no smoke found		

293-06	11-08-06	6:00 PM	Lundy
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Smoke from outdoor grilling entered apartment and activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 11/13/06 – 11/19/06

294-06	11-14-06	3:10 PM	Fox
Incident:	Possible chemical spill		
Location:	Parking lot 107, east of Adams Market		
Details:	Degreaser being used on grease spills		
295-06	11-14-06	1:30 AM	Mason
Incident:	Fire Alarm		
Location:	Stinchcomb Hall, third & fourth floors		
Details:	Fire extinguishers shot off by unknown person, which activated fire alarm		
296-06	11-13-06	5:25 PM	Kelley
Incident:	Possible chemical spill		
Location:	University Mailing, outside north loading dock		
Details:	Broken bottles discovered containing unknown liquid		
297-06	11-14-06	11:30 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. F		
Details:	Resident using spray hair conditioner and hair dryer under smoke detector activated detector.		
298-06	11-15-06	8:39 PM	Kelley
Incident:	Ambulance Assist		
Location:	Classroom Building, basement hallway		
Details:	Patient having a seizure		
299-06	11-16-06	6:53 PM	Kelley
Incident:	Ambulance Assist		
Location:	Athletic Ave.; Sidewalk south of fence surrounding Dairy Building		
Details:	Pedestrian hit by bicyclist who left the scene; pedestrian declined transport to SMC		
300-06	11-16-06	7:20 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Steam from shower activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 11/20/06 – 11/26/06

301-06	11-21-06	5:15 PM	Nutt
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Burned food activated smoke detector		

302-06	11-21-06	5:20 PM	Nutt
Incident:	Fire Alarm		
Location:	Booker Hall		
Details:	Pull box activated by unknown person		

303-06	11-28-06	12:20 PM	Nutt
Incident:	Fire Alarm		
Location:	Life Science West		
Details:	Broken hot water line above room 013 shorted a heat detector, which activated the fire alarm		

**OSU EHS Department
Incident Summary**
For the Period 11/27/06 – 12/03/06

303-06	11-28-06	12:20 PM	Nutt
Incident:	Fire Alarm		
Location:	Life Science West		
Details:	Broken hot water line above room 013 shorted a heat detector, which activated the fire alarm		
304-06	11-29-06	10:00 AM	Nutt
Incident:	Fire Alarm		
Location:	Allen Hall		
Details:	Smoking light fixture activated smoke detector		
305-06	12-01-06	6:00 AM	Nutt
Incident:	Fire Alarm		
Location:	Fire Service Training Facility		
Details:	Fire Alarm activated by unknown cause		
306-06	12/02/06	12:20 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		
309-06	12-02-06	3:38 AM	Kelley
Incident:	Fire Alarm		
Location:	Stinchcomb Apartments		
Details:	Fire Alarm activated by unknown cause		
310-06	12/02/06	4:26 PM	Kelley
Incident:	Fire Alarm		
Location:	Boone Pickens North Stadium, Mechanical Room		
Details:	Water surge in sprinkler system activated fire alarm		
311-06	12-02-06	8:47 PM	Kelley
Incident:	Fire Alarm		
Location:	Stinchcomb Apartments		
Details:	Fire Alarm activated by unknown cause		
312-06	12/02/06	11:28 PM	Kelley
Incident:	Fire Alarm		
Location:	Stinchcomb Apartments, 3 rd floor hall		
Details:	Fire alarm activated by unknown cause		
313-06	12/03/06	12:07 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Building D		
Details:	Steam from shower activated smoke detector		
314-06	12-03-06	1:45 PM	Kelley
Incident:	Fire Alarm		
Location:	Smith Apartments, Mechanical Room		
Details:	Water dripping in smoke detector activated fire alarm		

**OSU EHS Department
Incident Summary**
For the Period 12/04/06 – 12/10/06

315-06	12/04/06	1:41 AM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Building F		
Details:	Cooking activated smoke detector		
307-06	12/04/06	9:10 AM	Nutt
Incident:	Ambulance Assist		
Location:	Corner of Monroe and Scott Streets		
Details:	Pedestrian fell on ice and possibly injured left leg		
308-06	12-04-06	11:00 AM	Nutt
Incident:	Fire Alarm		
Location:	Kamm Hall		
Details:	Smoke from burned food activated smoke detector		
316-06	12-05-06	3:20 PM	Nutt
Incident:	Fire Alarm		
Location:	Engineering South		
Details:	Dust/dirt activated smoke detector		
317-06	12-06-06	10:30 AM	Nutt
Incident:	Fire Alarm		
Location:	Boone Pickens Stadium, North Side		
Details:	Dust from construction activated smoke detector		
318-06	12-06-06	8:06 PM	Kelley
Incident:	Fire		
Location:	University Apartments, Near N27		
Details:	Hot charcoal put in dumpster started fire		
319-06	12-07-06	7:53 PM	Kelley
Incident:	Fire Alarm		
Location:	Drummond Hall, 1 st floor trash chute mechanical room		
Details:	Plug on unused sprinkler line failed, causing water flow in system		
320-06	12-08-06	4:26 PM	Kelley
Incident:	Ambulance Assist		
Location:	Bennett Hall		
Details:	Patient found semi-conscious		
321-06	12-09-06	5:10 AM	Spybuck
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Residents' smoking activated smoke detector		

OSU EHS Department
Incident Summary
For the Period 12/11/06 – 12/17/06

322-06	12-14-06	3:51 PM	Kelley
Incident:	Fire Alarm		
Location:	Noble Center, B Wing, Greenhouse outside Mechanical Room		
Details:	Contractor accidentally hit duct detector on AHU		

323-06	12-14-06	7:17 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg B		
Details:	Burned microwave popcorn activated smoke detector		

324-06	12-14-06	8:16 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. A		
Details:	Microwaved food activated smoke detector		

325-06	12-14-06	11:38 PM	Kelley
Incident:	Fire Alarm		
Location:	Zink Apartments		
Details:	Resident using hair dryer near a smoke detector		

OSU EHS Department
Incident Summary
For the Period 12/18/06 – 12/24/06

326-06	12-19-06	2:20 PM	Nutt
Incident:	Fire Alarm		
Location:	Kamm Hall		
Details:	Resident using hair dryer set off smoke detector		

327-06	12-18-06	8:40 PM	Kelley
Incident:	Ambulance Assist		
Location:	University Apartments		
Details:	Patient having difficulty breathing		

328-06	12-20-06	2:20 PM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Smoke from burned food activated smoke detector		

329-06	12-24-06	12:45 PM	Lundy
Incident:	Fire Alarm		
Location:	Davis Apartments		
Details:	Smoke from burned food activated smoke detector		

OSU EHS Department
Incident Summary
For the Period 12/25/06 – 12/31/06

330-06	12-26-06	1:30 PM	Lundy
Incident:	Fire Alarm		
Location:	Engineering South, 4 th Floor		
Details:	Dust from construction activated smoke detector		

331-06	12-29-06	11:15 PM	Nutt
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Smoke from burned food activated smoke detector		

334-06	12-26-06	8:41 AM	Boles
Incident:	Chemical Incident		
Location:	Lake Carl Blackwell		
Details:	Bucket of drain cleaner found in dumpster at Lake Carl Blackwell area		
