

OKLAHOMA STATE UNIVERSITY

ENVIRONMENTAL HEALTH & SAFETY DEPARTMENT



2007 INCIDENT REPORT LOG

Weekly reports on fire alarms, ambulance calls, accident investigations, hazmat response, and other activities that required immediate response by EHS personnel

OSU EHS Department
Incident Summary
For the Period 01/01/07 – 01/07/07

001-07	01-01-07	4:30 PM	Nutt
Incident:	Fire Alarm		
Location:	Payne-Ellis Apartments		
Details:	Tenant moving out accidentally bumped pull box		

002-07	01/05/07	11:15 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C		
Details:	Dust from construction activated smoke detector		

003-07	01/07/07	9:00 AM	Mason
Incident:	Fire Alarm		
Location:	Vet Med Teaching Hospital, Lab Animal Research, Mechanical Room		
Details:	Steam leak activated smoke detector		

004-07	01/09/07	5:45 PM	Kelley
Incident:	Chemical Incident		
Location:	Kerr Hall, east stairwell between 2 nd & 3 rd floors		
Details:	Chemical soda bottle exploded in stairwell		

OSU EHS Department
Incident Summary
For the Period 01/08/07 – 01/14/07

005-07	01/10/07	11:40 AM	Nutt
Incident:	Ambulance Assist		
Location:	Student Union		
Details:	Patient feeling sick and light-headed		

006-07	01/11/07	9:15 AM	Nutt
Incident:	Ambulance Assist		
Location:	Physical Sciences		
Details:	Patient passed out and hit head		

007-07	01/13/07	11:20 AM	Kelley
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Smoke from cooking activated smoke detector		

008-07	01/13/07	11:40 AM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Building D		
Details:	Smoke from cooking activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 01/15/07 – 01/21/07

009-07	01/16/07	12:30 PM	Nutt
Incident:	Ambulance Assist		
Location:	Seretean Wellness Center		
Details:	Patient fell on ice		
010-07	01/17/07	8:30 AM	Isaacs
Incident:	Chemical Spill		
Location:	ATRC 250A		
Details:	Improper disposal of a broken thermometer		
012-07	01/17/07	5:55 PM	Kelley
Incident:	Ambulance Assist		
Location:	Colvin Center, east entrance		
Details:	Patient slipped and fell on ice, transported to SMC		
013-07	01/17/07	8:24 PM	Kelley
Incident:	Fire Alarm		
Location:	Smith Hall		
Details:	Cooking smoke activated smoke detector		
014-07	01/17/07	11:00 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments Bldg. F, 3 rd floor, SE Lounge		
Details:	Cooking smoke activated smoke detector		
015-07	01/18/07	6:39 PM	Kelley
Incident:	Ambulance Assist		
Location:	Hall of Fame, west side of west entrance to Cowboy Mall		
Details:	Auto Accident		
016-07	01/19/07	9:40 AM	Isaacs
Incident:	Chemical Spill		
Location:	Physical Plant Bldg., Supply Area		
Details:	Small amount of White E.I. Disinfectant Bowl Cleaner leaked from bottle		
017-07	01/21/07	10:30 PM	Spybuck
Incident:	Fire Alarm		
Location:	Booker Suites Room 322		
Details:	Sprinkler system activated by a shot from a Soft BB gun		
018-07	01/20/07	1:30 AM	Spybuck
Incident:	Fire Alarm		
Location:	Village Apartments Bldg. D, Room 282 Common Area		
Details:	Burned popcorn activated smoke detector		
019-07	01/20/07	11:30 AM	Spybuck
Incident:	Fire Alarm		
Location:	Peterson Apt. 103		
Details:	burned food activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 01/15/07 – 01/21/07

020-07	01/21/07	12:30 PM	Spybuck
Incident:	Fire Alarm		
Location:	University Apartments, Bldg. 36		
Details:	Burned food activated smoke detector		

021-07	01/21/07	5:30 PM	Spybuck
Incident:	Fire Alarm		
Location:	Student Union, 4 th floor, NE freight elevator landing		
Details:	Water leak from roof activated fire alarm		

**OSU EHS Department
Incident Summary**
For the Period 01/22/07 – 01/28/07

022-07	01-22-07	4:35 PM	Kelley
Incident:	Ambulance Assist		
Location:	Kerr-Drummond Cafeteria		
Details:	Patient having difficulty breathing		
023-07	01/22/07	11:35 PM	Kelley
Incident:	Ambulance Assist		
Location:	Colvin Center, outside east entrance on sidewalk		
Details:	Patient injured in a fight		
024-07	01/23/07	11:30 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. F		
Details:	Steam from shower activated smoke detector		
025-07	01/23/07	3:00 PM	Nutt
Incident:	Fire Alarm		
Location:	Kerr-Drummond Cafeteria		
Details:	Unknown cause, nothing found		
026-07	01/23/07	5:40 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Microwave cooking activated smoke detector		
027-07	01/24/07	6:56 PM	Kelley
Incident:	Fire Alarm		
Location:	Food Processing, 2 nd floor SW stairs, inside freezer exit		
Details:	Someone pulled the pull box		
028-07	01/24/07	7:08 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C, 4 th floor hallway near west kitchen area		
Details:	Smoke from cooking activated the smoke detector		
029-07	01/25/07	9:50 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. A		
Details:	Dust from construction activated smoke detector		
030-07	01/24/07	11:28 PM	Kelley
Incident:	Ambulance Assist		
Location:	Colvin Center, lower level, SW basketball courts		
Details:	Patient injured leg playing basketball		
031-07	01/24/07	11:29 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E, 4 th floor hallway near west kitchen area		
Details:	Smoke from cooking activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 01/22/07 – 01/28/07

032-07	01/25/07	12:24 AM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. A		
Details:	Cooking in microwave activated smoke detector		

033-07	01/25/07	5:05 PM	Kelley
Incident:	Fire Alarm		
Location:	Kerr-Drummond Cafeteria, 2 nd floor zone		
Details:	Unknown cause		

034-07	01/25/07	8:50 PM	Kelley
Incident:	Fire Alarm		
Location:	Petroleum Technology Bldg.		
Details:	Vacuum cleaner bag broke open under smoke detector		

035-07	01/28/07	4:30 AM	Nutt
Incident:	Fire Alarm		
Location:	Patchin Jones Hall		
Details:	Pull box activated by unknown person		

**OSU EHS Department
Incident Summary**
For the Period 01/29/07 – 02/04/07

036-07	01-29-07	9:20 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. A		
Details:	Hair spray activated smoke detector		
037-07	01/29/07	5:30 PM	Nutt
Incident:	Fire Alarm		
Location:	Patchin Jones Hall		
Details:	Hair dryer activated smoke detector		
038-07	01/29/07	5:00 pm	Kelley
Incident:	Fire Alarm		
Location:	Vet Med Teaching Hospital Equine Isolation Ward		
Details:	Maintenance on heating unit activated smoke detector		
039-07	01-30-07	10:45 AM	Nutt
Incident:	Ambulance Assist		
Location:	VMTH Small Animal Clinic		
Details:	Patient felt light-headed and passed out briefly; refused transport to SMC		
040-07	01/29/07	6:54 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		
041-07	01/30/07	1:20 PM	Spybuck
Incident:	Fire Alarm		
Location:	Physical Science II, 2 nd floor by room 257		
Details:	Burning tongue suppressor in lab		
042-07	01/30/07	8:53 PM	Kelley
Incident:	Fire Alarm		
Location:	Bennett Hall West 4 th floor		
Details:	Alarm caused by broken sprinkler head		
043-07	01/31/07	4:33 PM	Kelley
Incident:	Fire Alarm		
Location:	Student Union 1 st floor kitchen		
Details:	Deep fryers were turned on without turning on the exhaust fan		
044-07	02/01/07	1:40 AM	Spybuck
Incident:	Ambulance Assist		
Location:	Colvin Center, lower level SW basketball courts		
Details:	Patient injured leg playing basketball		
045-07	02/01/07	9:30 PM	Kelley
Incident:	Fire Alarm		
Location:	Allen Hall		
Details:	Candle smoke activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 01/29/07 – 02/04/07

046-07	02/02/07	9:20 AM	Nutt
Incident:	Ambulance Assist		
Location:	Seretean Wellness Center		
Details:	Patient with chest pain transported to SMC		

047-07	02-04-07	9:15 PM	Nutt
Incident:	Fire Alarm		
Location:	Zink Hall		
Details:	Dust activated smoke detector		

048-07	02/02/07	4:30 PM	Kelley
Incident:	Fire Alarm		
Location:	Engineering North, 4 th floor, South stairwell		
Details:	Faulty smoke detector activated alarm		

049-07	02-02-07	6:10 PM	Kelley
Incident:	Fire Alarm		
Location:	Animal Science, 2 nd floor elevator lobby		
Details:	Maintenance personnel accidentally hit pull box and activated alarm		

OSU EHS Department
Incident Summary
For the Period 02/05/07 – 02/11/07

050-07	02/06/07	10:43 PM	Kelley
Incident:	Ambulance Assist		
Location:	Colvin Center, east entrance		
Details:	Patient injured right knee playing basketball		

051-07	02/08/07	6:26 PM	Kelley
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Cooking activated smoke detector		

052-07	02/11/07	2:35 PM	Kelley
Incident:	Fire Alarm		
Location:	Visual Arts Annex		
Details:	Student melting wax on hot plate. Smoke activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 02/12/07 – 02/18/07

053-07	02/14/07	9:45 AM	Nutt
--------	----------	---------	------

Incident: Ambulance Assist
Location: Student Health Services
Details: OSU employee with chest pains transported to Stillwater Medical Center

054-07	02/13/07	4:33 PM	Kelley
--------	----------	---------	--------

Incident: Fire Alarm
Location: Young Hall
Details: Cooking activated smoke detector

055-07	02/13/07	9:21 PM	Kelley
--------	----------	---------	--------

Incident: Fire Alarm
Location: Village Apartments, Bldg. B
Details: Burned popcorn activated smoke detector

056-07	02/14/07	9:50 PM	Kelley
--------	----------	---------	--------

Incident: Ambulance Assist
Location: Zink Hall
Details: Patient found unconscious in room

057-07	02/15/07	3:40 PM	Nutt
--------	----------	---------	------

Incident: Fire Alarm
Location: Village Apartments, Bldg. D
Details: Burned popcorn activated smoke detector

058-07	02/14/07	8:47 PM	Kelley
--------	----------	---------	--------

Incident: Fire Alarm
Location: North Stadium, Plaza Level, east end
Details: Hot charcoal put in plastic trash can, causing fire

059-07	02/15/07	5:54 PM	Kelley
--------	----------	---------	--------

Incident: Fire Alarm
Location: Track Building, Hallway
Details: Vacuum cleaner bag overfilled and dust set off smoke detector

060-07	02/15/07	10:14 PM	Kelley
--------	----------	----------	--------

Incident: Fire Alarm
Location: Allen Hall, mechanical room
Details: Possible water surge in sprinkler line

061-07	02/16/07	5:45 AM	Mason
--------	----------	---------	-------

Incident: Fire Alarm
Location: Gallagher-Iba Arena
Details: Belt on air handler got hot, smoked and activated smoke detector

063-07	02/17/07	6:03 PM	Kelley
--------	----------	---------	--------

Incident: Fire Alarm
Location: North & South Stadiums, Mechanical rooms & west elevator tower
Details: Broken sprinkler line/head in elevator shaft

**OSU EHS Department
Incident Summary**
For the Period 02/12/07 – 02/18/07

064-07	02/18/07	1:15 AM	Kelley
Incident:	Fire Alarm		
Location:	North Stadium, west tower		
Details:	Broken sprinkler head/pipe		

065-07	02/18/07	5:08 AM	Kelley
Incident:	Fire Alarm		
Location:	South Stadium East tower elevator shaft		
Details:	Sprinkler head/pipe leak (Last 3 alarms due to freezing/thawing of trapped water in sprinkler system)		

066-07	02/18/07	3:40 PM	Kelley
Incident:	Fire Alarm		
Location:	Fire Protection & Technology Lab		
Details:	Fire protection students using fire hose got water into the pullbox		

**OSU EHS Department
Incident Summary**
For the Period 02/19/07 – 02/25/07

062-07	02/19/07	1:00 PM	Nutt
Incident:	Fire Alarm		
Location:	Morsani Hall		
Details:	Cooking activated smoke detector		

067-07	02/19/07	6:34 PM	Kelley
Incident:	Ambulance Assist		
Location:	University Apartments		
Details:	Baby choking/breathing problems		

068-07	02/19/07	7:03 PM	Kelley
Incident:	Fire Alarm		
Location:	Davis Hall		
Details:	Cooking activated smoke detector		

069-07	02/21/07	9:30 AM	Nutt
Incident:	Fire Alarm		
Location:	North Stadium		
Details:	Water surge in sprinkler system activated fire alarm		

070-07	02/21/07	10:20 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. F		
Details:	Spilled milk on stove burner activated smoke detector		

071-07	02/21/07	3:30 PM	Nutt
Incident:	Ambulance Assist		
Location:	University Health Services		
Details:	patient having difficulty breathing		

072-07	02/24/07	1:15 AM	Spybuck
Incident:	Fire Alarm		
Location:	Bennett Hall NE, Basement, Computer Room		
Details:	Dirty smoke detector activated smoke alarm		

073-07	02/24/07	11:40 AM	Spybuck
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C		
Details:	Resident using blow dryer on hair activated smoke detector		

OSU EHS Department
Incident Summary
For the Period 02/26/07 – 03/04/07

074-07	02/26/07	1:00 AM	Spybuck
Incident:	Fire Alarm		
Location:	Booker Hall		
Details:	Alarm malfunction		

075-07	02/28/07	2:00 AM	Spybuck
Incident:	Fire alarm		
Location:	Bost Hall 2 nd floor NW stairs		
Details:	Accidental activation of the pull box		

076-07	02/28/07	6:00 AM	Spybuck
Incident:	Fire Alarm		
Location:	Allen Hall		
Details:	Smoke detector activated; cause unknown		

092-07	02/27/07	4:00 PM	Nutt
Incident:	Fire Alarm		
Location:	Colvin Center		
Details:	Pull box hit by basketball		

**OSU EHS Department
Incident Summary**
For the Period 03/05/07 – 03/11/07

077-07	03/05/07	11:30 AM	Spybuck
Incident:	Fire Alarm		
Location:	Graphic Arts; kiln area		
Details:	Heating of pottery activated smoke detector		
078-07	03/06/07	9:18 PM	Kelley
Incident:	Fire alarm		
Location:	Village Apartments Bldg. E, 2 nd floor hallway		
Details:	Cooking in kitchenette activated smoke detector		
079-07	03/06/07	9:30 PM	Kelley
Incident:	Ambulance Assist		
Location:	Kerr Hall, 1 st floor elevator lobby		
Details:	Patient unconscious and seizing; transported to SMC		
080-07	03/06/07	9:49 PM	Kelley
Incident:	Fire alarm		
Location:	Sitlington Hall		
Details:	Cooking activated smoke detector		
081-07	03/06/07	10:38 PM	Kelley
Incident:	Ambulance Assist		
Location:	Village Apartments Bldg. C 1st floor east lounge		
Details:	Patient with breathing problems		
082-07	03/05/07	3:45 PM	Spybuck
Incident:	Fire Alarm		
Location:	Village Apartments Bldg. B Third Floor		
Details:	Burned popcorn activated smoke detector		
083-07	03/07/07	5:36 PM	Kelley
Incident:	Ambulance Assist		
Location:	Bennett Hall East, 4 th floor hallway		
Details:	Patient having a seizure		
084-07	03/07/07	11:40 PM	Kelley
Incident:	Fire Alarm		
Location:	Bennett Hall West, 1 st floor lounge/laundry		
Details:	Cooking activated smoke detector		
085-07	03/08/07	11:40 PM	Kelley
Incident:	Ambulance Assist		
Location:	Peterson Apts.		
Details:	Excessive alcohol ingestion		
089-07	03/08/07	10:47 PM	Kelley
Incident:	Fire Alarm		
Location:	Classroom Bldg. 1 st floor east entrance hallway		
Details:	Custodians sweeping floor got dust in smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 03/12/07 – 03/18/07

086-07	03/12/07	3:15 PM	Nutt
Incident:	Ambulance Assist		
Location:	Village Apartments Bldg. E		
Details:	Patient with flu-like symptoms and dizzy		

087-07	03/13/07	10:30 AM	Nutt
Incident:	Fire Alarm		
Location:	Fire Protection Lab		
Details:	Employee soldering in mechanical room activated smoke detector		

088-07	03/15/07	10:50 AM	Nutt
Incident:	Ambulance Assist		
Location:	Ag Hall		
Details:	Patient with possible cardiac incident		

090-07	03/14/07	7:42 PM	Kelley
Incident:	Ambulance Assist		
Location:	Wellness Center 1 st floor lobby		
Details:	Patient feeling dizzy and faint, not transported		

091-07	03/15/07	3:50 PM	Nutt
Incident:	Fire Alarm		
Location:	Physical Science II		
Details:	Instructor using compressed air to clean equipment activated smoke detector		

OSU EHS Department
Incident Summary
For the Period 03/19/07 – 03/25/07

093-07	03/19/07	10:20 AM	Nutt
Incident:	Ambulance Assist		
Location:	Soccer Fields		
Details:	Participant in soccer camp injured leg		

094-07	03/22/07	5:00 PM	Kelley
Incident:	Fire Alarm		
Location:	University Apartments		
Details:	Cooking activated smoke detector		

095-07	03/22/07	3:55 PM	Kelley
Incident:	Fire Alarm		
Location:	Sitlington Apartments		
Details:	Cooking activated smoke detector		

096-07	03/23/07	8:45 AM	Nutt
Incident:	Fire Alarm		
Location:	Cordell South 4 th Floor		
Details:	Motor malfunction in HVAC activated smoke detector		

OSU EHS Department
Incident Summary
For the Period 03/26/07 – 04/1/07

098-07	03/27/07	8:50 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Cooking activated smoke detector		

099-07	03/28/07	3:00 PM	Nutt
Incident:	Ambulance Assist		
Location:	North side of ATRC		
Details:	OSU Physical Plant employee fell from ladder		

100-07	03/28/07	1:00 PM	Nutt
Incident:	Fire Alarm		
Location:	Young Hall		
Details:	Burned food activated smoke detector		

101-07	03/29/07	11:30 AM	Nutt
Incident:	Ambulance Assist		
Location:	Willard Hall		
Details:	Patient with possible diabetic reaction		

102-07	03/30/07	6:30 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. F		
Details:	Possibly hair spray and/or candle that had been blown out activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 04/02/07 – 04/08/07

103-07	04/03/07	6:14 pm	Kelley
Incident:	Fire Alarm		
Location:	Bennett Hall, Center Section		
Details:	Unknown cause		
104-07	104-07	6:40 PM	Kelley
Incident:	Fire Alarm		
Location:	Student Union, 2 nd floor, Little Theater backstage		
Details:	Accidental activation of pull box		
105-07	04/04/07	8:10 AM	Nutt
Incident:	Fire		
Location:	Adam's Market		
Details:	Bird's nest in outdoor heater caught fire		
106-07	04/05/07	10:50 AM	Nutt
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Hair dryer activated smoke detector		
107-07	04/04/07	6:31 PM	Kelley
Incident:	Ambulance Assist		
Location:	OSU Bus, south side of Bennett Hall on Hall of Fame Ave.		
Details:	Person having seizure		
108-07	04/06/07	5:08 PM	Kelley
Incident:	Fire Alarm		
Location:	Sitlington Hall		
Details:	Possible dust in smoke detector		
109-07	04/06/07	7:41 PM	Kelley
Incident:	Fire Alarm		
Location:	Sitlington Hall		
Details:	Faulty smoke detector		
110-07	04/06/07	10:47 PM	Kelley
Incident:	Fire Alarm		
Location:	Visual Arts Bldg.		
Details:	Wind blew smoke from kiln into air handler on roof		
122-07	04-04-07	2:45 PM	Germain
Incident:	Ambulance Assist		
Location:	Physical Science Bldg., south parking lot		
Details:	Person having dizzy spell		

**OSU EHS Department
Incident Summary**
For the Period 04/09/07 – 04/15/07

111-07	04/09/07	10:30 AM	Nutt
Incident:	Ambulance Assist		
Location:	NOC Campus at Cowboy Mall		
Details:	Possible cardiac incident		

112-07	04/09/07	11:15 AM	Nutt
Incident:	Ambulance Assist		
Location:	Wes Watkins CITD		
Details:	Employee passed out		

113-07	04/10/07	3:20 PM	Nutt
Incident:	Ambulance Assist		
Location:	Student Health Center		
Details:	Possible allergic reaction		

114-07	04/11/07	7:50 AM	Nutt
Incident:	Fire Alarm		
Location:	Vet Med Teaching Hospital		
Details:	Unknown cause		

115-07	04/11/07	1:15 PM	Nutt
Incident:	Ambulance Assist		
Location:	Student Union		
Details:	Possible cardiac incident		

116-07	04/11/07	3:50 PM	Nutt
Incident:	Fire Alarm		
Location:	Electronics Lab		
Details:	Worker bumped heat detector and set off alarm		

117-07	04/10/07	4:45 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Burned food in microwave activated smoke detector		

118-07	04/11/07	6:15 AM	Kelley
Incident:	Fire Alarm		
Location:	Student Union Kitchen		
Details:	Vent hood over deep-fryer not working and heat from fryer set off heat detector		

119-07	04/10/07	5:26 PM	Kelley
Incident:	Fire Alarm		
Location:	Lab Animal Research office area		
Details:	Bug bombs set off in office area; aerosol got into smoke detector		

120-07	04/11/07	5:50 PM	Kelley
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Cooking activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 04/09/07 – 04/15/07

121-07	04/10/07	9:20 PM	Kelley
Incident:	Fire Alarm		
Location:	Sitlington Hall		
Details:	Cooking activated smoke detector		

122-07	04/04/07	2:45 PM	Germain
Incident:	Ambulance Assist		
Location:	Physical Science Bldg., south parking lot		
Details:	Person having dizzy spell		

123-07	04/13/07	8:15 PM	Spybuck
Incident:	Fire Alarm		
Location:	Classroom Bldg. 1 st floor hallway		
Details:	Vacuum cleaner bag got overfilled and blew out; dust activated smoke detector		

124-07	04/14/07	2:20 AM	Spybuck
Incident:	Fire Alarm		
Location:	Kamm Hall		
Details:	Tenant cleaned stove, then later turned burner on; the residue from the cleaner caused smoke		

125-07	04/12/07	7:47 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Resident using hair dryer activated smoke detector		

126-07	4/13/07	1:16 AM	Kelley
Incident:	Fire Alarm		
Location:	Young Hall		
Details:	Cooking activated smoke detector		

127-07	4/14/07	7:20 PM	Spybuck
Incident:	Fire Alarm		
Location:	Controlled Environment Research Lab, Greenhouse area		
Details:	Worker building a wall hit a heat detector and activated it		

128-07	04/14/07	11:07 AM	Spybuck
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Smoke from cooking activated smoke detector		

OSU EHS Department
Incident Summary
For the Period 04/16/07 – 04/22/07

129-07	04/16/07	11:15 AM	Nutt
Incident:	Fire		
Location:	Behind Paul Miller J & B building		
Details:	Fire in dumpster; unknown cause		

130-07	04/16/07	10:02 PM	Kelley
Incident:	Fire Alarm		
Location:	Colvin Center, lower level, Court #4		
Details:	Pull station hit with a volley ball		

131-07	04/19/07	4:35 AM	Spybuck
Incident:	Fire Alarm		
Location:	Morsani Smith Apts.		
Details:	Burned food activated smoke detector		

132-07	04/20/07	4:30 PM	Nutt
Incident:	Fire Alarm		
Location:	Parker Hall, 3 rd floor		
Details:	Student accidentally hit sprinkler head with a nerf football		

OSU EHS Department
Incident Summary
For the Period 04/23/07 – 04/29/07

133-07	04/24/07	3:14 PM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Building B		
Details:	Microwaving popcorn activated smoke detector		

134-07	04/23/07	8:50 PM	Kelley
Incident:	Fire Alarm		
Location:	Davis Hall		
Details:	Cooking activated smoke detector		

OSU EHS Department
Incident Summary
For the Period 04/30/07 – 5/06/07

135-07	04/30/07	6:54 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Building B		
Details:	Steam from shower activated smoke detector		

136-07	05/02/07	2:15 PM	Isaacs
Incident:	Chemical Spill		
Location:	NRC D Wing #247		
Details:	Broken bottle of calcium oxide		

137-07	05/03/07	9:00 AM	Nutt
Incident:	Fire Alarm		
Location:	Transportation Bldg.		
Details:	Unknown cause		

138-07	05/02/07	6:14 PM	Kelley
Incident:	Fire Alarm		
Location:	OADDL Basement Mech. Room 000G		
Details:	Water from broken drain line blown into fire alarm module		

**OSU EHS Department
Incident Summary**
For the Period 05/07/07 – 05/13/07

139-07	05/07/07	8:55 AM	Nutt
Incident:	Fire Alarm		
Location:	Stout Hall basement		
Details:	Flooding in basement caused electrical circuit short		

140-07	05/07/07	4:57 AM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Steam from shower activated smoke detector		

141-07	05/13/07	9:23 AM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Cooking smoke activated smoke detector		

142-07	05/13/07	2:11 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D, 4 th floor hallway		
Details:	Pull box activated by unknown person		

143-07	05/13/07	10:10 AM	Kelley
Incident:	Fire Alarm		
Location:	Bost Hall		
Details:	Malfunction in Fire Alarm system		

OSU EHS Department
Incident Summary
For the Period 05/14/07 – 05/20/07

143-07	05/13/07	10:10 AM	Kelley
Incident:	Fire Alarm		
Location:	Bost Hall		
Details:	Malfunction in fire alarm system		

**OSU EHS Department
Incident Summary**
For the Period 05/21/07 – 05/27/07

144-07	05/21/07	10:45 AM	Nutt
Incident:	Ambulance Assist		
Location:	Peterson Hall		
Details:	Student with abdominal pain		

145-07	05/21/07	9:34 PM	Kelley
Incident:	Fire Alarm		
Location:	Vet Med Teaching Hospital, Small Animal Ward		
Details:	Unknown		

146-07	05/23/07	1:20 PM	Nutt
Incident:	Fire Alarm		
Location:	Gallagher-Iba Arena		
Details:	Dust from construction activated smoke detector		

147-07	05/26/07	4:56 PM	Spybuck
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C/D		
Details:	Cause unknown		

148-07	05/26/07	6:19 PM	Spybuck
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C/D		
Details:	Smoke from cooking activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 05/29/07 – 06/03/07

149-07	06/01/07	5:00 PM	Kelley
Incident:	Fire Alarm		
Location:	Math Sciences Room 309A		
Details:	Button vibrated out of heat detector		

150-07	06/01/07	6:00 PM	Kelley
Incident:	Fire Alarms and trouble signals		
Location:	Various buildings on campus		
Details:	Alarms and signals activated due to storm and lightning		

151-07	06/02/07	5:15 PM	Kelley
Incident:	Trouble signals and power outage		
Location:	Various buildings on campus		
Details:	Switch malfunction at power plant		

152-07	06/01/07	12:05 AM	Kelley
Incident:	Fire Alarm		
Location:	Noble Center, room 100D		
Details:	Alarm panel malfunction		

155-07	05/30/07	6:30 AM	Spybuck
Incident:	Fire Alarm		
Location:	Bennett Hall, Blair Dining		
Details:	Smoke from overheated grease activated smoke alarm		

156-07	05/30/07	8:00 PM	Spybuck
Incident:	Fire Alarm		
Location:	Student Union, 1 st floor atrium		
Details:	Cleaning crew dusting the ceiling tile activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 06/04/07 – 06/10/07

153-07	06/05/07	10:45 AM	Nutt
Incident:	Ambulance Assist		
Location:	Classroom Building		
Details:	Fall victim injured left ankle on stairs		

154-07	06/05/07	2:20 PM	Nutt
Incident:	Ambulance Assist		
Location:	Whitehurst 207		
Details:	Employee experiencing extreme back pain		

157-07	06/08/07	11:52 PM	Kelley
Incident:	Fire Alarm		
Location:	Young Hall, 3 rd floor breezeway		
Details:	Alarm pullbox pulled by unknown person		

158-07	06/09/07	10:20 AM	Nutt
Incident:	Fire Alarm		
Location:	Adam's Market		
Details:	Vent hood over pizza oven not turned on, smoke from oven activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 06/11/07 – 06/17/07

159-07	06/11/07	9:50 AM	Nutt
Incident:	Fire Alarm		
Location:	Career-Tech Offices		
Details:	Burned popcorn activated smoke detector		

160-07	06/12/07	3:30 PM	Nutt
Incident:	Fire Alarm		
Location:	Classroom Building		
Details:	Dirt in smoke detector activated alarm		

161-07	06/13/07	11:15 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C		
Details:	Construction dust activated smoke detector		

162-07	06/13/07	4:11 PM	Kelley
Incident:	Fire Alarm		
Location:	Kamm Hall		
Details:	Smoke from cooking activated smoke detector		

163-07	06/14/07	12:05 AM	Nutt
Incident:	Fire Alarm		
Location:	Ag Engineering		
Details:	Dirt in smoke detector activated alarm		

164-7	06/14/7	4:11 PM	Nutt
Incident:	Fire Alarm		
Location:	Lake Carl Blackwell Store		
Details:	Unknown cause, probably wet phone lines		

165-07	06/14/07	7:01 PM	Kelley
Incident:	Ambulance Assist		
Location:	Wentz Hall 1 st floor lounge		
Details:	Patient fell from back of chair and hit head & neck		

166-07	06/14/07	10:00 PM	Kelley
Incident:	Burning Odor		
Location:	University Apartments, Bldg. #27		
Details:	Refrigerator motor overheating		

**OSU EHS Department
Incident Summary**
For the Period 06/18/07 – 06/24/07

167-07	06/18/07	4:42 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Blow-drying hair under smoke detector activated alarm		

168-07	06/16/07	7:30 AM	Spybuck
Incident:	Stuck Elevator		
Location:	Village Apartments, Bldg. B, Elevator Lobby		
Details:	People stuck on elevator		

169-07	06/17/07	7:30 AM	Spybuck
Incident:	Stuck Elevator		
Location:	Village Apartments, Bldg. F		
Details:	People stuck on elevator		

170-07	06/19/07	4:08 PM	Kelley
Incident:	Fire Alarm		
Location:	Live Animal Research Bldg. 1 st floor hallway		
Details:	Steam from cage wash area activated smoke detector		

171-07	06/20/07	11:00 AM	Nutt
Incident:	Water rescue		
Location:	Low-water crossing on Virginia Street		
Details:	Motorist attempting to drive through the low water crossing became stranded		

OSU EHS Department
Incident Summary
For the Period 06/25/07 – 07/01/07

172-07	06/25/07	8:15 AM	Isaacs
Incident:	Mercury Spill		
Location:	Lake Carl Blackwell, behind dam		
Details:	Manometer leaked, cause unknown		

173-07	06/27/07	12:45 PM	Nutt
Incident:	Fire Alarm		
Location:	MAER Lab		
Details:	Construction work activated smoke detector, which had been taken down by workers		

174-07	06/28/07	9:25 PM	Kelley
Incident:	Fire Alarm		
Location:	Live Animal Research Lab		
Details:	Cause unknown		

175-07	06/28/07	3:05 PM	Nutt
Incident:	Fire Alarm		
Location:	Peterson Hall		
Details:	Burned food activated the smoke detector		

176-07	06/29/07	9:30 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C		
Details:	Dust from construction activated smoke detector		

177-07	06/29/07	4:34 PM	Kelley
Incident:	Ambulance Assist		
Location:	East side of Student Health Center		
Details:	Patients received electrical charge from lightning strike		

178-07	06/29/07	4:56 PM	Kelley
Incident:	Fire Alarm		
Location:	McElroy Hall		
Details:	Unknown cause		

179-07	06/30/07	3:00 PM	Nutt
Incident:	Fire Alarm		
Location:	Motor Pool		
Details:	Employee flowed water from sprinkler system, which activated the alarm		

**OSU EHS Department
Incident Summary**
For the Period 07/16/07 – 07/22/07

194-07	7/16/07	1:15 PM	Nutt
Incident:	Fire Alarm		
Location:	Parker Hall		
Details:	Worker drilled through conduit containing fire alarm circuitry		
195-07	7/16/07	3:45 PM	Kelley
Incident:	Ambulance Assist		
Location:	McElroy Hall		
Details:	Accidental activation of medical alert switch		
196-07	7/16/07	6:53 PM	Kelley
Incident:	Ambulance Assist		
Location:	Gallagher-Iba Arena, Training Room		
Details:	Patient suffering from heat exhaustion		
197-07	7/17/07	9:00 AM	Nutt
Incident:	Ambulance Assist		
Location:	Atherton Hotel, outside near entrance		
Details:	Patient tripped on rough surface		
198-07	07/17/07	9:05 PM	Kelley
Incident:	Smoke Investigation		
Location:	ATRC 2 nd and 3 rd floors west hallway and south stairwell		
Details:	Belt on fan motor was burned and shredding in AHU R-4-400E		
199-07	07/19/07	9:25 AM	Stevenson
Incident:	Fire Alarm		
Location:	Visual Arts Annex		
Details:	Dust in HVAC unit activated smoke detector		
200-07	07/19/07	2:55 PM	Stevenson
Incident:	Fire Alarm		
Location:	Zink/Allen Suites		
Details:	Deodorizer fogger being used by housekeeping staff activated smoke detectors		
201-07	07/19/07	12:15 AM	Stevenson
Incident:	Fire Alarm		
Location:	ATRC Bldg.		
Details:	Unknown cause, possible duct detector malfunction		
202-07	07/20/07	7:48 PM	Kelley
Incident:	Ambulance Assist		
Location:	Intersection of Hall of Fame & Monroe		
Details:	Auto accident		

OSU EHS Department
Incident Summary
For the Period 07/02/07 – 07/08/07

180-07	07/02/07	2:30 AM	Nutt
Incident:	Fire alarm		
Location:	Animal Science Arena		
Details:	Dirt in duct detector activated alarm		

181-07	07/02/07	1:20 PM	Nutt
Incident:	Fire Alarm		
Location:	North Stadium		
Details:	Accidental pull box activation		

182-07	07/02/07	2:30 PM	Nutt
Incident:	Ambulance Assist		
Location:	Gallagher-Iba Arena		
Details:	Injury to arm		

183-07	07/02/07	4:47 PM	Kelley
Incident:	Ambulance Assist		
Location:	Gallagher-Iba Arena		
Details:	Patient collapsed after wrestling practice		

184-07	07/02/07	3:30 PM	Isaacs
Incident:	Mercury Spill		
Location:	054 Ag Hall		
Details:	Broken bottle discovered during inventory		

185-07	07/05/07	8:15 AM	Nutt
Incident:	Fire Alarm		
Location:	Bennett Hall East		
Details:	Accidental pull box activation		

186-07	07/03/07	10:45 AM	Nutt
Incident:	Fire Alarm		
Location:	Power Plant		
Details:	Short circuit in heat detector caused by leak in roof		

OSU EHS Department
Incident Summary
For the Period 07/09/07 – 07/15/07

187-07	07/09/07	10:00 AM	Isaacs
Incident:	Unknown hazard		
Location:	University Mailing Services		
Details:	Box leaking unknown substance		

188-07	07/09/07	10:30 PM	Kelley
Incident:	Fire Alarm		
Location:	Classroom Bldg., 1 st floor hallway		
Details:	Vacuum cleaner bag burst under smoke detector		

189-07	07/11/07	8:30 AM	Nutt
Incident:	Fire Alarm		
Location:	Zink Hall		
Details:	Dirt in smoke detector		

190-07	07/11/07	9:45 AM	Nutt
Incident:	Ambulance Assist		
Location:	Boone Pickens Stadium, southwest entrance		
Details:	Construction worker injured		

191-07	07/12/07	10:15 AM	Nutt
Incident:	Fire Alarm		
Location:	Stevens Apartments		
Details:	Food left cooking unattended on stove		

192-07	07/13/07	8:15 AM	Nutt
Incident:	Ambulance Assist		
Location:	Gallagher-Iba Arena, weight room		
Details:	Patient injured in weight-lifting accident		

193-07	07/15/07	9:30 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke from cooking activated smoke detector		

OSU EHS Department
Incident Summary
For the Period 07/23/07 – 07/29/07

203-07	07/23/07	10:30 AM	Germain
Incident:	Fire alarm		
Location:	Allen Suites, 4 th floor east stairs		
Details:	Pull box activated		

204-07	07/24/07	11:00 PM	Kelley
Incident:	Fire Alarm		
Location:	Sitlington Apartments		
Details:	Steam from shower activated smoke detector		

205-07	07/25/07	4:16 PM	Kelley
Incident:	Fire Alarm		
Location:	Bennett Hall, east basement hallway		
Details:	Worker moving cabinet broke off sprinkler head, which set off the alarm and caused a large water flow.		

OSU EHS Department
Incident Summary
For the Period 07/30/07 – 08/05/07

206-07	07/30/07	2:35 PM	Nutt
Incident:	Fire alarm		
Location:	Noble Research Center "A" Wing, 3 rd floor east, electrical room		
Details:	Dirty smoke detector activated alarm		

207-07	07/30/07	6:55 PM	Kelley
Incident:	Fire Alarm		
Location:	Young Hall		
Details:	System malfunction		

208-07	08/01/07	1:55 PM	Stevenson
Incident:	Fire Alarm		
Location:	Williams Apartments, Bldg. 103		
Details:	Electrical fire in circuit breaker box		

**OSU EHS Department
Incident Summary**
For the Period 08/06/07 – 08/12/07

209-07	08/06/07	1:15 PM	Spybuck
Incident:	Fire Alarm		
Location:	PIO Building		
Details:	Dust from masonry saw activated fire alarm		
210-07	08/07/07	8:45 AM	Nutt
Incident:	Ambulance Assist		
Location:	Gallagher-Iba Arena		
Details:	OSU employee having a seizure		
211-07	08/07/07	8:15 AM	Isaacs
Incident:	Spill of corrosive substance		
Location:	Physical Plant, Surplus Loading Dock		
Details:	Spill from punctured barrel		
212-07	08/09/07	3:11 AM	Kelley
Incident:	Fire Alarm		
Location:	Canine Long-Term Housing		
Details:	Smoke from extinguishing a candle		
213-07	08/09/07	5:58 PM	Kelley
Incident:	Ambulance Assist		
Location:	Parking Lot 19		
Details:	Diabetic patient unresponsive in car		
214-07	08/10/07	9:53 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke from cooking activated smoke detector		
215-07	08/10/07	10:45 PM	Kelley
Incident:	Fire Alarm		
Location:	Life Science East, 1 st floor by elevator		
Details:	Dust from custodial floor buffing activated smoke detector		
216-07	08/10/07	10:58 PM	Kelley
Incident:	Fire Alarm		
Location:	Bartlett Center, 3 rd floor, South Hall, near elevator		
Details:	Unknown cause for alarm		
217-07	08/08/07	1:15 PM	Germain
Incident:	Fire Alarm		
Location:	Electronics Lab North Wing		
Details:	Dust activated a smoke detector in the north wing		

**OSU EHS Department
Incident Summary**
For the Period 08/13/07 – 08/19/07

218-07	08/18/07	9:50 AM	Nutt
Incident:	Fire Alarm		
Location:	Classroom Building		
Details:	Dust set off smoke detector		
219-07	08/14/07	5:45 PM	Kelley
Incident:	Fire Alarm		
Location:	North Boone Pickens Stadium		
Details:	Construction worker hit pullbox		
220-07	08/15/07	9:10 AM	Nutt
Incident:	Ambulance Assist		
Location:	Morrill Ave. near Gunderson Hall		
Details:	Person fell on sidewalk		
221-07	08/14/07	1:45 PM	Nutt
Incident:	Fire Alarm		
Location:	Morrill Hall		
Details:	Dirty smoke detector in mechanical room		
222-07	08/16/07	6:45 AM	Nutt
Incident:	Fire Alarm		
Location:	Math Sciences		
Details:	Unknown cause		
223-07	08/16/07	9:12 PM	Kelley
Incident:	Fire Alarm		
Location:	Pinkston Educational Pest Control Facility		
Details:	Dust or bug activated smoke detector		
224-07	08/15/07	3:30 PM	Spybuck
Incident:	Ambulance Assist		
Location:	Vet Med Teaching Hospital, parking lot		
Details:	Person injured by horse		
225-07	08/17/07	4:06 PM	Kelley
Incident:	Ambulance Assist		
Location:	Corner of Monroe and Athletic Ave.		
Details:	Auto accident		
226-07	08/18/07	4:30 PM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C		
Details:	Unknown cause		
227-07	08/19/07	8:20 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C		
Details:	Faulty detector		

OSU EHS Department
Incident Summary
For the Period 08/20/07 – 08/26/07

228-07	08/21/07	Nutt	3:15 PM
Incident:	Fire alarm		
Location:	Dumpster south of Biosystems & Ag Engineering Lab		
Details:	Smoldering cigarette suspected cause		

229-07	08/21/07	Kelley	7:43 PM
Incident:	Fire alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		

230-07	08/22/07	Nutt	9:45 AM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Blow dryer activated smoke detector		

231-07	08/23/07	Kelley	11:30 PM
Incident:	Fire alarm		
Location:	Classroom Bldg. 1 st floor SE exit		
Details:	Dust from custodian using vacuum activated smoke detector		

232-07	08/24/07	Kelley	5:21 PM
Incident:	Fire alarm		
Location:	Colvin Center, indoor soccer area		
Details:	Patient hit head on floor, briefly knocked unconscious		

233-07	08/24/07	Kelley	8:30 PM
Incident:	Fire Alarm		
Location:	Morrison Apartments		
Details:	Smoke from cooking activated smoke detector		

OSU EHS Department
Incident Summary
For the Period 08/27/07 – 09/02/07

234-07	08/27/07	Nutt	2:05 PM
Incident:	Ambulance Assist		
Location:	Allen Hall		
Details:	Patient cut finger		

235-07	08/28/07	Nutt	11:15 AM
Incident:	Fire Alarm		
Location:	Allen Hall		
Details:	Burned food in microwave activated smoke detector		

236-07	08/28/07	Kelley	9:40 PM
Incident:	Ambulance Assist		
Location:	Friend Hall		
Details:	Patient with laceration to right thigh		

237-07	08/28/07	Kelley	11:53 PM
Incident:	Fire Alarm		
Location:	Classroom Bldg. 1 st floor, east end by elevator		
Details:	Dust from vacuuming activated smoke detector		

238-07	08/30/07	Kelley	11:02 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Burned food in microwave activated smoke detector		

OSU EHS Department
Incident Summary
For the Period 09/03/07 – 09/09/07

239-07	09/04/07	Nutt	9:30 AM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Hair dryer activated smoke detector		

240-07	09/04/07	Kelley	10:19 PM
Incident:	Fire Alarm		
Location:	Colvin Center, room 040, lower-level basketball courts		
Details:	Volleyball hit fire alarm pullbox		

241-07	09/06/07	Kelley	10:23 PM
Incident:	Ambulance Assist		
Location:	Colvin Center, outside by east entrance		
Details:	Patient with history of heart problems, passed out		

**OSU EHS Department
Incident Summary**
For the Period 09/10/07 – 09/16/07

242-07	09/10/07	Kelley	11:55 PM
Incident:	Fire Alarm		
Location:	Allen Hall		
Details:	Unknown cause		

254-07	09/11/07	Spybuck	2:30 PM
Incident:	Explosion		
Location:	ATRC		
Details:	Heating chemical in lab		

243-07	09/11/07	Nutt	4:50 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. A		
Details:	Iron being cleaned activated smoke detector		

244-07	09/13/07	Nutt	2:15 PM
Incident:	Ambulance Assist		
Location:	Classroom Bldg.		
Details:	Patient having difficulty breathing		

245-07	09/13/07	Nutt	12:50 PM
Incident:	Fire		
Location:	Dumpster east of Bost Hall		
Details:	Unknown cause of ignition of fire		

246-07	09/11/07	Stevenson	3:17 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Burned popcorn activated smoke detector		

247-07	09/14/07	Kelley	7:45 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		

248-07	09/14/07	Kelley	10:55 PM
Incident:	Fire Alarm		
Location:	Student Union basement, NW women's restroom		
Details:	Alarm activated by possible sprinkler water flow movement		

249-07	09/15/07	Nutt	4:30 AM
Incident:	Fire Alarm		
Location:	McElroy Hall		
Details:	Unknown cause		

250-07	09/15/07	Nutt	7:12 PM
Incident:	Fire alarm		
Location:	Friend Hall		
Details:	Unknown cause		

**OSU EHS Department
Incident Summary**
For the Period 09/10/07 – 09/16/07

251-07	09/15/07	Nutt	8:10 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		

252-07	09/16/07	Nutt	4:06 PM
Incident:	Fire alarm		
Location:	Friend Hall		
Details:	Grilling on deck; smoke entered apartment and activated smoke detector		

253-07	09/16/07	Nutt	8:50 PM
Incident:	Fire alarm		
Location:	Friend Hall		
Details:	Alarm activated by broken sprinkler head		

258-07	09/11/07	Spybuck	2:30 PM
Incident:	Explosion		
Location:	ATRC		
Details:	explosion in lab		

**OSU EHS Department
Incident Summary**
For the Period 09/17/07 – 09/23/07

255-07	09/17/07	Isaacs	9:30 AM
Incident:	Leaking box		
Location:	University Mailing		
Details:	Box leaking saline eyewash solution		

256-07	09/17/07	Nutt	4:00 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C		
Details:	Unknown cause		

257-07	09/17/07	Nutt	11:55 PM
Incident:	Fire Alarm		
Location:	Stout Hall		
Details:	Unknown cause		

259-07	09/19/07	Nutt	7:15 AM
Incident:	Fire Alarm		
Location:	Ag Hall South, 1 st floor		
Details:	Dust or bugs in smoke detector activated alarm		

260-07	09/20/07	Kelly	6:18 PM
Incident:	Fire Alarm		
Location:	Animal Science Arena		
Details:	Students washing wall got water in pull box and horn/strobe		

261-07	09/21/07	Nutt	9:00 AM
Incident:	Ambulance Assist		
Location:	Physical Plant North		
Details:	Patient passed out and hit head on floor		

262-07	09/21/07	Stevenson	9:10 AM
Incident:	Fire Alarm		
Location:	Zink Hall		
Details:	Dirty smoke detector activated alarm		

263-07	09/21/07	Kelley	8:51 PM
Incident:	Ambulance Assist		
Location:	Outside, corner of McElroy and Willis		
Details:	Patient lying at side of road		

264-07	09/22/07	Nutt	12:00 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Building E		
Details:	Blow dryer activated smoke detector		

265-07	09/23/07	Kelley	11:15 PM
Incident:	Fire Alarm		
Location:	Booker Hall		
Details:	Dirty smoke detector activated alarm		

**OSU EHS Department
Incident Summary**
For the Period 09/17/07 – 09/23/07

266-07	09/23/07	Kelley	10:24 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C		
Details:	Steam from shower activated alarm		

**OSU EHS Department
Incident Summary**
For the Period 09/24/07 – 09/30/07

267-07	09/25/07	Mason	2:30 PM
Incident:	Fire Alarm		
Location:	Vet Med Teaching Hospital, Junior Surgery		
Details:	Smoke from burned microwaved rice socks activated alarm		
268-07	09/26/07	Isaacs	3:05 PM
Incident:	Glass-break Alarm		
Location:	McElroy Hall basement, outside of lab in hallway		
Details:	Unknown cause for alarm		
269-07	09/27/07	Nutt	1:39 PM
Incident:	Fire Alarm		
Location:	Gallagher Iba Arena		
Details:	Pull box activated; no evidence of fire		
270-07	09/27/07	Isaacs	2:05 PM
Incident:	Glass-break Alarm		
Location:	McElroy Hall, outside of lab on loading dock		
Details:	Unknown cause for alarm		
271-07	09/27/07	Spybuck	3:25 PM
Incident:	Fire Alarm		
Location:	Patchin-Jones Suites		
Details:	Steam from shower activated alarm		
272-07	09/27/07	Kelley	9:42 PM
Incident:	Fire Alarm		
Location:	Young Hall		
Details:	Smoke from cooking activated alarm		
273-07	09/28/07	Nutt	9:30 AM
Incident:	Fire Alarm		
Location:	Patchin-Jones Suites		
Details:	Employee released dust from vacuum cleaner, which activated alarm		
274-07	09/29/07	Nutt	10:40 AM
Incident:	Fire		
Location:	Apartment 16, North University Place, north of Tyler Ave.		
Details:	Dumpster fire		
275-07	09/30/07	Nutt	11:00 AM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		
277-07	09/29/07	Kelley	4:45 PM
Incident:	Ambulance Assist		
Location:	Wes Watkins Center, 1 st floor		
Details:	Patient with chest pain		

OSU EHS Department
Incident Summary
For the Period 10/01/07 – 10/07/07

276-07	10/01/07	Nutt	3:30 AM
Incident:	Fire Alarm		
Location:	Forage Research Lab		
Details:	unknown cause for alarm		

278-07	10/01/07	Stevenson	1:20 PM
Incident:	Fire Alarm		
Location:	Ag Hall South wing		
Details:	Water leaked into a smoke detector		

279-07	10/01/07	Kelley	9:42 PM
Incident:	Ambulance Assist		
Location:	South of Connell Ave. on Monroe St.		
Details:	Bicycle wreck		

280-07	10/02/07	Stevenson	9:03 AM
Incident:	Ambulance Assist		
Location:	Village Apartments, Bldg. F		
Details:	Patient jumped to landing and injured ankle		

281-07	10/03/07	Kelley	6:44 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Smoke from cooking appeared to activate the alarm		

282-07	10/03/07	Kelley	7:13 PM
Incident:	Ambulance Assist		
Location:	Morrill Hall		
Details:	Patient appeared to be having a seizure		

283-07	10/03/07	Kelley	10:40 PM
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke from cooking appeared to activate the alarm		

284-07	10/03/07	Kelley	8:27 PM
Incident:	Fire Alarm		
Location:	Kerr Hall		
Details:	Unknown cause		

285-07	10/05/07	Kelley	4:26 PM
Incident:	Fire Alarm		
Location:	Human Environmental Sciences West		
Details:	Patient appeared to be having a seizure		

**OSU EHS Department
Incident Summary**
For the Period 10/08/07 – 10/14/07

Page 1 of 2

287-07	10/08/07	Spybuck	2:10 PM
Incident:	Fire Alarm		
Location:	Visual Arts Annex		
Details:	Dirt, dust from changing filters got into the air handling unit and activated the fire alarm		

288-07	10/09/07	Spybuck	1:26 AM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. F		
Details:	Pull box activated—no fire		

289-07	10/10/07	Germain	9:30 AM
Incident:	Fire Alarm		
Location:	Boone Pickens Stadium, South		
Details:	Unknown—possibly related to construction activity		

290-07	10/10/07	Germain	10:30 AM
Incident:	Fire Alarm		
Location:	Physical Sciences I, 1 st floor		
Details:	Smoke from burned drive belt in HVAC unit; pull box activated alarm		

291-07	10/10/07	Germain	2:45 PM
Incident:	Burning odor investigation		
Location:	Engineering North, south elevator		
Details:	Hot motor in basement elevator control room		

292-07	10/11/07	Spybuck	2:04 AM
Incident:	Fire Alarm		
Location:	Stinchcomb Apartments		
Details:	Unknown cause		

293-07	10/11/07	Spybuck	2:19 AM
Incident:	Fire Alarm		
Location:	Reynolds Stadium		
Details:	Unknown cause		

294-07	10/11/07	Spybuck	2:44 AM
Incident:	Fire Alarm		
Location:	Cohn Family Animal Shelter		
Details:	Faulty heat detector		

295-07	10/11/07	Stevenson	12:02 PM
Incident:	Fire		
Location:	Engineering North, Room 410		
Details:	Overheating of axle grease in industrial oven		

296-07	10/11/07	Germain	12:12 PM
Incident:	Vehicle Fire		
Location:	Parking Lot 99, corner of Washington & Connell		
Details:	Electrical short		

**OSU EHS Department
Incident Summary**
For the Period 10/08/07 – 10/14/07

297-07	10/12/07	Kelley	6:22 PM
Incident:	Ambulance Assist		
Location:	Village Apartments, Bldg. D		
Details:	Lacerated forearm		

298-07	10/14/07	Kelley	12:30 PM
Incident:	Fire Alarm		
Location:	Kamm Apartments		
Details:	Smoke from cooking activated fire alarm		

**OSU EHS Department
Incident Summary**
For the Period 10/15/07 – 10/21/07

299-07	10/16/07	Kelley	8:08 PM
Incident:	Fire Alarm		
Location:	Peterson Apts.		
Details:	Smoke from cooking activated detector		

300-07	10/16/07	Kelley	9:19 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. A		
Details:	Steam from shower activated detector		

301-07	10/17/07	Kelley	7:06 PM
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Smoke from cooking activated detector		

302-07	10/18/07	Nutt	8:08 AM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower blown by hair dryer and activated detector		

303-07	10/18/07	Stevenson	8:19 AM
Incident:	Ambulance Assist		
Location:	Parking lot, north of Wes Watkins Center for International Development building		
Details:	Patient tripped and fell		

304-07	10/18/07	Kelley	4:44 PM
Incident:	Ambulance Assist		
Location:	Wentz Hall		
Details:	Patient weak and dizzy		

305-07	10/19/07	Kelley	9:03 PM
Incident:	Fire Alarm		
Location:	Zink Hall 2 nd floor hallway		
Details:	Unknown cause		

306-07	10/20/07	Nutt	4:37 PM
Incident:	Fire Alarm		
Location:	Ag Hall South fourth floor		
Details:	Smoke detector malfunction		

307-07	10/20/07	Nutt	8:38 PM
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Smoke from burned food activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 10/22/07 – 10/28/07

308-07	10/22/07	Stevenson	11:45 AM
Incident:	Fire Alarm		
Location:	Kamm Apartments		
Details:	Smoke from cooking activated detector		

309-07	10/23/07	Kelley	7:06 PM
Incident:	Fire Alarm		
Location:	Student Union		
Details:	No fire; alarm trouble signal mis-read as a fire alarm by dispatcher		

310-07	10/24/07	Kelley	7:43 PM
Incident:	Ambulance Assist		
Location:	Brumley Apartments		
Details:	Patient with breathing difficulty		

311-07	10/24/07	Kelley	9:51 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Steam from shower activated smoke detector		

312-07	10/25/07	Nutt	2:26 PM
Incident:	Ambulance Assist		
Location:	Brumley Apartments		
Details:	Unknown illness		

313-07	10/25/07	Kelley	9:29 PM
Incident:	Ambulance Assist		
Location:	Colvin Center, lower level		
Details:	Patient with injured right ankle		

314-07	10/25/07	Kelley	11:08 PM
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke from burned food activated detector		

315-07	10/26/07	Dodson	2:00 PM
Incident:	Asbestos Exposure		
Location:	EHS Asbestos Office		
Details:	Plumber brought asbestos-insulated pipe into the office		

316-07	10/28/07	Nutt	3:04 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C		
Details:	Smoke from burned food activated detector		

317-07	10/28/07	Nutt	6:58 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. F		
Details:	Smoke from burned food activated detector		

**OSU EHS Department
Incident Summary**
For the Period 10/29/07 – 11/04/07

318-07	10/29/07	Nutt	1:52 PM
Incident:	Ambulance Assist		
Location:	Iba Hall – Reslife offices		
Details:	Possible cardiac incident		

319-07	10/29/07	Kelley`	3:22 PM
Incident:	Fire Alarm		
Location:	Drummond Hall		
Details:	Contractors testing new fire pump may have activated alarm		

320-07	10/29/07	Kelley	9:41 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Use of hair spray may have activated detector		

321-07	10/31/07	Nutt	10:15 AM
Incident:	Ambulance Assist		
Location:	Morrill Hall		
Details:	Patient with chest pain		

322-07	10/31/07	Nutt	5:55 PM
Incident:	Fire Alarm		
Location:	Smith Hall		
Details:	Smoke from burned food activated smoke detector		

323-07	11/01/07	Nutt	4:04 AM
Incident:	Fire Alarm		
Location:	Peterson Hall		
Details:	Smoke from burned food activated smoke detector		

324-07	11/02/07	Stevenson	2:31 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam or hair spray activated smoke detector		

325-07	11/02/07	Nutt	11:03 AM
Incident:	Fire Alarm		
Location:	North Ag Hall		
Details:	Unknown cause		

**OSU EHS Department
Incident Summary**
For the Period 11/05/07 – 11/11/07

326-07	11/05/07	Kelley	11:50 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		

327-07	11/06/07	Kelley	5:54 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Steam from shower activated smoke detector		

328-07	11/08/07	Kelley	4:31 PM
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		

329-07	11/08/07	Kelley	8:02 PM
Incident:	Fire Alarm		
Location:	Bost Hall		
Details:	Smoking in room activated smoke detector		

330-07	11/09/07	Nutt	9:26 AM
Incident:	Ambulance Assist		
Location:	Brumley Apartments		
Details:	Recurring medical issues required transport to SMC		

331-07	11/09/07	Nutt	3:45 PM
Incident:	Ambulance Assist		
Location:	Practice field west of Student Union		
Details:	Band student became ill		

332-07	11/10/07	Nutt	6:21 PM
Incident:	Fire Alarm		
Location:	Outside, SW corner of Booker Hall		
Details:	Dumpster fire		

333-07	11/11/07	Spybuck	12:14 PM
Incident:	Tamper Alarm		
Location:	Breezeway, Morrison Housing		
Details:	Cover for a pull station was activated		

334-07	11/11/07	Spybuck	7:49 PM
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Smoke from cooking activated alarm		

**OSU EHS Department
Incident Summary**
For the Period 11/12/07 – 11/18/07

Page 1 of 2

335-07	11/12/07	4:34 AM	Spybuck
Incident:	Fire Alarm		
Location:	Peterson Hall		
Details:	Smoke detector activated--unknown cause		

336-07	11/12/07	12:07 PM	Nutt
Incident:	Fire		
Location:	Chi-O Clock Mall		
Details:	Smoking materials discarded in trash can		

337-07	11/12/07	5:26 PM	Kelley
Incident:	Ambulance assist		
Location:	Village Apartments, Bldg. F		
Details:	Fight resulting in injuries		

338-07	11/13/07	9:24 AM	Nutt
Incident:	Ambulance Assist		
Location:	Morrill Hall north parking lot		
Details:	Patient with abdominal pain		

339-07	11/13/07	11:08 AM	Stevenson
Incident:	Ambulance Assist		
Location:	South side of Library		
Details:	Patient with seizures		

340-07	11/13/07	1:39 AM	Spybuck
Incident:	Fire Alarm		
Location:	Bost Hall		
Details:	Steam from bathroom activated smoke detector		

341-07	11/14/07	8:29 AM	Nutt
Incident:	Ambulance Assist		
Location:	Atherton Hotel Lobby		
Details:	Patient with chest pains		

342-07	11/14/07	10:30 AM	Isaacs
Incident:	Hazardous Substance Spill		
Location:	University Mailing Services, outside dock		
Details:	Broken bottles of lidocaine		

343-07	11/15/07	10:30 AM	Isaacs
Incident:	Hazardous Substance Spill		
Location:	University Mailing Services, outside dock		
Details:	Broken bottles of water samples		

344-07	11/17/07	5:30 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. F		
Details:	Resident using hair dryer under smoke detector activated detector		

**OSU EHS Department
Incident Summary**
For the Period 11/12/07 – 11/18/07

345-07	11/17/07	11:23 PM	Kelley
Incident:	Fire Alarm		
Location:	Patchin Suites		
Details:	Smoke from burned popcorn activated smoke detector		

OSU EHS Department
Incident Summary
For the Period 11/19/07 – 11/25/07

346-07	11/19/07	7:18 PM	Kelley
Incident:	Fire Alarm		
Location:	Stout Hall		
Details:	Undetermined cause		

347-07	11/20/07	7:45 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. A		
Details:	Burned food activated smoke detector		

348-07	11/21/07	1:36 AM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		

349-07	11/23/07	10:43 PM	Stevenson
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Smoke from cooking activated detector		

350-07	11/24/07	1:46 AM	Stevenson
Incident:	Fire alarm		
Location:	Student Union		
Details:	Water flow alarm		

OSU EHS Department
Incident Summary
For the Period 11/26/07 – 12/2/07

351-07	11/26/07	1:44 PM	Nutt
Incident:	Ambulance Assist		
Location:	Physical Sciences, 4 th floor		
Details:	Unknown medical issues		

352-07	11/27/07	1:45 AM	Nutt
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Burned food activated smoke detector		

353-07	11/27/07	1:31 PM	Nutt
Incident:	Ambulance Assist		
Location:	Corner of Athletic & Hester		
Details:	Patient unresponsive		

354-07	11/27/07	4:36 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke from cooking activated smoke detector		

355-07	11/28/07	3:58 PM	Kelley
Incident:	Ambulance Assist		
Location:	Engineering South		
Details:	Patient felt ill; no transport		

356-07	11/28/07	7:16 PM	Kelley
Incident:	Ambulance Assist		
Location:	Corner of Weir Lane and Monroe St.		
Details:	Patient with neck pain, no transport		

**OSU EHS Department
Incident Summary**
For the Period 12/03/07 – 12/09/07

Page 1 of 2

357-07	12/03/07	4:30 PM	Isaacs
Incident:	Leaking package		
Location:	University Mailing Services		
Details:	Package leaking unknown substance		

358-07	12/03/07	10:00 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Using hair dryer under smoke detector		

359-07	12/03/07	10:13 PM	Kelley
Incident:	Ambulance Assist		
Location:	Bennett Hall		
Details:	Unknown medical condition		

360-07	12/04/07	11:00 AM	Nutt
Incident:	Ambulance Assist		
Location:	Student Union food court		
Details:	Unknown medical condition		

361-07	12/04/07	12:50 PM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		

362-07	12/04/07	11:29 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E/F		
Details:	Steam from shower activated smoke detector		

363-07	12/05/07	1:20 PM	Stevenson
Incident:	Fire Alarm		
Location:	Morsani Apartments		
Details:	Smoke from burned food activated detector		

364-07	12/05/07	11:41 AM	Nutt
Incident:	Fire Alarm		
Location:	Patchin Hall		
Details:	Smoke from burned food activated detector		

365-07	12/06/07	11:20 AM	Nutt
Incident:	Fire Alarm		
Location:	Peterson Hall		
Details:	Smoke from burned food activated detector		

366-07	12/06/07	4:42 PM	Kelley
Incident:	Ambulance Assist		
Location:	Parking lot at Cantwell & Hester		
Details:	Injuries from altercation in parking lot		

**OSU EHS Department
Incident Summary**
For the Period 12/03/07 – 12/09/07

367-07	12/07/07	3:00 PM	Nutt
Incident:	Ambulance Assist		
Location:	Monroe Street in front of Math Science Bldg.		
Details:	Freight fell off truck and injured patient		

368-07	12/07/07	4:54 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments Bldg. D		
Details:	Resident using hair dryer activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 12/10/07 – 12/16/07

369-07	12/10/07	10:19 PM	Kelley
Incident:	Fire Alarm		
Location:	Kamm Apartments		
Details:	Burned food activated smoke detector		

370-07	12/11/07	7:32 AM	Nutt
Incident:	Fire Alarm		
Location:	Student Union		
Details:	Water leaking through 4 th floor; shorted out smoke detector		

371-07	12/10/07	9:30 AM	Nutt
Incident:	Report of Injury		
Location:	Student Services Center/Student Union		
Details:	Student fell on icy steps		

372-07	12/12/07	11:38 AM	Nutt
Incident:	Fire Alarm		
Location:	Kamm Apartments		
Details:	Smoke from burned food activated smoke detector		

373-07	12/13/07	7:01 pm	Kelley
Incident:	Chemical spill		
Location:	Engineering South, Engineering Lab		
Details:	Ammonium persulfate and sodium carbonate		

375-07	12/13/07	11:44 AM	Nutt
Incident:	Fire Alarm		
Location:	Peterson Hall		
Details:	Smoke from burned food activated smoke detector		

OSU EHS Department
Incident Summary
For the Period 12/17/07 – 12/23/07

374-07	12/17/07	12:37 AM	Kelley
Incident:	Fire Alarm		
Location:	Agriculture Center Office Bldg., 2 nd floor		
Details:	Cause of alarm is unknown		

376-07	12/18/07	5:55 PM	Stevenson
Incident:	Fire Alarm		
Location:	Friend Hall Apartments		
Details:	Smoke from burning incense activated smoke detector		

377-07	12/19/07	3:21 PM	Germain
Incident:	Fire Alarm		
Location:	Peterson Hall Apartments		
Details:	Dust from contractor's work activated smoke detector		

378-07	12/22/07	9:20 AM	Nutt
Incident:	Fire Alarm		
Location:	Gallagher-Iba Arena		
Details:	Testing of smog generator activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 12/24/07 – 12/30/07

379-07	12/24/07	7:05 AM	Nutt
Incident:	Fire Alarm		
Location:	4-H Building		
Details:	Power fluctuation activated alarm system		

380-07	12/24/07	8:12 PM	Nutt
Incident:	Fire Alarm		
Location:	Small Grains Bldg.		
Details:	Dirty smoke detector activated alarm		

381-07	12/24/07	11:25 AM	Nutt
Incident:	Fire Alarm		
Location:	Fire Service Training Lab/Classroom		
Details:	Power fluctuation activated alarm system		

382-07	12/26/07	9:28 PM	Nutt
Incident:	Fire Alarm		
Location:	Small Grains Bldg.		
Details:	Dirty smoke detector activated alarm		

383-07	12/28/07	2:41 AM	Nutt
Incident:	Fire Alarm		
Location:	Bennett Hall West, lounge area		
Details:	Smoke from burned food in microwave activated smoke detector		

384-07	12/28/07	10:27 PM	Stevenson
Incident:	Fire Alarm		
Location:	Student Union		
Details:	Malfunctioning smoke detector		

OSU EHS Department
Incident Summary
For the Period 12/31/07 – 01/06/08

385-08	12/31/07	4:06 PM	Stevenson
Incident:	Fire Alarm		
Location:	Student Union		
Details:	Water leak caused a smoke detector to short out		

386-07	12/31/07	5:13 PM	Stevenson
Incident:	Fire Alarm		
Location:	Student Union		
Details:	Water leak continuing to affect fire alarm system		

387-07	12/31/07	6:03 PM	Stevenson
Incident:	Fire Alarm		
Location:	South Stadium		
Details:	Fire pump run alarm activated, unknown cause		

001-08	01/01/08	3:15 AM	Stevenson
Incident:	Fire Alarm		
Location:	Brumley Apartments		
Details:	Smoke from burned food activated smoke detector		

002-08	01/03/08	3:00 PM	Nutt
Incident:	Fire		
Location:	Smith Hall, parking lot		
Details:	Fire in dumpster		

003-08	01/04/08	8:15 AM	Nutt
Incident:	Fire Alarm		
Location:	Life Science East		
Details:	Construction crew set off smoke detector with dust		
