

OKLAHOMA STATE UNIVERSITY

ENVIRONMENTAL HEALTH & SAFETY DEPARTMENT



2008 INCIDENT REPORT LOG

Weekly reports on fire alarms, ambulance calls, accident investigations, hazmat response, and other activities that required immediate response by EHS personnel

**OSU EHS Department
Incident Summary**
For the Period 01/07/08 – 01/13/08

004-08	01/07/08	9:58 PM	Kelley
Incident:	Ambulance Assist		
Location:	Colvin Center		
Details:	Patient feeling dizzy and nauseated		
005-08	01/08/08	8:49 AM	Nutt
Incident:	Ambulance Assist		
Location:	McElroy Hall		
Details:	Patient passed out		
006-08	01/09/08	9:35 AM	Nutt
Incident:	Ambulance Assist		
Location:	Intersection of Monroe & Hall of Fame		
Details:	Bicyclist in path of turning vehicle; no injuries, but bicycle struck and damaged		
007-08	01/09/08	9:56 AM	Nutt
Incident:	Ambulance Assist		
Location:	Classroom Building		
Details:	Patient briefly passed out in class		
008-08	01/09/08	10:02 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. A		
Details:	Steam from shower activated smoke detector		
009-08	01/10/08	5:29 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Smoke from cooking activated smoke detector		
010-08	01/12/08	12:10 PM	Kelley
Incident:	Ambulance Assist		
Location:	Gallagher Iba Arena		
Details:	Patient collapsed		
011-08	01/12/08	3:31 AM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke from cooking activated smoke detector		
012-08	01/13/08	1:38 PM	Kelley
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Smoke from cooking activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 01/14/08 – 01/20/08

013-08	01/14/08	6:51 PM	Kelley
Incident:	Fire Alarm		
Location:	Bennett Hall West		
Details:	Smoke from cooking activated detector		
014-08	01/15/08	9:45 AM	Stephenson
Incident:	Fire Alarm		
Location:	Jones Hall		
Details:	Smoke from cooking activated detector		
015-08	01/15/08	10:52 AM	Stephenson
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. F		
Details:	Steam from shower activated detector		
016-08	01-15-08	7:36 PM	Kelley
Incident:	Fire		
Location:	McElroy Hall, west side of building		
Details:	Probably caused by hot charcoal dumped in trash can		
017-08	01/16/08	8:50 AM	Nutt
Incident:	First Aid		
Location:	Life Science East		
Details:	Patient fainted		
018-08	01/16/08	7:47 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke from cooking activated detector		
019-08	01/17/08	4:18 PM	Kelley
Incident:	Fire Alarm		
Location:	Smith Hall		
Details:	Detector activated from unknown cause		
120-08	01/17/08	7:40 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Resident blow-drying hair activated detector		
121-08	01/18/08	8:23 AM	Stevenson
Incident:	Fire Alarm		
Location:	Live Animal Research Bldg. 64		
Details:	Steam in air handling units activated alarm		
122-08	01/17/08	11:02 PM	Kelley
Incident:	Fire Alarm		
Location:	Classroom Bldg. 1 st floor, NW exit		
Details:	Unknown person pulled pull box		

OSU EHS Department
Incident Summary
For the Period 01/21/08 – 01/27/08

123-08	01/25/08	10:50 AM	Nutt
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Spray from aerosol can activated smoke detector		

124-08	01/24/08	8:31 PM	Kelley
Incident:	Fire Alarm		
Location:	Classroom Bldg., 3 rd floor hallway		
Details:	Dust activated smoke detector		

125-08	01/26/08	10:06 PM	Nutt
Incident:	Fire Alarm		
Location:	Patchin Jones Hall		
Details:	Steam from iron activated smoke detector		

OSU EHS Department
Incident Summary
For the Period 01/28/08 – 02/03/08

128-08	01/29/08	4:15 AM	Nutt
Incident:	Fire Alarm		
Location:	Carreker Hall West		
Details:	Alarm activated by a sprinkler flow switch		

129-08	01/29/08	3:20 PM	Nutt
Incident:	Fire Alarm		
Location:	Gallagher Iba Arena		
Details:	Pull box activated—no fire		

130-08	02/01/08	9:08 AM	Stevenson
Incident:	Fire Alarm		
Location:	Young Hall		
Details:	Alarm activated by smoke from hot grease that spilled on stove		

131-08	02/01/08	9:05 AM	Nutt
Incident:	Ambulance Assist		
Location:	North University Apartments		
Details:	Patient having difficulty breathing		

**OSU EHS Department
Incident Summary**
For the Period 02/04/08 – 02/10/08

132-08	02/04/08	10:02 AM	Germain
Incident:	Fire Alarm		
Location:	Whitehurst Hall, basement		
Details:	Construction crew activated smoke detector with dust		

133-08	02/05/08	8:12 AM	Nutt
Incident:	Fire Alarm		
Location:	Physical Science Bldg.		
Details:	Malfunctioning smoke detector		

134-08	02/05/08	6:18 AM	Stevenson
Incident:	Fire Alarm		
Location:	Griffith Community Center at North Monroe Apartments		
Details:	Lightning strike activated several apartment alarms		

135-08	02/06/08	3:44 AM	Stevenson
Incident:	Fire Alarm		
Location:	Allen Apartments		
Details:	Possibly linked to the lightning strike the previous day		

136-08	02/06/08	6:18 PM	Kelley
Incident:	Fire Alarm		
Location:	Noble Research Center, D Wing		
Details:	Someone pulled a pull box		

137-08	02/06/08	10:01 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		

138-08	02/06/08	10:18 AM	Germain
Incident:	Ambulance Assist		
Location:	Classroom Bldg., 3 rd floor		
Details:	Patient having seizure		

139-08	02/06/08	10:18 AM	Germain
Incident:	Fire Alarm		
Location:	Engineering North , 3 rd floor		
Details:	Burned food in microwave activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 02/11/08 – 02/17/08

140-08	02/12/08	10:22 AM	Nutt
Incident:	Ambulance Assist		
Location:	Ag Hall, North		
Details:	Patient going in and out of consciousness		

141-08	02/13/08	11:29 AM	Nutt
Incident:	Ambulance Assist		
Location:	Wes Watkins Center for International Trade Development, north parking lot		
Details:	Patient hyperventilating		

142-08	02/13/08	4:57 PM	Kelley
Incident:	Fire Alarm		
Location:	Jones Suites		
Details:	Resident using blow dryer activated smoke detector		

143-08	02/13/08	10:50 PM	Kelley
Incident:	Ambulance Assist		
Location:	Colvin Center, lower level, indoor pool		
Details:	Patient hit face in water while diving		

144-08	02/14/08	8:48 PM	Kelley
Incident:	Fire Alarm		
Location:	Classroom Bldg., 2 nd floor west stairwell		
Details:	Someone pulled a pull box		

145-08	02/14/08	10:08 PM	Kelley
Incident:	Fire Alarm		
Location:	Vet Med Teaching Hospital, North Front Lobby		
Details:	Custodian buffing floor activated smoke detector		

146-08	02/16/080	5:30 PM	Spybuck
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C		
Details:	Smoke from cooking activated detectors		

**OSU EHS Department
Incident Summary**
For the Period 02/18/08 – 02/24/08

147-08	02/18/08	2:41 PM	Germain
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		

148-08	02/18/08	9:15 PM	Kelley
Incident:	Ambulance Assist		
Location:	Colvin Center, lower level, gym 4		
Details:	Patient appeared to be having a seizure		

149-08	02/19/08	1:47 PM	Nutt
Incident:	Broken gas line		
Location:	New Science & Technology construction site		
Details:	Construction crew broke gas line		

150-08	02/19/08	10:12 PM	Kelley
Incident:	Ambulance Assist		
Location:	Gallagher Iba Arena, Auxiliary Gym		
Details:	Patient apparently injured neck during cheerleading routine		

151-08	02/19/08	11:03 PM	Kelley
Incident:	Fire alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		

152-08	02/21/08	1:48 PM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. F		
Details:	Smoke from burned food activated smoke detector		

153-08	02/21/08	11:44 PM	Kelley
Incident:	Ambulance Assist		
Location:	Village Apartments, Bldg. B		
Details:	Patient with possible alcohol poisoning		

OSU EHS Department
Incident Summary
For the Period 02/25/08 – 03/02/08

154-08	02/27/08	10:58 AM	Nutt
Incident:	Ambulance Assist		
Location:	West Chilled Water Plant construction area		
Details:	Construction worker fell from ladder onto concrete		

155-08	02/27/08	8:12 PM	Kelley
Incident:	Ambulance Assist		
Location:	Village Apartments, Bldg. F		
Details:	Patient complaining of chest pains & problems breathing		

156-08	02/27/08	1:20 PM	Spybuck
Incident:	Fire Alarm		
Location:	Public Information Office Bldg., mechanical room		
Details:	Dust from construction activated detector		

157-08	02/28/08	3:10 PM	Nutt
Incident:	Fire Alarm		
Location:	ATRC and Engr. North		
Details:	Fire in expansion joint area between two buildings, caused by construction work		

158-08	03/01/08	2:45 AM	Nutt
Incident:	Fire Alarm		
Location:	Jones Apartments		
Details:	Resident drying hair with blow dryer activated smoke detector		

159-08	03/01/08	11:05 AM	Nutt
Incident:	Fire Alarm		
Location:	Kamm Hall		
Details:	Burned food activated smoke detector		

160-08	03/01/08	10:12 PM	Nutt
Incident:	Fire Alarm		
Location:	Kamm Hall		
Details:	Burned food activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 03/03/08 – 03/09/08

161-08	03/03/08	2:45 AM	Nutt
Incident:	Fire Alarm		
Location:	Boone Pickens Stadium, south side		
Details:	dry pipe system filled		

162-08	03/03/08	8:14 PM	Kelley
Incident:	Ambulance Assist		
Location:	Colvin Center		
Details:	Patient injured shoulder while playing basketball		

163-08	03/04/08	5:03 PM	Kelley
Incident:	Ambulance Assist		
Location:	Monroe Street and entrance to parking lot #31		
Details:	Auto/pedestrian accident		

164-08	03/05/08	12:20 PM	Nutt
Incident:	Fire		
Location:	SE corner of intersection of Sangre and McElroy		
Details:	Unattended brush fire from 03/04/08 rekindled		

165-08	03/05/08	10:51 PM	Kelley
Incident:	Ambulance Assist		
Location:	North intramural field, near Wellness Center		
Details:	Patient injured ankle while running bases		

166-08	03/05/08	3:39 PM	Nutt
Incident:	Fire Alarm		
Location:	Boone Pickens Stadium, south side		
Details:	Steam from east kitchen suites set off HVAC duct detector		

167-08	03/06/08	7:06 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Steam from shower activated smoke detector		

168-08	03/08/08	11:07PM	Stevenson
Incident:	Fire Alarm		
Location:	Young Apartments		
Details:	Burned food activated smoke detector		

169-08	03/09/08	1:19 PM	Stevenson
Incident:	Report of gas smell		
Location:	Student Union Atherton Hotel		
Details:	Burned out motor in ceiling fan created a burned wiring smell		

170-08	03/09/08	6:36 PM	Stevenson
Incident:	Fire Alarm		
Location:	Carreker Apartments		
Details:	Pull box cover knocked off, which activated alarm		

**OSU EHS Department
Incident Summary**
For the Period 03/03/08 – 03/09/08

171-08	03/08/08	1:54 PM	Stevenson
Incident:	Fire Alarm		
Location:	Noble Research Center, east basement elevator area		
Details:	Elevator motor burned out, immobilizing elevator and creating smoke		

**OSU EHS Department
Incident Summary**
For the Period 03/10/08 – 03/16/08

172-08	03/11/08	5:12 PM	Kelley
Incident:	Fire Alarm		
Location:	SE corner of Intramural Fields		
Details:	Patient injured knee playing softball		

173-08	03/11/08	5:19 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke from cooking activated smoke detector		

174-08	03/13/08	11:05 AM	Germain
Incident:	Gas Odor		
Location:	University Apartment Bldg. 102		
Details:	Bad stove fitting caused gas odor		

175-08	03/13/08	3:10 PM	Germain
Incident:	Gas Odor		
Location:	University Apartment Bldg. 92		
Details:	Loose fitting on oven caused gas odor		

176-08	03/14/08	12:30 PM	Nutt
Incident:	Ambulance Assist		
Location:	Student Union Food Court area		
Details:	Patient with a possible reaction		

OSU EHS Department
Incident Summary
For the Period 03/17/08 – 03/23/08

177-08	03/17/08	10:05 AM	Nutt
Incident:	Ambulance Assist		
Location:	Gallagher Iba Auxiliary Gym		
Details:	Patient having loss of feeling left side of body		

178-08	03/19/08	9:10 AM	Nutt
Incident:	Fire Alarm		
Location:	Wes Watkins CITD		
Details:	Fire alarm system malfunction		

**OSU EHS Department
Incident Summary**
For the Period 03/24/08 – 03/30/08

179-08	03/26/08	8:30 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		
180-08	03/26/08	11:16 AM	Germain
Incident:	Fire Alarm		
Location:	Bennett Hall		
Details:	Steam from shower activated smoke detector		
181-08	03/26/08	7:20 PM	Kelley
Incident:	Fire Alarm		
Location:	Cordell Hall, center wing, 1 st floor, SW exit		
Details:	Alarm pull box accidentally pulled		
182-08	03/24/08	11:32 AM	Spybuck
Incident:	Chemical Spill		
Location:	Booker Hall, South end, outside by dumpster, parking lot 75A		
Details:	Unknown spilled substance		
183-08	03/27/08	3:07 PM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		
184-08	03/29/08	9:07 AM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Heat from hair dryer activated smoke detector		
185-08	03/29/08	5:29 PM	Kelley
Incident:	Fire Alarm		
Location:	Bennett Hall West		
Details:	Candle and container melted onto TV cabinet		
186-08	03/30/08	5:37 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartment,s Bldg. E		
Details:	Unattended candle melted and activated smoke detector		
188-08	03/27/08	3:50 PM	Nutt
Incident:	Fire		
Location:	Kamm parking lot, south		
Details:	Car on fire		

**OSU EHS Department
Incident Summary**
For the Period 03/31/08 – 04/06/08

187-08	04/01/08	12:45 PM	Nutt
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Burned food activated smoke detector		

189-08	03/31/08	9:57 AM	Spybuck
Incident:	Fire Alarm		
Location:	Bennett Hall East, 1 st floor mechanical room		
Details:	Condensation in detector caused malfunction		

190-08	04/02/08	2:45 PM	Isaacs
Incident:	Unidentified odor		
Location:	Wentz Hall		
Details:	Odor similar to paint thinner throughout building, dissipated before EHS left scene		

191-08	04/02/08	1:35 PM	Nutt
Incident:	Fire Alarm		
Location:	ATRC		
Details:	Possible malfunction of system		

192-08	04/03/08	2:18 PM	Nutt
Incident:	Fire Alarm		
Location:	Kamm Hall		
Details:	Smoke detector activated by unknown cause		

193-08	04/04/08	9:10 AM	Nutt
Incident:	Ambulance Assist		
Location:	Willard Hall		
Details:	Patient had passed out but regained consciousness		

194-08	04/04/08	4:46 PM	Kelley
Incident:	Ambulance Assist		
Location:	SW corner of Droke Track and Hall of Fame		
Details:	Bandaged left knee with small contusion due to traffic accident		

195-08	04/04/08	8:45 PM	Kelley
Incident:	Odor Investigation		
Location:	Kerr Hall, 4 th floor		
Details:	Pan left on hot plate created odor of burned food		

196-08	04/05/08	10:00 AM	Nutt
Incident:	Fire Alarm		
Location:	Patchin Jones		
Details:	Student using hair dryer activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 04/07/08 – 04/13/08

197-08	04/07/08	12:23 AM	Nutt
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Smoke from candles activated smoke detector		
198-08	04/07/08	1:30 AM	Nutt
Incident:	Fire Alarm		
Location:	Kamm Hall		
Details:	Use of hair spray activated smoke detector		
199-08	04/08/08	1:00 PM	Grotheer, L.
Incident:	Chemical Spill		
Location:	Biosystems Ag Engineering		
Details:	Broken thermometer resulted in a mercury spill		
200-08	04/09/08	10:27 PM	Kelley
Incident:	Fire Alarm		
Location:	Visual Arts Bldg.		
Details:	Smoke detector activated, unknown cause		
201-08	04/09/08	11:21 PM	Kelley
Incident:	Fire Alarm		
Location:	Classroom Bldg, 4 th floor, NW stairwell		
Details:	Water in smoke detector activated alarm		
202-08	04/10/08	8:29 PM	Nutt
Incident:	Fire Alarm		
Location:	Classroom bldg, 3 rd floor		
Details:	Pull box activated by unknown person		
203-08	04/11/08	2:53 AM	Nutt
Incident:	Fire Alarm		
Location:	Kamm Hall		
Details:	Use of hair dryer activated smoke detector		
204-08	04/10/08	11:45 AM	Isaacs
Incident:	Chemical Spill		
Location:	Life Sciences East		
Details:	Broken thermometer resulted in a mercury spill		
205-08	04/11/08	7:37 PM	Isaacs
Incident:	Ambulance Assist		
Location:	Allie Reynolds Stadium		
Details:	Unknown medical problem, transported to SMC		

**OSU EHS Department
Incident Summary**
For the Period 04/14/08 – 04/20/08

206-08	04/14/08	6:25 PM	Kelley
Incident:	Fire Alarm		
Location:	Kamm Hall		
Details:	Smoke from cooking activated detector		

207-08	04/17/08	8:29 PM	Kelley
Incident:	Fire Alarm		
Location:	Classroom Bldg., 3 rd floor hallway		
Details:	Unknown cause		

208-08	04/18/08	10:31 AM	Kelley
Incident:	Ambulance Assist		
Location:	Village Apartments		
Details:	Patient transported to SMC		

209-08	04/18/08	12:26 PM	Kelley
Incident:	Fire Alarm		
Location:	Construction Lab, Room 101 NW exit		
Details:	Accidental activation of pull box		

210-08	04/17/08	1:00 PM	Germain
Incident:	Fire Alarm		
Location:	Student Union, 1 st floor kitchen		
Details:	Burned food on grill activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 04/21/08 – 04/27/08

211-08	04/22/08	10:53	Kelley
Incident:	Fire Alarm		
Location:	Zink-Allen Hall		
Details:	Dust from fan blades might have blown into smoke detector		

212-08	04/21/08	10:59 PM	Spybuck
Incident:	Fire Alarm		
Location:	Noble Center, Bldg. C, Elevator Lobby		
Details:	Accidental activation of pull station by a custodian cleaning		

213-08	04/24/08	3:45 PM	Grotheer
Incident:	Chemical spill		
Location:	Biosystems Ag Engineering		
Details:	Broken mercury thermometer		

214-08	04/24/08	3:50 PM	Kelley
Incident:	Gas Leak		
Location:	McElroy Rd. between Ramsey & Hester		
Details:	Gas line broken by construction crew		

215-08	04/24/08	4:31 PM	Kelley
Incident:	Fire Alarm		
Location:	Family Resource Center		
Details:	Pull box activated by unknown person		

216-08	04/23/08	10:00 PM	Spybuck
Incident:	Fire Alarm		
Location:	Patchin-Jones Hall		
Details:	Burned food in the microwave activated smoke detector		

217-08	04/23/08	10:45 PM	Spybuck
Incident:	Fire Alarm		
Location:	Zink-Allen Hall		
Details:	Faulty smoke detector activated		

**OSU EHS Department
Incident Summary**
For the Period 04/28/08 – 05/04/08

218-08	04/30/08	6:48 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Steam from shower activated smoke detector		

219-08	04/30/08	9:02 PM	Kelley
Incident:	Ambulance Assist		
Location:	Math Science Bldg.		
Details:	Possible overdose		

220-08	05/04/08	3:30 PM	Stevenson
Incident:	Fire alarm		
Location:	Kamm Hall		
Details:	Custodian wiping dust off a smoke detector activated the detector		

223-08	05/04/08	2:30 PM	Kelley
Incident:	1 st Aid Response		
Location:	Baseball Stadium		
Details:	Patient hit in face with line drive, received lacerations		

**OSU EHS Department
Incident Summary**
For the Period 05/05/08 – 05/11/08

221-08	05/05/08	2:04 PM	Nutt
Incident:	Ambulance Assist		
Location:	Morrison Apartments		
Details:	Unknown medical emergency		
222-08	05/07/08	12:25 PM	Nutt
Incident:	Fire Alarm		
Location:	Smith Apartments		
Details:	Burned food activated smoke detector		
224-08	05/07/08	5:57 PM	Kelley
Incident:	Fire Alarm		
Location:	Young Hall		
Details:	Smoke from cooking activated detector		
225-08	05/08/08	7:26 AM	Nutt
Incident:	Fire Alarm		
Location:	Classroom Bldg.		
Details:	Dust from carpenter's sanding activated detector		
226-08	05/08/08	1:55 PM	Nutt
Incident:	Ambulance Assist		
Location:	Outside of North Murray		
Details:	Patient tripped on steps		
227-08	05/09/08	10:17 AM	Stevenson
Incident:	Fire Alarm		
Location:	Village Apartments		
Details:	Pull box activation—no fire		
228-08	05/09/08	7:10 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments		
Details:	Pull box activation—no fire		
229-08	05/10/08	3:00 PM	Kelley
Incident:	Ambulance Assist		
Location:	Baseball Stadium		
Details:	Spectator hit in face by baseball		
230-08	05/10/08	3:04 PM	Kelley
Incident:	Fire Alarm		
Location:	CITD Bldg.		
Details:	Unknown cause		
231-08	05/10/08	6:36 PM	Kelley
Incident:	Fire Alarm		
Location:	Bennett Hall East		
Details:	Dust in detector activated smoke detector		

OSU EHS Department
Incident Summary
For the Period 05/12/08 – 05/18/08

232-08	05/17/08	8:39 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C		
Details:	Steam from shower activated smoke detector		

233-08	05/17/08	2:40 PM	Nutt
Incident:	Fire Alarm		
Location:	Classroom Bldg.		
Details:	Unknown cause for activation of smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 05/19/08 – 05/25/08

234-08	05/19/08	10:00 PM	Nutt
Incident:	Odor Investigation		
Location:	Western Ave. near Career-Tech Printing		
Details:	Smoke odor; cause not found		

235-08	05/19/08	9:33 AM	Germain
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		

236-08	05/19/08	10:31 PM	Germain
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		

237-08	05/19/08	10:44 AM	Germain
Incident:	Fire		
Location:	Ag Hall, northwest loading dock		
Details:	Dumpster on fire		

238-08	05/19/08	6:30 PM	Kelley
Incident:	Injury Investigation		
Location:	Animal Science hallway near elevator and room 119		
Details:	Custodian cut finger on broken glass improperly disposed of in regular trash		

243-08	05/25/08	3:00 AM	Spybuck
Incident:	Fire Alarm		
Location:	Engineering South, 3 rd floor, west corridor		
Details:	Malfunction of smoke detector		

244-08	05/25/08	4:30 AM	Spybuck
Incident:	Fire Alarm		
Location:	Ag Biosystems Engineering East		
Details:	Malfunction of alarm system		

OSU EHS Department
Incident Summary
For the Period 05/26/08 – 06/01/08

239-08	05/27/08	10:30 PM	Isaacs
Incident:	Leak Investigation		
Location:	Noble Research Center, Rm. 142H		
Details:	Possible water leak from wall due to rain		

240-09	05/28/08	10:43 AM	Nutt
Incident:	Fire Alarm		
Location:	Patchin Jones Apartments, 3 rd floor		
Details:	Dust from construction work activated smoke detector		

241-09	05/28/08	11:35 AM	Nutt
Incident:	Fire Alarm		
Location:	Lot 74, soccer field parking lot		
Details:	Paper cargo in box truck was smoldering		

245-08	05/27/08	12:10 PM	Spybuck
Incident:	Fire Alarm		
Location:	Ag Biosystems Engineering East		
Details:	Malfunction of alarm system		

OSU EHS Department
Incident Summary
For the Period 06/16/08 – 06/22/08

261-08	06/17/08	4:00 PM	Germain
Incident:	Fire Alarm		
Location:	Morsani Apartments		
Details:	Dust from fan blades activated smoke detector		

262-08	06/17/08	10:00 PM	Nutt
Incident:	Ambulance Assist		
Location:	Village Apartments		
Details:	Assist passengers on a stuck elevator		

263-08	06/18/08	3:21 PM	Spybuck
Incident:	Fire Alarm		
Location:	Noble Research Center Fire Pump Room		
Details:	Power outage caused an activation of the fire pump		

**OSU EHS Department
Incident Summary**
For the Period 06/02/08 – 06/08/08

242-08	06/02/08	10:30 PM	Kelley
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Smoke from cooking activated smoke detector		

246-08	06/03/08	12:49 PM	Stevenson
Incident:	Ambulance Assist		
Location:	Baseball Stadium		
Details:	Patient became ill; transported to SMC		

247-08	06/05/08	7:42 PM	Kelley
Incident:	Fire Alarm		
Location:	Student Union, 4 th floor, near SE stairs		
Details:	Pull box activated by unknown person; unknown cause		

248-08	06/06/08	6:48 PM	Kelley
Incident:	Fire Alarm		
Location:	Live Animal Research Bldg.		
Details:	Steam from cage washer got into hallway and activated smoke detector		

249-08	06/06/08	8:32 PM	Kelley
Incident:	Ambulance Assist		
Location:	Peterson Apartments		
Details:	Patient transported to SMC with abdominal pains and problems breathing		

250-08	06/09/08	8:18 AM	Nutt
Incident:	Ambulance Assist		
Location:	Power Plant		
Details:	Patient transported to SMC with nausea and sweating		

**OSU EHS Department
Incident Summary**
For the Period 06/09/08 – 06/15/08

251-08	06/09/08	9:55 AM	Nutt
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Smoke from cooking activated smoke detector		
252-08	06/10/08	4:01 PM	Kelley
Incident:	Fire Alarm		
Location:	Morrison Apartments		
Details:	Smoke from cooking activated detector		
253-08	06/10/08	3:10 PM	Nutt
Incident:	Fire Alarm		
Location:	Bartlett Center		
Details:	Water leak shorted out smoke detector		
254-08	06/10/08	6:08 PM	Kelley
Incident:	Ambulance Assist		
Location:	Village Apartments, basketball courts, north side		
Details:	Patient injured knee, transported to SMC		
255-08	06/11/08	3:20 PM	Nutt
Incident:	Fire Alarm		
Location:	Allen Hall		
Details:	Dust from fan blades activated smoke detector		
256-08	06/12/08	8:56 AM	Stevenson
Incident:	Fire Alarm		
Location:	Gallagher Iba Arena		
Details:	Dust caused by employees' working activated smoke detector		
257-08	06/13/08	11:40 PM	Nutt
Incident:	Fire Alarm		
Location:	Walkway between Engineering North & South		
Details:	Suspected electrical short in lamp		
258-08	06/15/08	6:26 PM	Nutt
Incident:	Fire Alarm		
Location:	CITD Bldg. 3 rd floor		
Details:	Unknown cause for alarm		
259-08	06/15/08	7:20 PM	Nutt
Incident:	Fire Alarm		
Location:	Engineering North, 5th floor		
Details:	Possibly caused by bug in smoke detector		
260-08	06/13/08	11:00 AM	Sorenson
Incident:	Chemical Spill		
Location:	Physical Sciences, Room 303		
Details:	Possible flaw in bottle or cap resulted in bottle exploding, which caused a small chemical spill		

OSU EHS Department
Incident Summary
For the Period 06/23/08 – 06/29/08

264-08	06/24/08	5:00 PM	Kelley
Incident:	Ambulance Assist		
Location:	Student Union		
Details:	Patient became ill; transported to SMC		

265-08	06/24/08	5:21 PM	Kelley
Incident:	Fire Alarm		
Location:	McElroy Hall		
Details:	Steam from water heater activated alarm		

266-08	06/25/08	7:46 PM	Kelley
Incident:	Fire Alarm		
Location:	McElroy Hall		
Details:	Possible bad device in alarm system		

267-08	06/28/08	4:50 AM	Kelley
Incident:	Fire Alarm		
Location:	Small Grains Bldg.		
Details:	Spider and web in smoke detector		

268-08	06/28/08	1:12 PM	Kelley
Incident:	Fire Alarm		
Location:	McElroy Hall		
Details:	Possible bad detector		

**OSU EHS Department
Incident Summary**
For the Period 06/30/08 – 07/06/08

269-08	07/01/08	8:52 AM	Stevenson
Incident:	Ambulance Assist		
Location:	Fire Protection Publications Bldg.		
Details:	Patient feeling faint		

270-08	07/01/08	12:51 AM	Kelley
Incident:	Fire Alarm		
Location:	Engineering South, 1 st floor elevator lobby		
Details:	Custodian buffing floor activated smoke detector		

271-08	07/01/08	11:26 PM	Kelley
Incident:	Fire Alarm		
Location:	Young Hall		
Details:	Smoke from cooking activated smoke detector		

272-08	07/06/08	3:57 PM	Nutt
Incident:	Fire Alarm		
Location:	Village D Apartments		
Details:	Burned food activated smoke detector		

273-08	07/06/08	9:00 PM	Nutt
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Burned food activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 07/07/08 – 07/13/08

274-08	07/09/08	1:30 PM	Nutt
Incident:	Ambulance Assist		
Location:	Gallagher Iba Arena		
Details:	Participant in wrestling clinic was injured, transported to SMC		

275-08	07/09/08	7:04 PM	Kelley
Location:	Sitlington Hall		
Details:	Smoke from cooking activated detector		

276-08	07/10/08	2:00 AM	Kelley
Incident:	Fire Alarm		
Location:	McElroy Hall		
Details:	Unknown reason for activation of detector		

277-08	07/10/08	9:54 AM	Nutt
Incident:	Ambulance Assist		
Location:	Gallagher Iba Arena		
Details:	Participant in wrestling clinic was injured, transported to SMC		

278-08	07/10/08	4:02 PM	Stevenson
Incident:	Ambulance Assist		
Location:	Parking lot of Carreker Hall		
Details:	Person reported as having seizure		

279-08	07/10/08	5:55 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke from melting wax on stove activated smoke detector		

280-08	07/11/08	3:58 PM	Kelley
Incident:	Fire Alarm		
Location:	Ag Hall, South Wing Basement		
Details:	Wood chips in oven caught fire		

281-08	07/12/08	5:55 AM	Stevenson
Incident:	Fire Alarm		
Location:	Willard Hall		
Details:	Possible dirty detector activated alarm		

**OSU EHS Department
Incident Summary**
For the Period 07/14/08 – 07/20/08

282-08	07/14/08	12:35 PM	Nutt
Incident:	Fire Alarm		
Location:	Peterson Hall		
Details:	Smoke from cooking activated detector		

283-08	7-16-08	8:25 AM	Mason
Incident:	Ambulance Assist		
Location:	Math Science		
Details:	OSU employee fell down stairs		

284-08	07/14/08	12:35 PM	Nutt
Incident:	Fire Alarm		
Location:	Peterson Hall		
Details:	Smoke from burned food activated detector		

287-08	07/19/08	4:00 PM	Spybuck
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C		
Details:	Smoke from burned food activated detector		

OSU EHS Department
Incident Summary
For the Period 07/21/08 – 07/27/08

285-08	07/21/08	3:11 PM	Germain
Incident:	Fire Alarm		
Location:	Young Hall		
Details:	Possible alarm malfunction		

286-08	07/22/08	11:40 AM	Germain
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Steam from teapot left on stove activated detector		

288-08	07/24/08	2:00 PM	Kelley
Incident:	Fire Alarm		
Location:	Classroom Bldg. 1 st floor, SE exit		
Details:	Construction work got dust into detector		

OSU EHS Department
Incident Summary
For the Period 07/28/08 – 08/03/08

289-08	07/28/08	11:35 AM	Nutt
Incident:	Ambulance Assist		
Location:	Multi-Modal Transportation Construction Site		
Details:	Bricklayer fell from scaffolding		

290-08	07/30/08	11:20 AM	Nutt
Incident:	Ambulance Assist		
Location:	Gallagher-Iba Arena		
Details:	Patient fell; transported self to Stillwater Medical Center		

291-08	08/01/08	8:40 AM	Nutt
Incident:	Fire Alarm		
Location:	Career-Tech. Central Campus		
Details:	Utility worker shorted PIV wires		

292-08	08/03/08	8:28 PM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Unknown cause for detector activation		

**OSU EHS Department
Incident Summary**
For the Period 08/04/08 – 08/10/08

293-08	08/03/08	12:30 PM	Nutt
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Dust from cleaning activated smoke detector		
294-08	08/05/08	8:28 AM	Nutt
Incident:	Fire Alarm		
Location:	Gallagher-Iba Arena		
Details:	Dust from construction activated smoke detector		
295-08	08/05/08	10:02 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. F		
Details:	Steam from shower activated smoke detector		
296-08	08/05/08	4:59 PM	Kelly
Incident:	Fire Alarm		
Location:	Student Union, 4 th floor		
Details:	Pull box activated by unknown person		
297-08	08/06/08	5:12 PM	Kelly
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Smoke from cooking activated smoke detector		
298-08	08/06/08	9:55 AM	Nutt
Incident:	Gas line leak		
Location:	SW corner of Student Health Center		
Details:	Utility workers broke gas line with backhoe		
299-08	08/07/08	8:13 AM	Nutt
Incident:	Fire Alarm		
Location:	Classroom Building		
Details:	Dust from construction activated smoke detector		
300-08	08/07/08	3:50 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Resident tried to push on LED light to check detector		
301-08	08/07/08	5:00 PM	Kelley
Incident:	Broken water line		
Location:	West side of Boone Pickens stadium		
Details:	Construction crew broke sprinkler water line with backhoe		
302-08	08/09/08	7:05 PM	Kelley
Incident:	Fire Alarm		
Location:	University Apartments		
Details:	Food left on stove while resident left apartment		
303-08	08/10/08	7:23 AM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Unknown cause		

**OSU EHS Department
Incident Summary**
For the Period 08/11/08 – 08/17/08

304-08	08/11/08	4:36 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	cooking activated the detector		

305-08	08/11/08	7:27 PM and 8:20 PM	Kelley
Incident:	Ambulance Assist		
Location:	Kamm Hall		
Details:	Patient with possible allergic reaction, originally not transported but later transported		

306-08	08/12/08	11:55 AM	Sorenson
Incident:	Chemical Odor		
Location:	Physical Sciences I		
Details:	Unknown cause for slight odor		

307-08	08/13/08	1:25 PM	Grotheer
Incident:	Chemical Odor		
Location:	Physical Sciences I		
Details:	Odor possibly coming from dry drains		

308-08	08/12/08	11:14 PM	Kelley
Incident:	Fire Alarm		
Location:	Young Apartments		
Details:	Malfunctioning smoke detector		

309-08	08/14/08	4:30 PM	Kelley
Incident:	Fire Alarm		
Location:	Sitlington Apartments		
Details:	Dust in smoke detector		

OSU EHS Department
Incident Summary
For the Period 08/18/08 – 08/24/08

310-08	08/19/08	10:29 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Popcorn burned in microwave		

311-08	08/20/08	1:44 AM	Stevenson
Incident:	Fire Alarm		
Location:	Morsani Apartments		
Details:	Resident fell asleep while cooking food		

312-08	08/20/08	12:56 PM	Nutt
Incident:	Ambulance Assist		
Location:	Student Union, 2 nd floor Atrium		
Details:	Patient with unknown medical problems		

313-08	08/20/08	2:27 PM	Stevenson
Incident:	Ambulance Assist		
Location:	Parking Lot 80, south of Colvin Center		
Details:	Patient with unknown medical problems		

314-08	08/20/08	8:38 PM	Kelley
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Cooking activated smoke detector		

315-08	08/22/08	2:10 PM	Stevenson
Incident:	Ambulance Assist		
Location:	Life Science West		
Details:	Person having difficulty breathing		

316-08	08/23/08	10:10 AM	Kelley
Incident:	Acid Spill		
Location:	Intersection of McElroy & Washington		
Details:	Someone hit a jug of muriatic acid with a lawnmower		

317-08	08/23/08	12:39 PM	Kelley
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Use of incense in apartment		

OSU EHS Department
Incident Summary
For the Period 08/25/08 – 09/01/08

318-08	08/25/08	10:40 AM	Nutt
Incident:	Ambulance Assist		
Location:	Outside VMTH		
Details:	Chest pain		

319-08	08/25/08	2:30 PM	Nutt
Incident:	Ambulance Assist		
Location:	Gallagher Iba Arena area		
Details:	Possible bicycle accident		

320-08	08/25/08	5:07 PM	Kelley
Incident:	Fire Alarm		
Location:	Engineering North basement		
Details:	Elevator motor overheated		

321-08	08/26/08	1:21 PM	Nutt
Incident:	Fire Alarm		
Location:	Library		
Details:	Accidental pull box activation		

322-08	08/26/08	2:37 PM	Nutt
Incident:	Ambulance Assist		
Location:	Human Environmental Sciences		
Details:	Possible seizure; not transported		

323-08	08/25/08	10:52 PM	Kelley
Incident:	Ambulance Assist		
Location:	Zink Hall		
Details:	Difficulty breathing		

324-08	08/27/08	11:00 AM	Nutt
Incident:	Ambulance Assist		
Location:	Classroom Building		
Details:	Unknown medical problem; not transported		

325-08	08/28/08	7:40 PM	Kelley
Incident:	Fire Alarm		
Location:	Smith Hall		
Details:	Smoke from cooking activated smoke detector		

326-08	08/29/08	1:20 PM	Nutt
Incident:	Ambulance Assist		
Location:	Bus stop at intersection of Athletic and Hester		
Details:	Chest pain		

**OSU EHS Department
Incident Summary**
For the Period 09/01/08 – 09/07/08

327-08	9/01/08	7:45 PM	Spybuck
Incident:	Fire Alarm		
Location:	South Stadium, west elevators, south elevator shaft		
Details:	Water in the smoke detector activated the detector		

328-08	09/02/08	8:20 PM	Kelley
Incident:	Fire Alarm		
Location:	Brumley Apartments		
Details:	Cooking in oven caused fire in oven		

329-08	09/04/08	6:50 AM	Nutt
Incident:	Fire Alarm		
Location:	Classroom Building		
Details:	Alarm activated by dirt in smoke detector		

330-08	09/05/08	8:38 PM	Kelley
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Cooking activated smoke detector		

331-08	09/07/08	1:45 PM	Kelley
Incident:	Fire Alarm		
Location:	Patchin Hall		
Details:	Use of hair spray activated smoke detector		

340-08	09/04/08	8:40 AM	Spybuck
Incident:	Gas line break		
Location:	Construction area, east of Cordell South		
Details:	Construction employee hit a gas line with a back hoe		

**OSU EHS Department
Incident Summary**
For the Period 09/08/08 – 09/14/08

332-08	09/08/08	12:13 PM	Nutt
Incident:	Ambulance Assist		
Location:	Parking lot of Adams Market		
Details:	Bicycle accident; patient refused transport		
333-08	09/08/08	3:11 PM	Spybuck
Incident:	Fire Alarm		
Location:	Ag Hall North 157		
Details:	Construction work activated smoke detector		
334-08	09/09/08	10:26 AM	Grotheer
Incident:	Chemical Spill		
Location:	Noble Research Center		
Details:	Broken mercury thermometer		
335-08	09/10/08	5:32 PM	Kelley
Incident:	Fire Alarm		
Location:	Construction Lab, south exit		
Details:	Pull box accidentally knocked open by construction worker		
336-08	09/10/08	9:42 PM	Kelley
Incident:	Fire Alarm		
Location:	Morrison Apartments		
Details:	Resident burning incense candle activated smoke detector		
337-08	09/11/08	9:21 AM	Nutt
Incident:	Ambulance Assist		
Location:	Student Union Atrium		
Details:	Patient with facial laceration escorted on foot to Student Health Center		
338-08	09/10/08	11:43 AM	Sorenson
Incident:	Odor Investigation		
Location:	Engineering South & Engineering Annex		
Details:	Unknown cause for undefined odor		
339-08	09/11/08	6:42 PM	Kelley
Incident:	Fire Alarm		
Location:	Library, 4 th floor remodel area		
Details:	Possibly caused by construction activity		
341-08	09/13/08	6:30 PM	Spybuck
Incident:	Fire Alarm		
Location:	Library, 4 th floor center stairs		
Details:	Unknown person activated pull box		
343-08	09/12/08	5:59 PM	Kelley
Incident:	Fire Alarm		
Location:	Engineering North, 5 th floor		
Details:	Dirt in smoke detector caused activation		

**OSU EHS Department
Incident Summary**
For the Period 09/08/08 – 09/14/08

344-08	09/12/08	11:02 PM	Kelley
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Smoke from cooking activated detector		

346-08	09/14/08	7:49 PM	Spybuck
Incident:	Odor Investigation		
Location:	Willard Hall, basement library		
Details:	Burning odor from a burnt ballast in light fixture		

**OSU EHS Department
Incident Summary**
For the Period 09/15/08 – 09/21/08

342-08	09/15/08	7:01 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C & D		
Details:	Dirty smoke detector		

345-08	09/15/08	10:10 PM	Kelley
Incident:	Ambulance Assist		
Location:	Allen Hall		
Details:	Person complaining of pain		

347-08	09/16/08	11:22 AM	Stevenson
Incident:	Fire Alarm		
Location:	Life Sciences East		
Details:	Dust in detector		

348-08	09/16/08	2:55 PM	Mason
Incident:	Ambulance Assist		
Location:	Fire Service Training Grounds, West		
Details:	Person fell backwards while climbing ladder		

349-08	09/17/08	1:57 AM	Spybuck
Incident:	Fire Alarm		
Location:	Davis Hall		
Details:	Possible dirty smoke detector		

350-08	09/20/08	8:30 PM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Hair dryer activated smoke detector		

351-08	09/21/08	12:52 PM	Nutt
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Burned food activated smoke detector		

352-08	09/21/08	4:00 PM	Nutt
Incident:	Ambulance Assist		
Location:	OSU Soccer Fields		
Details:	Injured athlete		

353-08	09/21/08	10:40 PM	Nutt
Incident:	Fire Alarm		
Location:	Colvin Recreation center		
Details:	Dirty duct detector		

355-08	09/17/08	4:25 PM	Kelley
Incident:	Fire Alarm		
Location:	Kamm Hall		
Details:	Dust in smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 09/15/08 – 09/21/08

356-08	09/18/08	3:40 PM	Fox
Incident:	Chemical Spill		
Location:	Ag Hall		
Details:	Spilled neutralizing agent during neutralization of nitric acid		

361-08	09/18/08	11:25 AM	Stevenson
Incident:	Gas line break		
Location:	Multi Modal Transportation Facility; parking garage		
Details:	Construction equipment struck buried gas line		

**OSU EHS Department
Incident Summary**
For the Period 09/22/08 – 09/28/08

354-08	09/22/08	8:44 AM	Nutt
Incident:	Fire Alarm		
Location:	Bennett Hall		
Details:	Steam from shower activated smoke detector		
357-08	09/22/08	8:49 PM	Nutt
Incident:	Fire		
Location:	Parking lot south of Ag Engineering		
Details:	Dumpster fire		
358-08	09/22/08	11:20 PM	Nutt
Incident:	Fire Alarm		
Location:	Life Science East		
Details:	Custodian buffing floor set off smoke detector		
359-08	09/23/08	8:02 AM	Nutt
Incident:	Ambulance Assist		
Location:	Wes Watkins Center for International Trade Development		
Details:	Patient with labored breathing		
360-08	09/24/08	1:20 AM	Nutt
Incident:	Fire Alarm		
Location:	Stinchcomb Hall		
Details:	Malfunction in elevator control room		
362-08	09/24/08	8:16 AM	Fox
Incident:	Odor Investigation		
Location:	Wes Watkins Center for International Trade Development		
Details:	Possibly associated with carpentry work being done in building		
363-08	09/25/08	0:25 AM	Nutt
Incident:	Ambulance Assist		
Location:	Edmon Low Library		
Details:	Patient appeared to be having a seizure		
364-08	09/24/08	11:45 AM	Sorenson
Incident:	Odor Investigation		
Location:	Wes Watkins CITD		
Details:	Portable generator near outside air intake		
365-08	09/24/08	4:09 PM	Sorenson
Incident:	Odor Investigation		
Location:	Human Environmental Sciences		
Details:	Use of charcoal lighter to light grill near the building		
366-08	09/28/08	4:08 AM	Stevenson
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C		
Details:	Unknown cause for alarm		

**OSU EHS Department
Incident Summary**
For the Period 09/22/08 – 09/28/08

367-08	09/28/08	12:04 PM	Stevenson
Incident:	Fire Alarm		
Location:	Peterson Hall		
Details:	Smoke from cooking activated detectors		

368-08	09/28/08	6:30 PM	Stevenson
Incident:	Fire		
Location:	Southwest lawn area of Thatcher Hall		
Details:	Contents of smoker firebox dumped on ground and not extinguished		

**OSU EHS Department
Incident Summary**
For the Period 09/29/08 – 10/05/08

370-08	09/29/08	3:38 AM	Stevenson
Incident:	Fire Alarm		
Location:	Stinchcomb Hall		
Details:	Dirty smoke detector		
371-08	09/30/08	4:52 PM	Stevenson
Incident:	Fire Alarm		
Location:	SPW Cafeteria		
Details:	Water from a leak coming out of smoke detector		
372-08	09/30/08	12:02 PM	Stevenson
Incident:	Fire Alarm		
Location:	Classroom Building		
Details:	Alarm activated by dirt in smoke detector		
373-08	10/01/08	10:54 AM	Nutt
Incident:	Fire Alarm		
Location:	Peterson Hall		
Details:	Air freshener accidentally sprayed directly into smoke detector		
374-08	09/30/08	10:32 PM	Kelley
Incident:	Fire Alarm		
Location:	Allen Hall		
Details:	Steam from hot water faucet leak got into detector		
375-08	10/02/08	9:08 AM	Nutt
Incident:	Fire Alarm		
Location:	4-H Youth Development Bldg.		
Details:	Burned food in oven spread smoke throughout 2 nd floor		
376-08	09/30/08	10:30 AM	Grotheer
Incident:	Odor Investigation		
Location:	Engineering North		
Details:	Upon investigation, odor had dissipated		
377-08	10/01/08	2:40 PM	Grotheer
Incident:	Leak Investigation		
Location:	Seretean Center for Performing Arts		
Details:	Leaking hydrogen peroxide injector valve		
378-08	10/02/08	8:16 AM	Fox
Incident:	Leak Investigation		
Location:	Life Science East		
Details:	Defrosting freezer in room 310 allowed water to leak into room 206		
379-08	10/02/08	2:19 PM	Grotheer
Incident:	Gas odor		
Location:	Outside University Apartments Bldg. S73		
Details:	Minimal amount of gas leaking from a supply pipe		

**OSU EHS Department
Incident Summary**
For the Period 09/29/08 – 10/05/08

380-08	10/02/08		Nutt
Incident:	Ambulance Assist		
Location:	Vet Med Teaching Hospital Small Animal Clinic		
Details:	Patient with personal medical conditions		

381-08	10/02/08		Fox
Incident:	Chemical Investigation		
Location:	Stout Hall		
Details:	Removed unauthorized chemicals for proper disposal		

382-08	10/02/08	5:32 PM	Kelley
Incident:	Grass Fire		
Location:	Vet Med Ranch, west of Stillwater		
Details:	Small controlled burn was left unattended		

383-08	10/02/08	7:06 PM	Kelley
Incident:	Fire Alarm		
Location:	Patchin Hall		
Details:	Burned microwave popcorn activated detector		

384-08	10/05/08	10:27 AM	Kelley
Incident:	Fire Alarm		
Location:	EFAW Research		
Details:	Dirt in smoke detector activated detector		

385-08	10/03/08	2:57 PM	Nutt
Incident:	Ambulance Assist		
Location:	Village Apartments E/F Courtyard		
Details:	Patient hit lamp post while playing frisbee		

**OSU EHS Department
Incident Summary**
For the Period 10/06/08 – 10/12/08

386-08	10/06/08	10:12 AM	Nutt
Incident:	Fire alarm		
Location:	Allen Hall		
Details:	Dirty smoke detector		
387-08	10/06/08	4:01 PM	Kelley
Incident:	Fire Alarm		
Location:	Booker Hall		
Details:	Dust in smoke detector		
388-08	10/06/08	6:31 PM	Kelley
Incident:	Ambulance Assist		
Location:	Parking Lot #4, near Gallagher-Iba Arena		
Details:	Patient having difficulty breathing		
389-08	10/07/08	8:35 AM	Nutt
Incident:	Ambulance Assist		
Location:	Business Building		
Details:	Unknown illness		
390-08	10/07/08	8:32 AM	Spybuck
Incident:	Fire Alarm		
Location:	Jones Suites		
Details:	Hair dryer activated smoke detector		
391-08	10/07/08	10:45 AM	Spybuck
Incident:	Fire Alarm		
Location:	Noble Research Center, D Wing		
Details:	Use of cotton candy machine activated smoke detectors		
392-08	10/07/08	1:50 PM	Nutt
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Burned food activated smoke detector		
393-08	10/07/08	2:10 AM	Kelley
Incident:	Fire Alarm		
Location:	Allen Hall		
Details:	Smoke from cooking activated detector		
394-08	10/07/08	5:19 PM	Kelley
Incident:	Fire Alarm		
Location:	Boone Pickens Stadium		
Details:	Pull box activated by unknown person		
395-08	10/08/08	10:58 AM	Nutt
Incident:	Ambulance Assist		
Location:	Noble Research Center		
Details:	Patient with medical problems		

**OSU EHS Department
Incident Summary**
For the Period 10/06/08 – 10/12/08

396-08	10/09/08	12:49 AM	Kelley
Incident:	Fire Alarm		
Location:	Patchin Suites		
Details:	Burned popcorn activated smoke detector		

397-08	10/09/08	3:54 AM	Kelley
Incident:	Fire Alarm		
Location:	McElroy Hall		
Details:	Dust in smoke detector caused activation		

398-08	10/09/08	8:35 AM	Nutt
Incident:	Ambulance Assist		
Location:	Classroom Building		
Details:	Patient collapsed at podium		

399-08	10/09/08	8:38 AM	Nutt
Incident:	Ambulance Assist		
Location:	Classroom Building		
Details:	Patient with unknown medical problems		

400-08	10/10/08	11:45 AM	Nutt
Incident:	Ambulance Assist		
Location:	Student Union Bookstore		
Details:	Patient experiencing chest pains		

**OSU EHS Department
Incident Summary**
For the Period 10/13/08 – 10/19/08

401-08	10/14/08	10:40 AM	Isaacs
Incident:	Gas Leak		
Location:	Life Science East		
Details:	Flair nut on gas cock needed to be tightened		

402-08	10/14/08	11:45 AM	Nutt
Incident:	Fire Alarm		
Location:	Peterson Hall		
Details:	Smoke from cooking activated detector		

403-08	10/16/08	1:57 PM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Smoke from cooking in lounge activated detector		

404-08	10/15/08	2:45 PM	Stevenson
Incident:	Fire Alarm		
Location:	Hazardous Reaction Lab		
Details:	Chemical reaction created steam in the fume hood, which activated detector		

405-08	10/15/08	6:47 PM	Kelley
Incident:	Fire Alarm		
Location:	Patchin Suites		
Details:	Smoke from cooking activated detector		

406-08	10/16/08	10:23 PM	Kelley
Incident:	Fire Alarm		
Location:	Sitlington Hall		
Details:	Cardboard carton left on stove, burner turned on catching carton on fire		

407-08	10/18/08	2:29 PM	Nutt
Incident:	Ambulance Assist		
Location:	North of Ag Hall		
Details:	Patient having a seizure		

408-08	10/18/08	4:45 PM	Nutt
Incident:	Ambulance Assist		
Location:	Parking Lot east of ATRC		
Details:	Patient fell		

**OSU EHS Department
Incident Summary**
For the Period 10/20/08 – 10/26/08

413-08	10/20/08	9:31 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Burned microwave popcorn activated detector		

414-08	10/21/08	2:45 PM	Isaacs
Incident:	Leaking Package		
Location:	University Mailing Services		
Details:	Water on outside of package; no chemicals		

415-08	10/21/08	3:42 PM	Isaacs
Incident:	Gas Odor		
Location:	Physical Plant Wash Bay area		
Details:	Vendor had recently filled gas storage tank or possible sewer gas odor		

417-08	10/23/08	9:26 AM	Nutt
Incident:	Gas line break		
Location:	Courtyard area between Whitehurst and Library		
Details:	Construction crew cut a gas line		

418-08	10/21/08	8:12 PM	Kelley
Incident:	Fire Alarm		
Location:	McElroy Hall		
Details:	Unknown cause for alarm		

419-08	10/21/08	8:45 PM	Kelley
Incident:	Fire Alarm		
Location:	Monroe Street Parking garage, 2 nd level		
Details:	Dust in smoke detector activated alarm		

420-08	10/23/08	8:11 PM	Kelley
Incident:	Fire Alarm		
Location:	Allen Hall		
Details:	Burned food in microwave activated detector		

421-08	10/22/08	9:27 PM	Kelley
Incident:	Ambulance Assist		
Location:	Patchin Suites		
Details:	Patient became ill		

422-08	10/24/08	8:30 PM	Kelley
Incident:	Fire Alarm		
Location:	University Apartments		
Details:	Smoke from cooking activated detector		

423-08	10/24/08	8:53 PM	Kelley
Incident:	Fire Alarm		
Location:	West Bennett		
Details:	Burned food in microwave activated detector		

**OSU EHS Department
Incident Summary**
For the Period 10/20/08 – 10/26/08

424-08	10/24/08	10:50 PM	Kelley
Incident:	Hazardous spill		
Location:	Food & Ag Products Center, 1 st floor west mechanical room		
Details:	Radiator hose leaked antifreeze from emergency generator		

425-08	10/25/08	7:20 PM	Nutt
Incident:	Fire Alarm		
Location:	Kerr Hall		
Details:	Suspected water surge in sprinkler line		

**OSU EHS Department
Incident Summary**
For the Period 10/27/08 – 11/02/08

426-08	10/27/08	12:40 AM	Nutt
Incident:	Fire Alarm		
Location:	Kamm Hall		
Details:	Smoke from burned food activated detector		

427-08	10/27/08	5:48 PM	Kelley
Incident:	Ambulance Assist		
Location:	Young Hall		
Details:	Patient with back pain		

428-08	10/28/08	2:55 PM	Fox
Incident:	Gas Odor		
Location:	Community Center, Brumley Apts.		
Details:	Stove not properly turned off		

429-08	10/28/08	4:45 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. A		
Details:	Pull box activated by unknown person; no fire		

430-08	10/28/08	10:01 PM	Kelley
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Smoke from cooking activated detector		

431-08	10/30/08	11:34 AM	Nutt
Incident:	Ambulance Assist		
Location:	Alumni Building		
Details:	Unknown medical emergency; transported patient to Stillwater Medical Center		

432-08	10/27/08	5:48 PM	Kelley
Incident:	Ambulance Assist		
Location:	Young Hall		
Details:	Patient with back pain transported to Stillwater Medical Center		

433-08	10/31/08	4:41 PM	Kelley
Incident:	Fire Alarm		
Location:	McElroy Hall		
Details:	unknown cause		

434-08	11/02/08	6:55 PM	Stevenson
Incident:	Fire Alarm		
Location:	Payne Ellis Apartments		
Details:	Broken sprinkler head		

**OSU EHS Department
Incident Summary**
For the Period 11/03/08 – 11/09/08

435-08	11/03/08	2:05 AM	Stevenson
Incident:	Fire Alarm		
Location:	Engineering South		
Details:	Bug in smoke detector activated detector		

436-08	11/03/08	9:12 AM	Nutt
Incident:	Ambulance Assist		
Location:	Student Union Food Court		
Details:	Unknown medical problem		

437-08	11/03/08	9:13 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Smoke from cooking activated fire alarm		

438-08	11/04/08	11:43 AM	Fox
Incident:	Unknown substance		
Location:	Gallagher Iba Arena		
Details:	Unknown powdery substance on restroom floor		

439-08	11/05/08	1:38 PM	Nutt
Incident:	Ambulance Assist		
Location:	Student Union Atrium		
Details:	Unknown medical problem		

440-08	11/06/08	8:35 AM	Fox
Incident:	Odor Investigation		
Location:	Physical Science I		
Details:	Moisture from window drains suspected to be causing odor		

441-08	11/06/08	9:29 AM	Nutt
Incident:	Fire Alarm		
Location:	Cordell Hall, Center		
Details:	Unknown water flowage		

**OSU EHS Department
Incident Summary**
For the Period 11/10/08 – 11/16/08

442-08	11/10/08	8:12 AM	Nutt
Incident:	Fire Alarm		
Location:	ATRC 4 th floor		
Details:	Suspected water flow in sprinkler system		
443-08	11/10/08	9:34 AM	Nutt
Incident:	Ambulance Assist		
Location:	Wentz Hall		
Details:	Unknown medical problem		
444-08	11/10/08	12:49 PM	Nutt
Incident:	Ambulance Assist		
Location:	Student Union		
Details:	Unknown medical problem		
445-08	11/11/08	1:00 PM	Sorenson
Incident:	Odor Investigation		
Location:	Physical Sciences I		
Details:	Odor similar to paint solvent reported		
446-08	11/12/08	12:44 PM	Nutt
Incident:	Ambulance Assist		
Location:	Gundersen Hall		
Details:	Unknown medical problem		
447-08	11/12/08	2:53 PM	Isaacs
Incident:	Odor reported		
Location:	Physical Science I		
Details:	No odor detected, no odor readings on monitor		
448-08	11/12/08	10:54 AM	Nutt
Incident:	Fire Alarm		
Location:	Student Union Services Center		
Details:	Ceiling tile moved; possibly allowed dust to enter detector		
449-08	11/13/08	6:30 Am	Nutt
Incident:	Fire Alarm		
Location:	Cohn Animal Shelter		
Details:	Panel not in alarm upon arrival		
450-08	11/13/08	1:20 PM	Nutt
Incident:	Ambulance Assist		
Location:	Classroom Building		
Details:	Unknown medical problem		
451-08	11/11/08	3:50 PM	Stevenson
Incident:	Fire Alarm		
Location:	Willard Hall		
Details:	Burned popcorn in microwave activated detector		

**OSU EHS Department
Incident Summary**
For the Period 11/10/08 – 11/16/08

452-08	11/11/08	5:06 PM	Stevenson
Incident:	Fire Alarm		
Location:	Family Resource Center		
Details:	Pull box activated possibly by a child		

453-08	11/12/08	5:03 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke from cooking activated detector		

454-08	11/12/08	6:46 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Smoke from cooking activated detector		

455-08	11/13/08	1:05 PM	Stevenson
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke from burned food activated detector		

456-08	11/13/08	4:36 PM	Kelley
Incident:	Fire Alarm		
Location:	Career Tech Print, South entrance		
Details:	Problem with phone lines activated fire alarm		

457-08	11/13/08	7:04 PM	Kelley
Incident:	Fire Alarm		
Location:	Kamm Apartments		
Details:	Resident using hair dryer under detector		

**OSU EHS Department
Incident Summary**
For the Period 11/17/08 – 11/23/08

462-08	11/18/08	12:02 PM	Nutt
Incident:	Fire Alarm		
Location:	Smith Hall		
Details:	Dirty smoke detector		

463-08	11/17/08	11:52 PM	Kelley
Incident:	Fire Alarm		
Location:	Multi-Modal Transportation Center		
Details:	Dust in detector		

464-08	11/18/08	1:20 AM	Kelley
Incident:	Fire Alarm		
Location:	Multi-Modal Transportation Center		
Details:	Dust in AHU #5 duct detector		

465-08	11/18/08	5:33 AM	Kelley
Incident:	Fire Alarm		
Location:	Smith Hall		
Details:	Dirty smoke detector		

466-08	11/18/08	8:55 PM	Stevenson
Incident:	Ambulance Assist		
Location:	Gallagher-Iba Arena		
Details:	Patient with unknown medical problems, no transport		

467-08	11/19/08	2:36 PM	Nutt
Incident:	Fire Alarm		
Location:	Noble Research Center		
Details:	Welding in basement activated detector		

OSU EHS Department
Incident Summary
For the Period 11/24/08 – 11/30/08

468-08	11/24/08	12:45 PM	Nutt
Incident:	Fire Alarm		
Location:	Peterson Hall		
Details:	Smoke from cooking activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 12/01/08 – 12/07/08

469-08	12/01/08	3:54 PM	Kelley
Incident:	Fire Alarm		
Location:	Willard Hall 1 st floor		
Details:	Dust in duct detector		

470-08	12/04/08	8:07 AM	Nutt
Incident:	Fire Alarm		
Location:	Zink Hall		
Details:	Possible dirt or malfunctioning detector (replacing)		

471-08	12/04/08	9:55 AM	Nutt
Incident:	Ambulance Assist		
Location:	Math Science		
Details:	Unknown medical problem, transported to SMC		

472-08	12/05/08	1:48 PM	Nutt
Incident:	Ambulance Assist		
Location:	Outside west entrance of Monroe St. Garage		
Details:	Unknown medical problem, transported to SMC		

473-08	12/05/08	7:45 PM	Kelley
Incident:	Fire Alarm		
Location:	Jones Hall		
Details:	Resident using hair dryer activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 12/08/08 – 12/14/08

474-08	12/09/08	7:56 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. F		
Details:	smoke from cooking activated detector		

475-08	12/10/08	1:10 PM	Sorenson
Incident:	Odor Investigation		
Location:	North Murray		
Details:	Odor not detected by investigating party		

476-08	12/10/08	4:13 PM	Kelley
Incident:	Gas line break		
Location:	West side of OADDL, outside		
Details:	Contractors hit gas line while digging with backhoe		

477-08	12/12/08	9:53 PM	Kelley
Incident:	Ambulance Assist		
Location:	Lot 2A, between Bennett West and Blair Dining		
Details:	Patient complaining of chest pain		

**OSU EHS Department
Incident Summary**
For the Period 12/15/08 – 12/21/08

478-08	12/16/08	10:52 AM	Kelley
Incident:	Fire Alarm		
Location:	Young Hall		
Details:	Dirt in smoke detector caused activation of alarm		

479-08	12/17/08	7:35 PM	Kelley
Incident:	Fire Alarm		
Location:	Engineering North 3 rd floor, hallway		
Details:	Custodians using buffer activated smoke detector		

480-08	12/19/08	9:29 PM	Kelley
Incident:	Fire Alarm		
Location:	Multi-Modal garage, level 4		
Details:	Dust in smoke detector caused activation of alarm		

486-08	12/17/08	11:00 PM	Kelley
Incident:	Fire Alarm		
Location:	Multi-Modal Parking Garage		
Details:	Ice expanded and cracked standpipe valve, causing activation of alarm		

487-08	12/18/08	7:00 AM	Nutt
Incident:	Fire Alarm		
Location:	Boone Pickens Stadium, North and West		
Details:	Sprinkler head froze, broke and caused the dry pipe system to activate, flooding Cowboy Authentic Wear		

**OSU EHS Department
Incident Summary**
For the Period 12/22/08 – 12/28/08

481-08	12/22/08	8:30 AM	Kelley
Incident:	Ambulance Assist		
Location:	University Apartments		
Details:	Patient feeling dizzy, having chest pain		

482-08	12/22/08	11:38 AM	Isaacs
Incident:	Odor Investigation		
Location:	Human Environmental Science		
Details:	Odor caused by cooking in an office		

483-08	12/28/08	9:30 AM	Kelley
Incident:	Fire Alarm		
Location:	Engineering South, 1 st floor Mechanical Room		
Details:	AHU motor overheated causing smoke and burning odor		

485-08	12/22/08	5:54 AM	Stevenson
Incident:	Fire Alarm		
Location:	Engineering South		
Details:	Malfunctioning smoke detector		

OSU EHS Department
Incident Summary
For the Period 12/29/08 – 1/04/09

484-08	12/31/08	8:31 PM	Kelley
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Resident using hair dryer activated smoke detector		
