

**OSU EHS Department
Incident Summary**
For the Period 01/12/09 – 01/18/09

007-09	01/12/09	12:01 AM	Nutt
Incident:	Fire		
Location:	Swine Research		
Details:	Dumpster fire; unknown cause of ignition		

008-09	01/12/09	1:03 PM	Sorenson
Incident:	Odor Investigation		
Location:	Stevens Apartments		
Details:	Leaky gas valve on natural gas line inside apartment		

009-09	01/13/09	8:49 AM	Nutt
Incident:	Ambulance Assist		
Location:	Engineering North		
Details:	Patient with unknown medical issue; refused transport		

010-09	01/14/09	8:13 AM	Nutt
Incident:	Ambulance Assist		
Location:	Lot 35 and Monroe Street		
Details:	Patient fell from bicycle and struck head on pavement		

011-09	01/14/09	3:45 PM	Stevenson
Incident:	Fire Alarm		
Location:	Kamm Hall		
Details:	Smoke detector activated by dust from construction activity		

012-09	01/14/09	4:52 PM	Kelley
Incident:	Fire Alarm		
Location:	Patchin Suites		
Details:	Smoke detector activated by smoke from food burned in microwave		

013-09	01/15/09	11:58 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments		
Details:	Use of hair dryer activated smoke detector		

014-09	01/15/09	11:50 PM	Nutt
Incident:	Fire Alarm		
Location:	Zink Hall		
Details:	Pull box activation by unknown person		

015-09	01/15/09	9:36 PM	Kelley
Incident:	Fire Alarm		
Location:	Engineering North		
Details:	Faulty smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 01/12/09 – 01/18/09

016-09	01/16/09	3:30 AM	Nutt
Incident:	Fire Alarm		
Location:	Engineering North		
Details:	Smoke detector activation; possible cause is dirt in the detector		

017-09	01/16/09	9:34 AM	Nutt
Incident:	Ambulance Assist		
Location:	Morrill Hall		
Details:	Unknown medical incident		

018-09	01/16/09	4:02 PM	Kelley
Incident:	Fire Alarm		
Location:	Boone Pickens Stadium		
Details:	Sprinkler head broke due to freezing conditions		

019-09	01/17/09	12:28 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke detector activated by cooking		

020-09	01/17/09	6:31 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Smoke detectors activated by steam from shower		

021-09	01/18/09	3:43 AM	Kelley
Incident:	Fire Alarm		
Location:	Smith Apartments		
Details:	Unknown reason for alarm		
