

**OSU EHS Department
Incident Summary**
For the Period 01/05/09 – 01/11/09

001-09	01/05/09	12:10 PM	Isaacs
Incident:	Odor Investigation		
Location:	PIO Bldg. 1 st floor		
Details:	Possible dry drain next to air handler causing odor		

002-09	01/06/09	9:20 AM	Nutt
Incident:	Ambulance Assist		
Location:	Intersection of Knoblock and Athletic Ave.		
Details:	Unknown medical problems		

003-09	01/06/09	11:30 AM	Isaacs
Incident:	Odor Investigation		
Location:	Cordell North, Northwest basement		
Details:	Odor of natural gas reported, but odor had dissipated and no cause found		

004-09	01/07/09	11:10 AM	Fox
Incident:	Odor Investigation		
Location:	Animal Science Arena		
Details:	An odor reported after boiler start-up; no leaks indicated by gas monitor		

005-09	01/07/09	1:10 pm	Isaacs
Incident:	Odor Investigation		
Location:	Bennett Hall, center basement		
Details:	Construction work created dust that entered building; hot work permit had been issued and protective sheeting was in place		

006-09	01/08/09	8:58 AM	Isaacs
Incident:	Odor Investigation		
Location:	Advanced Technology Research Center, North side		
Details:	Odor of natural gas reported, leak discovered and fixed		
