

**OSU EHS Department
Incident Summary**
For the Period 02/02/09 – 02/08/09

036-09	02/02/09	2:57 AM	Stevenson
Incident:	Odor Investigation		
Location:	Advanced Technology Research Center		
Details:	Malfunctioning air handler motor		

037-09	02/02/09	9:00 AM	Grotheer, L.
Incident:	Gas Odor		
Location:	Cordell South		
Details:	Dry sink drain caused odor		

038-09	02/02/09	10:25 AM	Grotheer, L.
Incident:	Gas Odor		
Location:	Willard Hall		
Details:	Various dry sink drains		

039-09	02/03/09	10:29 AM	Nutt
Incident:	Ambulance Assist		
Location:	Student Health Services		
Details:	Patient with chest pains, transported to Stillwater Medical Center		

040-09	02/03/09	12:25 PM	Nutt
Incident:	Ambulance Assist		
Location:	Visual Arts Annex		
Details:	Patient injured with chisel tool		

041-09	02/03/09	7:47 PM	Kelley
Incident:	Fire Alarm		
Location:	Engineering North		
Details:	Faulty smoke detector		

042-09	02/04/09	12:50 PM	Stevenson
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Smoke from cooking activated detector		

043-09	02/05/09	00:04 AM	Stevenson
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Smoke from cooking activated detector		

044-09	02/05/09	2:14 AM	Stevenson
Incident:	Fire Alarm		
Location:	Patchin Suites		
Details:	Smoke from burned food activated detector		

**OSU EHS Department
Incident Summary**
For the Period 02/02/09 – 02/08/09

045-09	02/05/09	8:48 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. A		
Details:	Steam from shower activated detector		

046-09	02/06/09	4:57 PM	Kelley
Incident:	Fire Alarm		
Location:	Multi Modal Parking Garage; rooftop AHU		
Details:	Activation of smoke detector caused by dust or faulty detector		

047-09	02/06/09	9:42 PM	Kelley
Incident:	Fire Alarm		
Location:	Smith Apartments		
Details:	Dust in smoke detector		

048-09	02/08/09	4:58 PM	Kelley
Incident:	Fire Alarm		
Location:	Morrison Apartments		
Details:	Resident burning incense activated smoke detector		

049-09	02/08/09	5:35 PM	Kelley
Incident:	Gas Odor		
Location:	Student Union, 3 rd floor		
Details:	Possibly caused by dry floor drains		
