

**OSU EHS Department
Incident Summary**
For the Period 03/09/09 – 03/15/09

063-09	03/09/09	2:40 AM	Nutt
Incident:	Fire alarm		
Location:	Village Apartments, Bldg. F		
Details:	Steam from shower activated smoke detector		

064-09	03/09/09	3:18 PM	Nutt
Incident:	Ambulance assist		
Location:	Noble Research Center		
Details:	Patient with chest and back pain, transported to SMC		

065-09	03/10/09	3:18 PM	Nutt
Incident:	Ambulance assist		
Location:	North Classroom Bldg., lobby		
Details:	Patient lying on floor, unknown cause, transported to SMC		

066-09	03/12/09	11:40 PM	Nutt
Incident:	Fire Alarm		
Location:	Morsani Hall		
Details:	Burned food activated smoke detector		

067-09	03/13/09	2:06 PM	Sorenson
Incident:	Gas Odor		
Location:	Ag Hall East, 041		
Details:	Hose coming from a natural gas outlet was cracked and in poor condition		
