

**OSU EHS Department  
Incident Summary**  
For the Period 04/13/09 – 04/19/09

---

098-09	04/13/09	1:11 AM	Spybuck
Incident:	Fire Alarm		
Location:	Jones Hall		
Details:	Use of hairspray activated smoke detector		

---

099-09	04/13/09	7:08 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. A		
Details:	Steam from shower activated smoke detector		

---

100-09	04/14/09	10:32 AM	Spybuck
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		

---

101-09	04/15/09	3:31 PM	Stevenson
Incident:	Ambulance Assist		
Location:	Bennett Hall, south side, on sidewalk		
Details:	Patient with possible allergic reaction		

---

102-09	04/15/09	9:10 PM	Kelley
Incident:	Fire Alarm		
Location:	Student Union, 2 <sup>nd</sup> floor south hallway near restrooms		
Details:	Custodian dusted smoke detector with a feather duster		

---

103-09	04/15/09	10:18 PM	Kelley
Incident:	Ambulance Assist		
Location:	Ag Hall, north wing, west lobby		
Details:	Patient with ankle injury		

---

104-09	04/16/09	8:32 AM	Isaacs
Incident:	Chemical spill		
Location:	Colvin Center		
Details:	Mercury thermometer dropped and broken		

---

105-09	04/16/09	10:34 AM	Isaacs
Incident:	Gas Odor		
Location:	Williams Housing, Bldg. 14		
Details:	Odor caused by leak in gas line		

---

106-09	04/16/09	8:03 PM	Kelley
Incident:	Fire		
Location:	Under a vacant house at the corner of Washington and McElroy		
Details:	Possibly slag igniting combustibles from welding done earlier in the day		

---

**OSU EHS Department  
Incident Summary**  
For the Period 04/13/09 – 04/19/09

---

107-09	04/17/09	5:30 AM	Spybuck
Incident:	Gas Odor/Leak		
Location:	Kerr Hall 1 <sup>st</sup> floor laundry room		
Details:	Possible Vandalism; dryer had been moved, gas line broken		

---

108-09	04/18/09	8:16 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Burned food in microwave activated smoke detector		

---

109-09	04/19/09	1:06 AM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. C		
Details:	Steam from shower activated smoke detector		

---