

**OSU EHS Department
Incident Summary**
For the Period 04/06/09 – 04/12/09

094-09	04/07/09	8:20 AM	Spybuck
Incident:	Fire Alarm		
Location:	Patchin Hall		
Details:	Use of hair dryer activated smoke detector		

095-09	04/08/09	8:10 AM	Isaacs
Incident:	Sewer Odor		
Location:	Student Union		
Details:	Unknown cause; odor had dissipated before arrival of EHS		

096-09	04/08/09	8:40 AM	Mason
Incident:	Medical Alarm		
Location:	OADDL		
Details:	Technicians working on alarm system set off alarms		

097-09	04/10/09	6:51 PM	Kelley
Incident:	Fire Alarm		
Location:	Morrison Apartments		
Details:	Smoke from cooking activated detector		
