

**OSU EHS Department
Incident Summary**
For the Period 05/18/09 – 05/24/09

146-09	05/19/09	8:19 AM	Fox
Incident:	Gas Odor		
Location:	Oklahoma Agriculture Experiment Station (Stillwater)		
Details:	Slight natural gas odor detected midway in greenhouse, possibly a hole in gas line diaphragm		

147-09	05/19/09	10:17 AM	Nutt
Incident:	Fire Alarm		
Location:	Life Sciences West		
Details:	Dust from HVAC work activated smoke detectors		

148-09	05/19/09	11:48 AM	Fox
Incident:	Odor Investigation		
Location:	Area east of Business Bldg. & Morrill Hall		
Details:	Unknown odor tracked and found to be originating off campus; OG&E notified		

149-09	05/21/09	3:33 AM	Kelley
Incident:	Math Sciences		
Location:	Fire Alarm		
Details:	Possible water surge in sprinkler line		

150-09	05/21/09	8:33 PM	Kelley
Incident:	Sitlington Hall		
Location:	Fire Alarm		
Details:	Smoke from cooking activated detector		

151-09	05/22/09	approx 9:45 PM	Stevenson
Incident:	Fall		
Location:	Gallagher Iba Arena, escalators		
Details:	A man fell backwards into a woman on the escalators, scraping her leg		
