

**OSU EHS Department
Incident Summary**
For the Period 05/25/09 – 05/31/09

152-09	05/25/09	8:30 AM	Spybuck
Incident:	Fire Alarm		
Location:	Math Sciences, Basement Mech Room		
Details:	Water surge in sprinkler line		

153-09	05/26/09	3:30 AM	Spybuck
Incident:	Fire Alarm		
Location:	Math Sciences, Basement Mech Room		
Details:	Water surge in sprinkler line		

154-09	05/26/09	10:57 AM	Nutt
Incident:	Fire Alarm		
Location:	Boone Pickens South Stadium		
Details:	Smoke detector in elevator mechanical room activated, unknown cause		

155-09	05/27/09	8:00 AM	Stevenson
Incident:	Ambulance Assist		
Location:	Physical Plant Bldg, north hallway		
Details:	Employee with medical problems; transported to SMC		

156-09	05/27/09	8:18 AM	Nutt
Incident:	Fire Alarm		
Location:	McElroy Hall, 2nd floor		
Details:	Possibly an insect in the smoke detector caused alarm activation		

157-09	05/27/09	8:18 AM	Spybuck
Incident:	Ambulance Assist		
Location:	Swine Research Facility, near water tower project		
Details:	Employee of outside contractor fell from scaffolding; transported to SMC		

158-09	05/27/09	2:00 PM	Sorenson
Incident:	Gas Odor Investigation		
Location:	Physical Science II, 4 th and 5 th floors		
Details:	Odor had dissipated before arrival, no odor detected with gas monitor, water poured down drains		

159-09	05/31/09	9:15 PM	Spybuck
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E, 4 th floor lobby		
Details:	Elevator controller inverter circuit burned up		
