

**OSU EHS Department  
Incident Summary**  
For the Period 05/04/09 – 05/10/09

---

132-09	05/04/09	1:20 PM	Isaacs
Incident:	Gas line leak		
Location:	University Housing, bldg. 41		
Details:	Nipple on gas line to stove was leaking		

---

133-09	05/05/09	7:45 AM	Nutt
Incident:	Ambulance Assist		
Location:	New Science & Tech Bldg. construction site		
Details:	Worker fell on piece of plastic conduit; transported to SMC		

---

134-09	05/06/09	1:31 AM	Spybuck
Incident:	Fire Alarm		
Location:	Allen Hall, 2 <sup>nd</sup> floor, east stairwell		
Details:	activation of pull box, possibly malicious act		

---

135-09	05/06/09	3:00 AM	Spybuck
Incident:	Fire Alarm		
Location:	Davis Hall		
Details:	Smoke from cooking activated smoke detector		

---

136-09	05/06/09	12:10 PM	Nutt
Incident:	Ambulance Assist		
Location:	Physical Sciences		
Details:	Unknown medical problem		

---

137-09	05/06/09	1:30 PM	Nutt
Incident:	Ambulance Assist		
Location:	Student Health Services		
Details:	Student transported to Stillwater Medical Center		

---

138-09	05/08/09	11:35 AM	Nutt
Incident:	Fire Alarm		
Location:	Animal Science Bldg.		
Details:	Steam in mechanical room activated smoke detector		

---

139-09	05/08/09	2:42 PM	Spybuck
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Dust from vacuum bag activated smoke detector		

---

140-09	05/08/09	11:15 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Steam from shower activated smoke detector		

---