

**OSU EHS Department
Incident Summary**
For the Period 06/15/09 – 06/21/09

173-09	06/16/09	6:30 PM	Kelley
Incident:	Fire Alarm		
Location:	Sitlington Hall		
Details:	Smoke from cooking activated detector		

174-09	06/16/09	10:13 PM	Kelley
Incident:	Fire Alarm		
Location:	Hazardous Reaction Lab		
Details:	Experiment with rocks in acid created fumes that activated smoke detector		

175-09	06/17/09	2:25 PM	Isaacs
Incident:	Odor Investigation		
Location:	Morrill Hall		
Details:	Asbestos Crew had been using mastic remover, which created an odor		

176-09	06/17/09	10:20 AM	Stevenson
Incident:	Ambulance Assist		
Location:	Engineering North		
Details:	Person passed out in hallway, transported to SMC		

177-09	06/18/09	9:25 AM	Nutt
Incident:	Ambulance Assist		
Location:	University Housing, Demaree Apartments		
Details:	Unknown medical problem, no transport		

178-09	06/18/09	11:50 AM	Nutt
Incident:	Fire Alarm		
Location:	Engineering South		
Details:	Dust from construction set off smoke detector		

179-09	06/17/09	10:58 AM	Stevenson
Incident:	Ambulance Assist		
Location:	Classroom Bldg.		
Details:	Unknown medical problem, no transport		

180-09	06/17/09	4:02 PM	Kelley
Incident:	Smoke Investigation		
Location:	Library, west of the south entrance in flower bed		
Details:	Wood chips in flower bed were smoldering		

181-09	06/19/09	10:21 AM	Stevenson
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Use of hair spray activated smoke detector		

**OSU EHS Department
Incident Summary**
For the Period 06/15/09 – 06/21/09

182-09	06/19/09	2:21 PM	Stevenson
Incident:	Ambulance Assist		
Location:	Parking lot north of Wes Watkins CITD		
Details:	Unknown medical problem, possibly heat-related, refused transport		

183-09	06/21/09	3:14 PM	Stevenson
Incident:	Fire Alarm		
Location:	Gallagher Iba Arena		
Details:	Basketball player ran into pull box, breaking it		
