

**OSU EHS Department
Incident Summary**
For the Period 06/29/09 – 07/05/09

185-09	06/29/09	11:07 AM	Nutt
Incident:	Fire Alarm		
Location:	Boone Pickens Stadium		
Details:	Faulty water flow switch, to be repaired by 06/30/09 by contractor		

186-09	07/01/09	8:59 AM	Kelley
Incident:	Fire Alarm		
Location:	University Apartments		
Details:	Smoke from cooking activated detector		

187-09	07/02/09	12:10 PM	Nutt
Incident:	Fire		
Location:	Field north of Driving Range		
Details:	Grass fire, investigation pending		
