

**OSU EHS Department  
Incident Summary**  
For the Period 06/08/09 – 06/14/09

---

167-09	06/08/09	7:40 AM	Nutt
Incident:	Fire Alarm		
Location:	Zink Hall		
Details:	Elevator maintenance crew was working on elevator and activated detector		

---

168-09	06/05/09	9:45 AM	Mason
Incident:	Gas Line Break		
Location:	Outside, west side of Seretean Center		
Details:	Utility crew was digging with a track hoe and cut the gas line		

---

169-09	06/10/09	1:38 PM	Isaacs
Incident:	Oil Spill		
Location:	Parking lot south of Thatcher and north of Bartlett		
Details:	Car pulled over parking block and oil began leaking from car		

---

170-09	06/11/09	11:56 AM	Nutt
Incident:	Fire Alarm		
Location:	Gallagher Iba Arena		
Details:	Stuck steam relief valve filled mechanical room with steam, activating detector		

---

171-09	06/11/09	4:31 PM	Nutt
Incident:	Fire Alarm		
Location:	NE side of Bennett Hall 1 <sup>st</sup> floor		
Details:	Pull box activated by unknown person; no fire		

---