

**OSU EHS Department  
Incident Summary**  
For the Period 07/13/09 – 07/19/09

---

192-09	07/13/09	7:05 PM	Kelley
Incident:	Fire Alarm		
Location:	Noble Center, 4 <sup>th</sup> floor mechanical room		
Details:	Possible dust in detector causing activation of alarm system		

---

193-09	07/15/09	6:48 PM	Kelley
Incident:	Fire Alarm		
Location:	Life Sciences West, basement hallway		
Details:	Custodian dusting possibly activated smoke detector		

---

196-09	07/16/09	7:02 AM	Spybuck
Incident:	Fire Alarm		
Location:	Multi-Modal Transit Facility, lower level		
Details:	Fire pump activation, unknown cause		

---

197-09	07/16/09	7:30 AM	Spybuck
Incident:	Fire Alarm		
Location:	Student Union, 4 <sup>th</sup> floor, Starlight Terrace		
Details:	Water in smoke detector from possible roof leakage		

---

198-09	07/16/09	7:22 PM	Spybuck
Incident:	Fire Alarm		
Location:	Multi-Modal Transit Facility, fire pump room		
Details:	Fire pump activation, unknown cause		

---

199-09	07/17/09	7:22 AM	Spybuck
Incident:	Fire Alarm		
Location:	Multi Modal Transit Facility, fire pump room		
Details:	Fire pump activation, unknown cause		

---