

**OSU EHS Department
Incident Summary**
For the Period 07/20/09 – 07/26/09

202-09	07/20/09	9:45 AM	Isaacs
Incident:	Leaking Package		
Location:	University Mailing Services		
Details:	Bottle broken in a package		

203-09	07/20/09	10:22 AM	Spybuck
Incident:	Fire Alarm		
Location:	Small Grains Bldg.		
Details:	Fault in system activated detector		

204-09	07/20/09	11:11 AM	Spybuck
Incident:	Ambulance Assist		
Location:	McElroy Hall		
Details:	Patient had fainted, refused transport		

205-09	07/20/09	1:32 PM	Isaacs
Incident:	Gas Odor		
Location:	Friend Hall		
Details:	Unknown cause, no reading on gas monitor		

206-09	07/21/09	9:23 AM	Stevenson
Incident:	Fire Alarm		
Location:	Peterson Hall		
Details:	Custodians cleaning smoke detector caused alarm activation		

207-09	07/21/09	11:20 AM	Stevenson
Incident:	Fire Alarm		
Location:	ATRC		
Details:	Electric motor caught fire, extinguished by electrician; smoke activated alarm system		

208-09	07/21/09	2:00 PM	Mason
Incident:	Fire Alarm		
Location:	Peterson Hall		
Details:	Dust in smoke detector caused activation of fire alarm		

209-09	07/23/09	8:45 AM	Sorenson
Incident:	Improper Trash Disposal		
Location:	Engineering North, 4 th floor hallway		
Details:	Pipettes disposed of into trashcan in hallway		
