

**OSU EHS Department  
Incident Summary**  
For the Period 07/06/09 – 07/12/09

---

188-09	07/06/09	8:04 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Unknown cause for activation of detector		

---

189-09	07/08/09	2:56 PM	Stevenson
Incident:	Ambulance Assist		
Location:	McElroy Ave., in front of University Laundry		
Details:	Patient fell while sorting clothes at rear of truck, possible injury to back		

---

190-09	07/08/09	7:56 PM	Kelley
Incident:	Ambulance Assist		
Location:	Gallagher Iba Arena, basketball court		
Details:	Participant in wrestling camp injured right shoulder		

---

191-09	07/09/09	6:28 AM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Dust from ceiling fan activated smoke detector		

---

194-09	07/11/09	4:36 PM	Spybuck
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	steam from shower activated detector		

---

195-09	07/12/09	12:24 AM	Spybuck
Incident:	Fire Alarm		
Location:	ATRC, NE exit		
Details:	Pull box activation, unknown cause		

---