

**OSU EHS Department  
Incident Summary**  
For the Period 08/10/09 – 08/16/09

---

|           |   |          |        |
|-----------|---|----------|--------|
| 219-09    | 08/13/09  | 10:10 AM | Kelley |
| Incident: | Fire Alarm  |          |        |
| Location: | Multimodal Transit Bldg.                                |          |        |
| Details:  | Storm blew dust or rain into roof-top AHU duct detector |          |        |

---

|           |  |          |      |
|-----------|--|----------|------|
| 220-09    | 08/13/09                                     | 10:12 AM | Nutt |
| Incident: | Fire Alarm                                   |          |      |
| Location: | Coen Animal Shelter                          |          |      |
| Details:  | No cause found for smoke detector activation |          |      |

---

|           |                         |         |      |
|-----------|-------------------------|---------|------|
| 221-09    | 08/14/09                | 1:18 PM | Nutt |
| Incident: | Ambulance Assist        |         |      |
| Location: | Wes Watkins CITD        |         |      |
| Details:  | Unknown medical problem |         |      |

---