

**OSU EHS Department
Incident Summary**
For the Period 08/17/09 – 08/23/09

222-09	08/17/09	9:59 AM	Nutt
Incident:	Ambulance Assist		
Location:	Boone Pickens Stadium, West		
Details:	Unknown medical problem		

223-09	08/17/09	3:55 PM	Kelley
Incident:	Broken gas line		
Location:	NW of Old Central		
Details:	Construction backhoe hit gas line		

224-09	08/17/09	6:47 PM	Kelley
Incident:	Fire Alarm		
Location:	Allen Hall		
Details:	Dust in smoke detector		

225-09	08/18/09	8:51 PM	Kelley
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Cooking smoke activated smoke detector		

226-09	8-19-09	7:35 AM	Nutt
Incident:	Fire Alarm		
Location:	OADDL		
Details:	Construction dust activated smoke detector		

227-09	8-19-09	11:30 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Use of blow dryer too close to smoke detector		

228-09	8-19-09	2:05 PM	Nutt
Incident:	Ambulance Assist		
Location:	Life Science West		
Details:	Unknown medical problem		

229-09	8-19-09	2:29 PM	Nutt
Incident:	Ambulance Assist		
Location:	Student Union		
Details:	Unknown medical problem		

230-09	8-20-09	10:45 AM	Nutt
Incident:	Fire Alarm		
Location:	Friend Hall		
Details:	Smoke from burned food activated detector		

**OSU EHS Department
Incident Summary**
For the Period 08/17/09 – 08/23/09

231-09	8-21-09	8:20 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Steam from shower activated smoke detector		

232-09	8-21-09	7:49 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		
