

**OSU EHS Department
Incident Summary**
For the Period 08/24/09 – 08/30/09

233-09	08/24/09	9:15 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Steam from shower activated smoke detector		

234-09	8/25/09	8:30 PM	Kelley
Incident:	Fire Alarm		
Location:	Sitlington Hall		
Details:	Cooking smoke activated smoke detector		

235-09	8/26/09	9:18 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Smoke from burned popcorn activated smoke detector		

236-09	8/27/09	2:32 PM	Nutt
Incident:	Fire Alarm		
Location:	Boone Pickens Stadium		
Details:	Accidental pullbox activation by construction worker		

237-09	8/28/09	1:19 PM	Mason
Incident:	Gas Line Break		
Location:	Behind Water Plant		
Details:	Contractor cut gas line with track hoe		

238-09	8-28-09	3:38 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Use of hair dryer close to a smoke detector activated alarm		

239-09	8-28-09	7:31 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke from cooking activated alarm		

240-09	8-29-09	10:00 AM	Spybuck
Incident:	Fire Alarm		
Location:	ATRC, Rm. 107		
Details:	Smoke detector activated; reason undetermined		

241-09	8-30-09	12:55 AM	Spybuck
Incident:	Stuck Elevator		
Location:	Wentz Hall		
Details:	Elevator occupants were freed; elevator placed out-of-service		

242-09	8-30-09	1:40 PM	Isaacs
Incident:	1 st Aid		
Location:	Soccer Complex		
Details:	1 st Aid given to a spectator		
