

**OSU EHS Department  
Incident Summary**  
For the Period 08/03/09 – 08/09/09

---

213-09	08/04/09	1:00 AM	Nutt
Incident:	Fire Alarm		
Location:	Physical Sciences Bldg.		
Details:	Custodian accidentally hit pull box		

---

214-09	08/06/09	7:55 AM	Fox
Incident:	Gas Line Break		
Location:	SE of Human Environmental Science Bldg.		
Details:	Contractor digging with backhoe		

---

215-09	08/06/09	3:20 PM	Isaacs
Incident:	Odor Investigation		
Location:	Noble Research Center		
Details:	No cause found; odor had dissipated		

---

216-09	08/07/09	2:02 AM	Nutt
Incident:	Fire Alarm		
Location:	Patchin Hall		
Details:	Use of blow dryer next to smoke detector activated fire alarm		

---

217-09	08/07/09	2:15 PM	Nutt
Incident:	Ambulance Assist		
Location:	Morrill Hall		
Details:	Patient fell down steps; taken to Student Health Services in POV with unknown ankle injury		

---

218-09	08/08/09	7:11 PM	Kelley
Incident:	Fire Alarm		
Location:	Booker Hall		
Details:	Dust from ceiling fan blew into smoke detector, which activated fire alarm		

---