

**OSU EHS Department
Incident Summary**
For the Period 08/31/09 – 09/06/09

243-09	8-31-09	4:38 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		
244-09	8-31-09	4:46 PM	Kelley
Incident:	Ambulance Assist		
Location:	Kerr-Drummond Store		
Details:	Unknown illness		
245-09	8-31-09	11:06 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Smoke from burned popcorn activated smoke detector		
246-09	9-1-09	3:42 PM	Sorenson
Incident:	Odor Investigation		
Location:	Life Sciences West		
Details:	Lab workers examining badger that was found dead on roadway		
247-09	9-2-09	7:45 AM	Nutt
Incident:	Fire Alarm		
Location:	Kamm Apartments		
Details:	Steam from shower activated smoke detector		
248-09	9-2-09	9:24 AM	Isaacs
Incident:	Oil Spill		
Location:	Advanced Technology Research Center		
Details:	Hydraulic fluid spill from scissor lift		
249-09	9-2-09	11:57 AM	Isaacs
Incident:	Chemical Spill		
Location:	Life Sciences East		
Details:	Spilled mercury from a broken thermometer		
250-09	9-2-09	7:38 PM	Kelley
Incident:	Ambulance Assist		
Location:	Gallagher-Iba Arena		
Details:	Patient injured in a fall during cheer practice		
251-09	9-4-09	10:25 AM	Spybuck
Incident:	Alarm Investigation		
Location:	Sitlington Apartments, 2 nd floor breezeway		
Details:	Piezo alarm on pull station tamper cover		

**OSU EHS Department
Incident Summary**
For the Period 08/31/09 – 09/06/09

252-09	9-4-09	6:40 PM	Kelley
Incident:	Fire Alarm		
Location:	Oklahoma Animal Disease Diagnostic Lab		
Details:	Heat from generator exhaust pipe activated heat detector		

253-09	9-5-09	4:40 PM	Nutt
Incident:	Ambulance Assist		
Location:	Boone Pickens Stadium, north side		
Details:	Unknown illness		

254-09	9-5-09	5:30 PM	Nutt
Incident:	Fire Alarm		
Location:	Boone Pickens Stadium		
Details:	Overheated elevator mechanical rooms		
