

**OSU EHS Department  
Incident Summary**  
For the Period 09/21/09 – 09/27/09

---

276-09	9-21-09	9:55 AM	Nutt
Incident:	Ambulance Assist		
Location:	Student Union		
Details:	Medical problem		

---

277-09	9-22-09	9:35 AM	Nutt
Incident:	Fire Alarm		
Location:	Kamm Hall		
Details:	Cooking smoke activated smoke detector		

---

278-09	9-22-09	2:51 PM	Isaacs
Incident:	Odor Investigation		
Location:	Noble Research Center		
Details:	No evidence found of reported gas odor		

---

279-09	9-22-09	9:18 PM	Kelley
Incident:	Smoke Investigation		
Location:	University Apartments		
Details:	Furnace turned on for 1 <sup>st</sup> time		

---

280-09	9-23-09	5:33 AM	Kelley
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Humidifier activated smoke detector		

---

281-09	9-24-09	9:24 AM	Nutt
Incident:	Fire Alarm		
Location:	Morrison Apartments		
Details:	Use of clothes steamer too close to a smoke detector		

---

282-09	9-24-09	3:44 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Use of hairspray too close to a smoke detector		

---

283-09	9-24-09	11:02 PM	Kelley
Incident:	Fire Alarm		
Location:	Bioconversion Lab		
Details:	Steam from a condenser box activated smoke detector		

---

284-09	9-25-09	11:40 AM	Nutt
Incident:	Ambulance Assist		
Location:	Parking lot near Bio-Ag Engineering Lab		
Details:	Injuries from automobile accident		

---

285-09	9-26-09	5:00 PM	Nutt
Incident:	Medical Assistance		
Location:	Parking lot south of Architecture		
Details:	Person feeling effects of dehydration		

---

**OSU EHS Department  
Incident Summary**  
For the Period 09/21/09 – 09/27/09

---

286-09	9-26-09	6:30 PM	Nutt
Incident:	Ambulance Assist		
Location:	Gallagher-Iba Arena		
Details:	Unknown medical incident		

---