

**OSU EHS Department  
Incident Summary**  
For the Period 09/7/09 – 09/13/09

---

255-09	9-8-09	10:37 AM	Nutt
Incident:	Ambulance Assist		
Location:	Hall of Fame Ave. at Colvin crosswalk		
Details:	Pedestrian hit by car in crosswalk		

---

256-09	9-8-09	1:20 PM	Nutt
Incident:	Fire Alarm		
Location:	Iba Hall		
Details:	Broken exhaust pipe on emergency generator		

---

257-09	9-9-09	1:25 PM	Nutt
Incident:	Ambulance Assist		
Location:	Classroom Bldg.		
Details:	Unknown medical problem		

---

258-09	9-10-09	1:34 PM	Isaacs
Incident:	Gas Odor		
Location:	Physical Science Bldg, north stairwell		
Details:	Bunsen burners in use.		

---

259-09	9-10-09	5:27 PM	Kelley
Incident:	Fire Alarm		
Location:	Kerr Hall		
Details:	Water surge on flow switch activated fire alarm		

---

260-09	9-10-09	6:34 PM	Kelley
Incident:	Fire Alarm		
Location:	Sitlington Apartments		
Details:	Smoke from cooking activated fire alarm		

---

261-09	9-11-09	2:25 PM	Nutt
Incident:	Ambulance Assist		
Location:	Student Union		
Details:	Unknown medical condition		

---

262-09	9-12-09	3:08 PM	Nutt
Incident:	Ambulance Assist		
Location:	Corner of Hester & Athletic Ave.		
Details:	Person struck by assailant		

---

263-09	9-12-09	9:40 PM	
Incident:	Dumpster Fire		
Location:	South of Thatcher Hall		
Details:	Possibly hot charcoals		

---

**OSU EHS Department  
Incident Summary**  
For the Period 09/7/09 – 09/13/09

---

264-09	9-13-09	7:00 AM	Stevenson
Incident:	Fire Alarm		
Location:	Conoco Phillips Alumni Center		
Details:	Duct detector activated alarm system		

---

265-09	9-13-09	12:15 PM	Stevenson
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		

---

266-09	9-13-09	1:16 PM	Stevenson
Incident:	Fire Alarm		
Location:	Morsani Apartments		
Details:	Burning paper discarded in trash can		

---