

**OSU EHS Department  
Incident Summary**  
For the Period 10/05/09 – 10/11/09

---

303-09	10-06-09	11:03 PM	Kelley
Incident:	Fire Alarm		
Location:	Friend Apartments		
Details:	Smoke from cooking activated smoke detector		

---

304-09	10-07-09	7:00 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. D		
Details:	Use of blow dryer near smoke detector		

---

305-09	10-08-09	7:03 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke from unattended cooking activated smoke detector; residents not present		

---

306-09	10-10-09	9:18 AM	Kelley
Incident:	Fire Alarm		
Location:	Willard Hall		
Details:	Dust in smoke detector; cleaned detector		

---

307-09	10-10-09	12:31 PM	Kelley
Incident:	Fire Alarm		
Location:	Classroom Building		
Details:	Room deodorizer sprayed near smoke detector		

---

308-09	10-10-09	8:40 PM	Kelley
Incident:	Fire Alarm		
Location:	Willard Hall		
Details:	Faulty smoke detector		

---

309-09	10-10-09	9:20 PM	Kelley
Incident:	Fire Alarm		
Location:	Willard Hall		
Details:	Water from roof leak activated smoke detector		

---